

VISIT...

LANZAROTE
Caliente.COM

Pure \$1.50

22-11-11

THE POCKET BOOK OF REFRIGERATION AND ICE-MAKING

EDITED BY

A. J. WALLIS-TAYLER, C.E.

ASSOC. MEMB. INST. C.E.

ETC.

AUTHOR OF "REFRIGERATING AND ICE-MAKING MACHINERY," "REFRIGERATION
COLD STORAGE AND ICE-MAKING," ETC. ETC.

Fourth Edition, Enlarged

ILLUSTRATED BY THIRTY-ONE DIAGRAMS



NEW YORK


THE NORMAN W. HENLEY
PUBLISHING COMPANY

132 NASSAU STREET

1905

Wallis

3-vc



UNIVERSITY OF MICHIGAN
LIBRARY
ANN ARBOR, MICH.

PUBLISHERS' PREFACE.

THE rapid extension of the use of Refrigerating and Ice-making Machinery, in recent years, with the establishment in important centres of Cold Stores and Ice Factories, has led to the demand for a handy POCKET-BOOK which should contain in an accessible form such formulæ, data, tablés, and memoranda as are constantly required by persons engaged or interested in the industries connected with Refrigeration and Cold Storage. The present little volume (which, since its first issue, has been revised and enlarged by the addition of fresh matter and diagrams) is designed to meet this demand.

The contents of the POCKET-BOOK may be briefly described as comprising amongst other matter the subjects of Refrigeration (in outline); Cold Storage; Ice-making and the Storing of Ice; Insulation;

the Testing and Management of Refrigerating Machinery; General Tables and Memoranda, etc., etc. There is also a carefully prepared Index, whereby reference may readily be made to the information furnished upon any particular subject.

THE
PUBLISHERS
OF THE

TABLE OF PRINCIPAL CONTENTS.

PAGE

SECTION I.

REFRIGERATION IN GENERAL: The Mechanical Theory of Heat—Refrigerating Apparatus—The Chemical or Liquefaction Process—Cold-air Machines—Vacuum Machines—Absorption Machines—The Compression Machine—The Application of the Entropy, or Theta-phi, Diagram to Refrigerating Machines—The Comparative Efficiency of various Refrigerating Machines—The Production of very Low Temperatures—Capacity of Refrigerating Machines—Approximate Allowance per Ton Capacity to be made when selecting a Machine for Refrigerating Purposes—Condensers—The Forecooler—The Analyser—The Liquid Receiver—Ether Machines—Tables, etc.	1-67
--	------

SECTION II.

COLD STORAGE: Amount of Refrigeration required—Amount of Refrigerating Pipes necessary for Chilling, Storage, and Freezing-chambers—Number of cubic feet covered by 1-ton Refrigerating Capacity for Twenty-four Hours—Estimate of Refrigeration in Breweries—Refrigerating Capacity in B.T.U. required per cubic foot of Storage Room in Twenty-four Hours—Refrigerating Capacities—Variation in Capacity of a Refrigerating Machine, etc., and Economy of Direct Expansion—Cubic feet of Ammonia Gas per Minute to produce one ton of Refrigeration per Day—Determination of Moisture in Air—Psychrometers—Hygrometers—Correct Relative Humidity for a Given Temperature in Egg Rooms—Specific Heat and Composition of Victuals—Temperatures adapted for the Cold Storage of Various Articles—Mean Temperature of Principal Cities of the World—Cold Storage Charges (England)—Conditions of Deposit and Regulations—Cold Storage Charges (United States)—Terms of Payment of Cold Storage and Freezing Rates—Cold Storage Charges (France)—Tables, etc. ...	68-99
--	-------

SECTION III.

ICE-MAKING AND STORING ICE: Ice-making—Pure Water—Simple Rules for ascertaining the Quality of	
--	--

So-called Mineral Water—Testing by Reagents— Freezing Tank or Box—Brine for Use in Refrigerating and Ice-making Plants—Solutions of Chloride of Calcium—Comparison of Various Hydrometer Scales —Freezing Times for Different Temperatures and Thicknesses of Can Ice—Storing Ice—Tables, etc.	100-114
---	---------

SECTION IV.

INSULATION: Results of Tests to determine the Non- conductive Values of Different Materials—Heat in Units transmitted per Square Foot per Hour through Various Substances—Walls for Cold Stores—Divisional Partitions for Cold Stores—Flooring for Cold Stores— Flooring for Ice Houses—Ceilings for Cold Stores and Ice Houses—Door Insulation—Window Insulation— Tank Insulation—Tables, etc.	115-135
---	---------

SECTION V.

TESTING AND MANAGEMENT OF REFRIGERATING MA- CHINERY: Testing—Interpretation of Compressor Diagram—Management of Ammonia Compression Machines—Leaks in Ammonia Apparatus—Leaks in Carbonic Acid Machines—Lubrication of Refrigerating Machinery—Form for Engineer's Daily Report—Light- ing Cold Stores	136-150
---	---------

SECTION VI.

GENERAL TABLES AND MEMORANDA: Experiments in Wort Cooling—Tension of Aqueous Vapour—Physical Constant of Gases—Properties of Saturated Steam— Heat of Combustion of Various Fuels—Specific Heat of Water at Various Temperatures—Specific Heat of Metals—Specific Heat of Liquids—Specific Heat of Gases—Thermal Units—Loss of Pressure by Friction of Compressed Air—Friction of Air in Tubes—Coefficients for Efflux of Air from Orifices—Centrifugal Fans— Hydraulics—Useful Information	151-175
---	---------

INDEX	177-184
--------------	---------

ILLUSTRATIONS.

FIG.		PAGE
1.	Diagram illustrating Cold-air Cycle	6
2.	Diagram illustrating Operation of Absorption Machine	8
3.	Diagram illustrating Cycle wherein a Volatile Liquid and Compression are employed	9
4.	Diagram illustrating Theoretically Perfect Reversible Cycle, with Pressure Volume Ordinates	13
5.	Diagram illustrating Theoretically Perfect Reversible Cycle, with Temperature Entropy Ordinates	13
6, 7.	Diagrams illustrating Operations in Air Refrigerators with Open Cycle	14
8.	Entropy Diagram, showing application to the Cold-air Cycle	15
9.	Entropy Diagram for 1 lb. of Saturated Ammonia Vapour	16
10.	Entropy Diagram for 1 lb. of Saturated Carbonic Acid Vapour	16
11.	Entropy Diagram, showing Working Cycle for 1 lb. of Saturated Ammonia Vapour	18
12.	Entropy Diagram, showing Working Cycle for 1 lb. of Saturated Carbonic Acid Vapour	19
13.	Diagram showing Loss of Efficiency with Ammonia and Carbonic Acid owing to use of Expansion Valve ...	21
14.	Diagram showing Percentage of Efficiency of Working Cycle of Carbonic Acid as compared with Ammonia	21
15.	Diagram showing Loss of Efficiency with Brine Circula- tion compared with Direct Expansion of Ammonia ...	23
16.	Diagram showing Relative Compressor Capacity with Ammonia at Various Expansion Pressures and Tempe- ratures	23

FIG.		PAGE
17.	Diagram showing Hampson's Apparatus for the production of very Low Temperatures	25
18.	Diagram showing Linde's Apparatus for the production of very Low Temperatures	25
19, 20.	Diagrams showing Curves of Latent Heat of Vaporisation, and Curves of Absolute Pressure for Saturated Vapours of Ammonia, Sulphurous Acid, and Carbonic Acid	48
21.	Diagram giving Efficiency Curves of a Perfect Refrigerating Machine at Various Limits of Temperature ...	64
22.	Diagram showing Variation in Capacity, Cost of Fuel, and Work Required, of a Refrigerating Machine ...	74
23.	Diagram from Compressor with Parts in Good Order ...	139
24.	Diagram from Compressor with an Excessive Amount of Clearance	139
25.	Diagram from Compressor indicating the Binding of the Pressure Valve	139
26.	Diagram from Compressor indicating too great a Resistance in the Pressure and Suction Valves	139
27.	Diagram from Compressor indicating the Binding of the Suction Valve	140
28.	Diagram from Compressor indicating Leaking of Compressor Valves	140
29.	Diagram from Compressor indicating Defective Packing of Piston	140
30.	Diagram illustrating Arrangement of Electric Lighting on the Series Circuit System	150
31.	Diagram illustrating Arrangement of Electric Lighting on the Parallel Circuit System	150

THE POCKET-BOOK OF REFRIGERATION AND ICE-MAKING.

SECTION I. REFRIGERATION IN GENERAL.

THE MECHANICAL THEORY OF HEAT.

HEAT pervades every substance known. Lord Armstrong said, "According to the new theory, heat is an internal motion of molecules, capable of being communicated from the molecules of one body to those of another; the result of this imparted motion being either an increase of temperature or the performance of work." The result of Joule's experiments was to demonstrate that under all circumstances the quantity of heat generated by the same amount of force is fixed and invariable. Professor Clerk Maxwell was of the opinion that heat, considered with respect to its power of warming things and changing their state, is a quantity strictly capable of measurement, and not subject to any variation of quality or kind.

The deductions to be arrived at on accepting this theory are, that if heat is a motion it must be an eternal one; the generation of heat in any substance must be additional to the heat that has been already generated in it or transferred thereto; heat can be lost or done away with to a degree only, as it is always of uniform quality, and it follows therefore that its annihilation must in every case be a definite part of the entire amount, and cannot be a reduction in quality.

The rational conclusion to be come to from the above is that the reduction of temperature or cooling of any substance is simply the withdrawal or annihilation of a greater or lesser part of its own heat.

Refrigeration may be defined as the art of reducing the temperature of any body, or of maintaining the said temperature below that of the atmosphere.

REFRIGERATING APPARATUS.

Widely, refrigerating apparatus may be classed under two main heads, viz. chemical and mechanical.

In the first, or apparatus working on the chemical system, the more or less rapid dissolution of a solid is utilised to abstract heat, and it is generally designated the liquefaction process.

The second, or mechanical process, comprises apparatus operating on four different systems, viz.: cold-air machines, in which the air is first compressed, then cooled, and afterwards permitted to expand whilst doing work, that is to say, practically, by first applying heat to ultimately produce cold; vacuum machines, wherein the evaporation of a portion of the liquid to be cooled, assisted by the action of an air-pump, and of sulphuric acid, effects the abstraction of heat; absorption machines, in which the abstraction of heat is effected by the evaporation of a separate refrigerating agent of a more or less volatile nature, under the direct action of heat, which agent again enters into solution with a liquid; and lastly, compression machines, wherein the abstraction of heat is effected by the evaporation of a separate refrigerating agent of a more or less volatile nature, which agent is subsequently restored to its original physical condition by mechanical compression and cooling.

THE CHEMICAL OR LIQUEFACTION PROCESS.

During the change of the physical condition of a substance, for instance, whilst it is passing from a solid to a liquid form, the cohesive force is overcome by energy in the

form of heat, and this may be brought about without change in sensible temperature, provided the heat be absorbed as fast as it is supplied from the exterior, as in the case of melting ice, the temperature of which remains constant at 32° Fahr., any increase or decrease in the heat supplied simply hastening or retarding the rate of melting, but in no way affecting the temperature. Mixtures composed of some salts with water or acids, and of certain salts with ice, however, forming liquids having freezing points lower than the original temperatures of the mixtures, act in a different manner, the tendency to pass into the liquid form being in this case so strong that a more rapid absorption of heat takes place than is capable of being supplied from without, and consequently a consumption takes place of the store of heat of the melting substances themselves. The natural result of this action is that the temperature of the latter falls, until such time as the rate of melting and the rate at which heat is supplied from the exterior become equalised. The degree to which the temperature can be lowered depends to a certain extent on the state of hydration of the salt and the percentage of it present in the mixture. The salts used in ordinary freezing mixtures are generally those of certain alkalies which almost exclusively possess the necessary degree of solubility at low temperatures, and the following table gives the mixtures usually employed :—

TABLE OF PRINCIPAL FREEZING MIXTURES.

COMPOSITION OF FREEZING MIXTURES.	Reduction of temperature in degrees Fahr.		Amount of fall in degrees Fahr.
	From	To	
Snow or pounded ice 2 parts; muriate of soda 1 part		- 5	
Snow 5; muriate of sodium 2; muriate of ammonia 1		- 12	
Snow 24; muriate of sodium 10; muriate of ammonia 5; nitrate of potash 5		- 18	
Snow 12; muriate of sodium 5; nitrate of ammonia 5		- 25	
Snow 4; muriate of lime 5	+ 32	- 40	72
Snow 1; chloride of sodium or common salt 1	+ 32	0	32
Snow 2; muriate of lime crystallized 3	+ 32	- 50	82
Snow 3; dilute sulphuric acid 2	+ 32	- 23	55
Snow 3; hydrochloric acid 5	+ 32	- 27	59
Snow 7; dilute nitric acid 4	+ 32	- 30	62
Snow 8; chloride of calcium 5	+ 32	- 40	72
Snow 2; chloride of calcium crystallized 3	+ 32	- 50	82
Snow 3; potassium 4	+ 32	- 51	83
Snow 2; chloride of sodium 1		- 5	
Snow 5; chloride of sodium 2; chloride of ammonia 1		- 12	
Snow 14; chloride of sodium 10; chloride of ammonia 5; nitrate of potassium 5		- 18	
Snow 12; chloride of sodium 5; nitrate of ammonia 5		- 25	
Snow 2; dilute sulphuric acid 1; dilute nitric acid 1	- 10	- 56	46
Snow 12; common salt 5; nitrate of ammonia 5	- 18	- 25	7
Snow 1; muriate of lime 3	- 40	- 73	33
Snow 8; dilute sulphuric acid 10	- 68	- 91	23
Chloride of ammonia 5; nitrate of potassium 5; water 16	+ 50	+ 4	46
Nitrate of ammonia 1; water 1	+ 50	+ 4	46
Chloride of ammonia 5; nitrate of potassium 5; sulphate of sodium 8; water 16	+ 50	+ 4	46
Sulphate of sodium 5; dilute sulphuric acid 4	+ 50	+ 3	47
Sulphate of sodium 8; hydrochloric acid 9	+ 50	- 0	50
Nitrate of sodium 3; dilute nitric acid 2	+ 50	- 3	53
Nitrate of ammonia 1; carbonate of sodium 1; water 1	+ 50	- 7	57
Sulphate of sodium 6; chloride of ammonia 4; nitrate of potassium 2; dilute nitric acid 4	+ 50	- 10	60
Phosphate of sodium 9; dilute nitric acid 4	+ 50	- 12	62
Sulphate of sodium 6; nitrate of ammonia 5; dilute nitric acid 4	+ 50	- 14	64

TABLE OF PRINCIPAL FREEZING MIXTURES—*Continued.*

COMPOSITION OF FREEZING MIXTURES. (Materials previously cooled.)	Reduction of temperature in degrees Fahr.		Amount of fall in degrees Fahr.
	From	To	
Phosphate of sodium 5 ; nitrate of ammonia 3 ; dilute nitric acid 4	0	-34	34
Phosphate of sodium 3 ; nitrate of ammonia 2 ; dilute mixed acid 4	-34	-50	16
Snow 3 ; muriate of lime 4	+20	-48	68
Snow 1 ; muriate of lime crystallized 2	0	-66	66
Snow 2 ; muriate of lime 3	-15	-68	53
Snow 8 ; dilute sulphuric acid 3 ; dilute nitric acid 3	-10	-56	46
Snow 3 ; dilute nitric acid 2	0	-46	46
Snow 1 ; dilute sulphuric acid 1	-20	-60	40
Snow 2 ; muriate of lime crystallized 3	-40	-73	33
Snow 8 ; dilute sulphuric acid 10	-68	-91	23

COLD-AIR MACHINES.

This class of machine is based upon one of the simplest principles of physics, that is to say, that the compression of air or other gas generates heat, and the subsequent expansion of this air or gas, cold. Mechanical work and heat being respectively convertible, it naturally follows that if air or other gas be caused to perform certain work on a piston during expansion, the performance of this work will cause its store of caloric to become exhausted to a degree equal to the thermal equivalent of the work done, the air or other gas after expansion being at a lower temperature than that at which it was before expansion ; that is, of course, provided always that no heat be supplied from any source to restore that so lost.

Cold-air machines all operate on the same general principle (see diagram, Fig. 1). The air is first compressed in a compressor, and the heat which is generated by this compression is removed by means of water, the cold air produced by expansion being employed for refrigeration. But there have been several notable

improvements during the past few years, practically removing most of the old defects, which make them compare favourably, with machines using more or less volatile agents, Cole's "Arctic" Machine being one that embodies important improvements.

The cycle of operations may be a perfect or closed one when the same air is in constant circulation, or where it is desirable to have pure air in the storage chambers, the air is rejected after once passing through the cycle, and fresh air is admitted at each stroke of the compressor.

Air machines, working at a comparatively low pressure, necessitate the compression and expansion cylinders being of a larger size than in compression machines using higher




FIG. 1.—Diagram illustrating cold-air cycle.

pressures, but the total actual space occupied is no more, as cold-air machines are generally self-contained, there being no additional apparatus required in the form of expansion pipes, condensers, circulating pumps, etc., obviously, therefore, a simple, cold-air system, in which the defects of the old machines have been eliminated, has much to recommend it.

In the early days of cold air it was considered a disadvantage and uneconomical to reduce air to a very low temperature; but these objections are now entirely overcome by the improved methods of making the cold-air ducts or trunking, by which the loss is reduced to a minimum, and is almost inappreciable.

VACUUM MACHINES.

Vacuum machines, together with absorption machines, compression machines, and binary, or dual, or mixed, absorption and compression machines, all come under the category of vaporisation machines, that is to say, of machines which practically utilise the heat of vaporisation for purposes of refrigeration. In a vacuum machine the refrigerating agent or medium is, as has been already stated, water, its volatilisation at a temperature sufficiently low being effected by the means of a vacuum pump, assisted by sulphuric acid, by which the vapours are absorbed as soon as they are formed, and in this manner rendering the action of the vacuum very effective. The sulphuric acid can be again concentrated for use, and so on *ad infinitum*.

ABSORPTION MACHINES.

In its action the absorption machine resembles the vacuum machine, with this difference, however, that instead of water, some such liquid as anhydrous ammonia (NH_3), capable of evaporating at a low temperature without the assistance of a vacuum, is employed as a refrigerating agent or medium. Instead of sulphuric acid being employed to absorb the vapour, water is employed for that purpose, and from this water the vapour is again separated by distillation and is liquefied by the pressure which takes place in the still, and by the action of the condensing water. (See diagram, Fig. 2.)

In this manner absorption machines can be operated continuously, the ammonia solution or *aqua ammonia* being passed into a still or generator, usually heated by a steam coil or worm, and the ammonia vapour being conducted thence to a condenser in which it is cooled and becomes liquefied into anhydrous ammonia owing to the pressure due to its own accumulation. The anhydrous ammonia is kept in a liquid ammonia receiver, from which it passes to the coils of the refrigerator wherein it expands or evaporates, effecting an amount of refrigeration corresponding to its heat of vaporisation. After performing

this duty the vapour enters the absorber and is there brought into contact with the weak solution of ammonia coming from the bottom of the still, and is reabsorbed by it with generation of heat, which latter is removed by the cooling water. Both the rich and cold solution of ammonia coming from the absorber and going to the still, as well as the poor and hot solution coming from the still




FIG. 2.—Diagram illustrating operation of absorption machine.

and going to the absorber, are passed through a device called an interchanger, by which their temperatures are equalised. The rich ammonia solution is pumped from the absorber into the still or generator.

THE COMPRESSION MACHINE.

Machines operating on the compression principle (see diagram, Fig. 3) utilise the latent heat of vaporisation of the substances having a low boiling point, and, whatever the refrigerating agent or medium that may be employed, they all practically act in the same manner; that is to say, the vapour or gas due to the expansion or vaporisation of the refrigerating agent or medium, in the refrigerating or expansion coils, passes into a compressor operated by any suitable power by which the gas or vapour is forced into the

coils of the condenser, and is there liquefied by the aid of the cooling water; the liquid thus formed then enters a liquid receiver, from which it is allowed to pass to the refrigerating coils through an expansion or flash valve or cock, by which the desired regulation can be effected. It will be seen that the process is a continuous one, representing a complete cycle of operations, inasmuch as the operating agent or medium periodically returns to its primary condition in a way that will more or less approach reversibility in accordance with the method of working peculiar to each machine.




FIG. 3.—Diagram illustrating cycle wherein a volatile liquid and compression are employed.

A perfect reversible compression system comprises the following changes, viz. : An isothermal change due to the vaporisation or gasification of the refrigerating agent or medium at the constant temperature of the refrigerator; an adiabatic change, caused by the compression of the vapour or gas without the addition of heat; a second isothermal change, due to the condensation of the compressed gas or vapour at the constant temperature of the condenser; and, finally, a second adiabatic change, owing to the temperature of the liquid being reduced from that of the condenser to that of the refrigerator by a portion of the liquid being vaporised or gasified, and performing work by moving a piston, thus once more returning the refrigerating

medium or agent to its primary state, and thereby completing the cycle. It is presumed that the above changes take place in such a manner that the transfers of heat follow infinitesimal variations in temperature only, and the changes in volume occur in connection with infinitesimal variations of pressure. The changes can be likewise carried out in the obverse direction, the cycle being therefore a reversible one, and a refrigerating machine, which, it may here be observed, is the exact obverse to a heat engine, operated on this plan, will give as economical results as it is possible to obtain in practice.

For this reason it has been observed by Professor J. E. Siebel that the heat H , removed by a refrigerating apparatus operated strictly on the above-mentioned bases, has a certain and well-defined relation to the work or mechanical power, W , required to lift the same in the cycle of operation. If, in a refrigerating machine so operated, t_1 is the temperature of the condenser and t_0 the temperature of the refrigerator (T_1 and T_0 designating the corresponding absolute temperatures), thermodynamics teach us that the following relations exist:—

$$\frac{H}{W} = \frac{t_0 + 460}{t_1 - t_0} = \frac{T_1}{T_1 - T_0}$$

Thermodynamically speaking, says the same authority, there should be no difference in economy on account of the nature of the circulating fluid if a perfect cycle of operation was carried out; but practically, this is not done. In all compression machines, the fourth operation, the reduction of the temperature of the liquid while doing work, is not carried out, but the liquid is cooled at the expense of the refrigeration of the system. No work is attempted, as the amount obtainable would not be in proportion to the expense involved in procuring the same.

The value of a circulating medium, it will be seen, is dependent upon its latent heat of vaporisation per pound, inasmuch as this quality governs its refrigerating effect. Regarding the choice of the circulating medium or agent, therefore, the above point must be taken into consideration, as well as the fact that the size of the compressor depends on the number of cubic feet of vapour that must

be taken in to produce a certain amount of refrigeration, and that the strength of its parts will depend on the pressure of the circulating medium. Also that the loss of refrigeration, on account of cooling the liquid circulating medium, depends on the specific heat of the liquid as compared with the heat of volatilisation.

From the following table it will be seen that with ammonia the loss due to the cooling of the liquid, as shown in percentages for every degree difference in temperature of condenser and refrigerator, is less than in the case of other liquids, and total refrigerating effect per pound of liquid is largest, thus readily accounting for the preference generally given to ammonia as the circulating medium or agent. The only advantage possessed by sulphurous acid is the lower pressure of its vapour, and that of carbonic acid the smaller size of compressor necessary; the loss due to heating of liquid is very large in the latter case.

TABLE OF QUALITIES OF PRINCIPAL LIQUIDS EMPLOYED IN REFRIGERATION.—(*Siebel.*)

	Pressure in lbs. per square inch, at 0° F.	Heat of Vaporisation per lb., at 0° F.	Volume cubic feet per lb., at 0° F.	Specific Heat of Liquid.	Heat of Vaporisation per cubic foot.	Relative Volume of Compressor for Equal Refrigeration.	Loss due to Cooling Liquid.
Sulphurous Acid..	10	171.2	7.35	0.41	23.3	61.70	0.24
Carbonic Acid ..	310	123.2	0.277	1.00	447.	3.24	0.81
Ammonia.. ..	30	555.5	9.10	1.02	61.7	23.3	0.18

THE APPLICATION OF THE ENTROPY, OR THETA-PHI, DIAGRAM TO REFRIGERATING MACHINES.

Entropy is the co-ordinate with the temperature of energy, that is to say, length on a diagram, the area of which is energy in heat-units; and the height of which is

absolute temperature; the abscissæ being the quotients found by the division of the heat quantity by the absolute temperature. Absolute temperature is denoted by the Greek letter *theta*, and entropy by the Greek letter *phi*, hence the temperature-entropy diagram is generally called the theta-phi (θ, ϕ) diagram.

In the case of an indicator diagram the co-ordinates are pressure and volume, the work done per stroke in foot-pounds being represented by the area. The theta-phi diagram represents the heat units as converted into work per pound of the working fluid, the area representing a quantity of heat in heat units, the vertical ordinates absolute temperatures, and the horizontal ordinates the quantity known as entropy. The special applicability of entropy diagrams to refrigeration was pointed out in 1892 by an American engineer, Mr. George Richmond, and they have also been used by Professor Linde for a considerable time past.

The following application of the entropy diagram to refrigerators is abstracted from a useful little work (to which the reader is referred for fuller information on the subject) by Henry A. Golding, A.M.I.M.E., on "The Theta-phi Diagram," published by the Technical Publishing Co., Ltd., Manchester: "The cycle of operations in refrigerators is exactly the reverse of that in the Carnot hot-air engine. Instead of taking in heat at a high temperature τ_1 , and transforming part of it into work, and rejecting the remainder at a lower temperature τ_2 , as in the heat-engine, the working substance in the refrigerator receives its heat at the lower temperature τ_2 , and discharges it at a higher temperature τ_1 , the extra energy required being obtained from external work done on the gas. The theoretically perfect cycle that is reversible is shown in Fig. 4 with pressure-volume ordinates, and in Fig. 5 with temperature-entropy ordinates. The first stage of the cycle, A to B, consists of the adiabatic expansion of a certain quantity of air, the temperature falling from τ_1 to τ_2 . From B to C the expansion is continued isothermally at constant temperature τ_2 , the air receiving heat from the body which it is desired to cool, the amount of heat abstracted being equal to the area EBCF (Fig. 5). Compression commences

at C, and is at first carried on adiabatically at constant entropy (or isentropically) from C to D, the temperature rising from τ_2 to τ_1 , and is finally completed by isothermal compression from D to A, at constant temperature τ_1 , a quantity of heat being rejected to the water-jacket equal




FIG. 4.—Diagram showing Theoretically Perfect Reversible Cycle, with Pressure Volume Ordinates.




FIG. 5.—Diagram showing Theoretically Perfect Reversible Cycle, with Temperature-Entropy Ordinates.

to FDAE. The heat expended in the process is the equivalent of the work done on the gas, and is equal to the area ABCD in both diagrams. The heat absorbed from the substance to be cooled is equal to the rectangle EBCF (Fig. 5), and the efficiency, therefore (in its thermodynamic sense), is equal to the ratio—

$$\frac{EBCF}{ABCD} = \frac{\tau_2}{\tau_1 - \tau_2}$$

It is thus seen clearly how the efficiency is increased by reducing the difference of temperature between τ_1 and τ_2 , and as the ratio—

$$\frac{\tau_2}{\tau_1 - \tau_2}$$

may sometimes be greater than unity, it is better known as “the coefficient of performance” (see Howard Lectures, by Professor Ewing, on “The Mechanical Production of Cold,” Society of Arts, 1897).

The series of operations in air refrigerators with an open cycle is somewhat different, and is shown in Figs. 6 and 7.

In this case the air is taken from the cold room, and compressed adiabatically from A to B. It is then cooled at constant pressure, the temperature falling from B to C (Fig. 7), and contracting in volume from B to C (Fig. 6), after which it is passed into the expansion cylinder, where it expands adiabatically from C to D, and is discharged to the cold room again. The work done on the air in the compression cylinder is equal to the area EBAF (Fig. 6), or GCBH (Fig. 7), and that done by the air in the expansion cylinder is equal to ECDF (Fig. 6), or GDAH (Fig. 7); so that the net external work required is the difference of these




FIG. 6.—Diagram showing Operations in Air Refrigerators with Open Cycle.




FIG. 7.—Diagram showing Operations in Air Refrigerators with Open Cycle.

two quantities, represented by the area enclosed by ABCD in both diagrams. The efficiency of the process will be represented by the ratio of the two areas—

$$\frac{ECDF}{ECAF} \quad (\text{Fig. 6})$$

but, as AB and CD are similar adiabatic curves, this will be equal to the ratio—

$$\frac{EC}{EB} \quad \text{or} \quad \frac{FD}{FA}$$

The following brief extracts from a paper on "The Theory and Practice of Mechanical Refrigeration," by temp. T. R. Murray, Wh.Sc., read before the Institution of it is dealers and Shipbuilders, Scotland, in December, 1897, equal to the interest :—The entropy diagram (Fig. 8) shows an

example of an application to the cold-air cycle, the air being taken in at a temperature t_1 of 18° Fahr., the temperature of the refrigeration chamber, and rejected at a temperature t_2 of 70° Fahr., which is the temperature of the air after being cooled by the cooling water; the temperature at which the cold air is discharged into the chamber to be taken as -85° Fahr., and the highest temperature to which it is heated in compression to be taken as 250° Fahr. Considering the machine to be theoretically perfect, then




FIG. 8.—Entropy Diagram, showing Application to the Cold-air Cycle.

the diagram ABCD is obtained, in which D to C is the rise of temperature of the air during compression from 18° Fahr. to 70° Fahr.; CB represents the removal of heat in the cooler; B to A represents the cooling in expansion cylinder; and A to D, the collection of heat in the refrigerated chamber. The proportions of the areas ABCD and ADEF represent the proportion of work done to the refrigeration produced. The rectangle AE will be found to be 9.19 times the rectangle BD. In the working cycle, where the air is raised to 250° Fahr. in the compressor, this will be represented on the diagram by point H, and the fall in

temperature during cooling by HB. The temperature being again lowered in expansion cylinder to -85° Fahr., is represented by the vertical line BG, and the collection of heat in the chamber by GD. The diagram of work is now BHDG, which is about 3.75 times the theoretical amount, and when compared with the refrigeration done, now represented by area GDEF, gives an efficiency of only a little over 2. Losses by friction, moisture, etc., reduce this in practice to a little over $\frac{3}{4}$.

Fig. 9 is an entropy diagram for 1 lb. of saturated




FIG. 9.—Entropy Diagram for 1 lb. of Saturated Ammonia Vapour from -40° to $+100^{\circ}$ Fahr.




FIG. 10.—Entropy Diagram for 1 lb. of Saturated Carbonic Acid Vapour from -40° to $+100^{\circ}$ Fahr.

ammonia vapour, from the temperature of -40° Fahr. to $+100^{\circ}$ Fahr. FE is the basis line, the temperature at this point being absolute zero, -460° Fahr.; A, the absolute temperature at -40° Fahr. = 420° Fahr. = T_1 ; B, the absolute temperature at $+100^{\circ}$ Fahr. = 560° Fahr. = T_2 ; AD = the entropy at T_1 ; and considering that a unit weight of ammonia, say 1 lb. is being dealt with, the length


AD can be determined by taking $\frac{L}{T} = \frac{603.45}{420} = 1.436$. In

the same way, $BC = \frac{L_2}{T_2} - 0.922$. The point G has still to be determined in order to find the position of point B. Considering, however, that DC represents the compression in compressor, CB the giving out of heat to the condenser, BA the expansion through the orifice of expansion valve, and AD the taking in of heat in the refrigerator, it will be understood that AG really represents the entropy of the liquid heat carried into the refrigerator; and its length may be found by the expression $AG = c \log_e \frac{T_2}{T_1}$, where c = mean specific heat of liquid between T_1 and T_2 . A simpler formula is $AG = \frac{h}{\frac{T_1 + T_2}{2}}$, where h = liquid heat T_2 - liquid heat T_1 .

By calculating these values for various temperatures between T_1 and T_2 , the points through which to draw the line BA are found. For ammonia it will be found to be practically a straight line, so that it is quite near enough to find the point B only and draw a straight line between A and B. By plotting as abscissæ the values of the entropy of the latent heat at same temperatures, the curve CD will be formed.

Fig. 10 is an entropy diagram for 1 lb. of saturated carbonic acid vapour from the temperature of -40° Fahr. to $+100^\circ$ Fahr., the same construction also applying in this case, but the formation being a continuous curve with a rounded top. To find the efficiency, by means of these diagrams, of a machine working with the same temperatures T_1 and T_2 as taken with the cold-air cycle, and considering, in the first place, the cycle as being the Carnot or perfect one, compression and expansion will both be adiabatic, therefore they will be represented by vertical lines, and the giving up of heat to the condenser, as well as the collection of same in the refrigerator, being isothermal, then will be shown as horizontal lines. Draw horizontals ad and be , and verticals b_gf and c_hc . Then the area bhf will represent the work of the compressor, and the area ge the refrigeration done.

that the cooling agent simply circulates in pipes through the chambers being cooled, and must of necessity be colder in order to secure a transference of heat. The difference in temperature depends on the cooling surface, or length of



F.G. 12.—Entropy Diagram, showing Working Cycle for 1 lb. of Saturated Carbonic Acid Vapour from -40° to $+100^{\circ}$ Fahr.

pipng, as compared with the cubic capacity of the chamber, and may be in practice from 10° to 25° Fahr. Suppose that allowance be made for a difference of 18° Fahr., then the lower temperature T_1 will correspond to 0° Fahr. Again, the working cycle falls away from the Carnot cycle in not being

reversible, owing to expansion taking place through a small orifice instead of by means of an expansion cylinder. Thus the liquid carries a certain amount of heat into the refrigerator, which goes to heat up the expanded gas, rendering part of it unavailable for refrigeration. The amount of this liquid heat varies for each agent, and the entropy diagrams, Figs. 11 and 12, to a larger scale, show the working cycle in each case. In these, the areas agb represent the additional work that the use of an expansion cycle would have obviated. The heat which ought to have been spent in producing this work is carried by the liquid into the refrigerator, and this therefore falls to be deducted from the refrigeration done, so that the latter is now represented by the area $g_1 h e f_1$, being less than before by the rectangle $g f_1$, which is equal to area agb .

COMPARATIVE EFFICIENCY OF REFRIGERATING MACHINES.

Professor Ewing estimates the efficiency of the absorption machine at from two and a half to three times that of the cold-air machine, and the efficiency of the vapour-compression machine at from five to six times that of the cold-air machine, and from two and a half to three times that of the absorption machine.

In comparing one system with another, the theoretical values obtained at the machines are not sufficient, as the combined losses in piping, brine cooling, circulating pumps, fans, and any other auxiliary apparatus, must be considered, and only the actual net useful duty performed taken into account. And further, an amount must be added to the capital interest in a plant for recharging with gas (except air machines), including incidentals such as calcium chloride and other items necessary to the system.

Refrigerating machines, to be efficient, must be efficient when working in hot weather or tropical climates. Some systems fall off considerably when the cooling water is about 60° Fahr., and the atmosphere above 70° Fahr., and in some the cost of working is so high under tropical conditions as to render their use almost prohibitive. The cold-air system does not fall off in the same ratio, and for many purposes is the most economical. All the losses under this system are in the machine, as the air after leaving the

machine does not pass through any secondary process, but is conducted direct to the storage or cooling chamber without the use of brine, circulation pumps, fans, etc.

RATIO OF PRESSURE OF SO_2 , NH_3 , and CO_2 .

(From Landolt & Bornstein's *Physico-Chemical Tables*, Lister & Co., Ltd., Catalogue.)

Temperature in Degrees Fabr.	Pressure expressed in pounds per square inch.		
	Sulphurous Acid. SO_2 .	Ammonia. NH_3 .	Carbonic Acid. CO_2 .
-4	—	12	276
+5	—	18	325
14	0	27	374
23	4	35	435
32	8	46	502
41	11	59	566
50	18	73	660
59	25	90	750
68	32	108	840
77	41	129	950
86	51	152	1,060
95	62	180	1,280
104	75	208	1,320




FIG. 13.—Diagram showing Loss of Efficiency with NH_3 and CO_2 owing to use of Expansion Valve.—(Murray, *Inst. Engrs. and Shipbuilders, Scotland*, 1897.)




FIG. 14.—Diagram showing Percentage of Efficiency of Working Cycle of CO_2 as compared with NH_3 .—(Murray, *Inst. Engrs. and Shipbuilders, Scotland*, 1897.)

RESULTS OF TEST EXPERIMENTS WITH COLD-AIR MACHINES.

	Haslam.*	Bell-Coleman.†	Cole's "Arctic"‡	
			No. 4 Size.	No. 1 Size.
Diameter of comp. cy. in ins. ..	25½ (2 cy.)	28	11	6½
Diameter of exp. cy. in ins. ...	19½ "	21	9	5½
Stroke of each	36	24	12	8
Revs. per minute	72	63·2	96	160
Air pres. in receiver (abs.) in lbs. per sq. in. ...	64	61	65	75
Temp. of air entering comp. cy. (cont. vapour up to 88 per cent. of sat.) in deg. Fahr. ..	—	65·5	48	46
Temp. of comp. air admitted to exp. cy., Fahr.	—	—	35	—
Temp. of air after expansion, Fahr.	-85	-52	-81	-98
Init. temp. of cooling water, Fahr.	—	—	62	41
I. H.P. in comp. cy.	346·4	124·5	14·5	3·28
I. H.P. in exp. cy.	176·2	58·5	7·8	1·68
Per cent. of I. H.P. of comp. retained in expander	51	47	54	51

EFFECTIVE COOLING POWER OBTAINABLE FROM THE EXPENDITURE OF ONE POUND OF STEAM IN THEORETICALLY PERFECT MACHINES.—(*Tuxen & Hammerich's Cat.*)

Ammonia by the absorption system.	Thermal Units	294	equal to 24 lbs. of ice per lb. of coal consumed.
Carbonic Anhydride	... 652		equal to 26 lbs. of ice per lb. of coal consumed.
Ammonia by the compression system		978	equal to 40 lbs. of ice per lb. of coal consumed.

* "Proceedings, Manchester Society of Engineers," 1894.

† Prof. Schroeter, "Untersuchungen an Kaeltemaschinen Verschiedener Systeme," 1881.

‡ A. J. Wallis-Taylor, A.M.I.C.E., 1902.

TESTS OF AMMONIA AND CARBONIC ACID MACHINES.

(Schroeter, Experimental Refrigerating Station, Munich, Germany.)

NO. OF TEST—	AMMONIA MACHINE.				CARBONIC ACID MACHINE.*			
	1	2	3	4	5	6	7	8
Temperature in brine tank, degrees Celsius	-6.1	-6.4	-6.4	-4.8	-4.0	-4.8	-4.8	-6.7
Temperature in condenser, degrees Celsius	21.4	21.4	21.4	34.9	20.9	21.2	22.2	30
Temperature before expansion valve, degrees Celsius	-6.7	11.6	18.4	28.3	-7.9	10.0	16.8	28.8
Refrigeration per hour, per horse power of steam-engine in calories ...	3897	3636	3508	2237	3832	3178	2867	1477




FIG. 15.—Diagram showing Loss of Efficiency with Brine Circulation compared with Direct Expansion of NH_3 .—(Murray, *Inst. Engrs. and Shipbuilders, Scotland, 1897.*)




FIG. 16.—Diagram showing Relative Compressor Capacity with NH_3 at various Expansion Pressures and Temperatures. —(Murray, *Inst. Engrs. and Shipbuilders, Scotland, 1897*)

* Dr. Mollier has since proved these results to be incorrect. See "Zeitschrift für Die Gesamnte Kalte Industrie."

THE PRODUCTION OF VERY LOW TEMPERATURES.

The idea of self-intensive refrigeration, or the regenerative process, seems to have occurred to Siemens, Coleman, Solway, and others many years ago, the first-named having applied for a patent in Germany for such a process as long ago as 1857; and in 1885 the latter patented a similar device and made an apparatus by means of which, however, he was only able to obtain a temperature as low as -140° Fahr., and was not successful in liquefying air. The first perfect self-intensive refrigerating methods are due to Professor Linde and Dr. William Hampson.

The methods primarily employed for the production of intense cold were arranged to operate upon what is known as the cascade system; that is to say, carbonic acid, methyl chloride, nitrous oxide, or any other gas capable of being easily liquefied, is first compressed by a pump, then cooled by water, and finally allowed to pass through a contracted orifice or expansion valve, at lower pressure and reduced to a temperature of, say for instance -110° Fahr., and back again to the compression pump,—in fact, a precisely similar cycle to that of the ammonia compression machine. The low temperature liquid and vapour thus produced then performs a second cycle, taking the place which water takes in the first, and is used to effect the cooling and condensation of a gas of a more volatile nature, such as ethylene, which latter, on passing the orifice or expansion valve, liquefies and vaporises at a still lower temperature, of, say, about -155° Fahr., the exact degree varying according to the pressure maintained on the suction side of the compressor pump. By the ethylene, compressed air or oxygen is cooled in a like manner, and the pressure of the liquid air or oxygen being reduced by passing through an expansion valve, becomes partly vaporised by its own heat, that portion remaining a liquid under atmospheric pressure being reduced to the boiling point of air.

In the self-intensive, or regenerative, method of producing very low temperatures, only one circuit of gas is required, viz. that of the air to be liquefied. This air, starting at an ordinary temperature, with the assistance of only water as a refrigerant, lowers by degrees its own temperature of expansion, by returning over the coils of compressed gas

in the above-mentioned manner, until it reaches the boiling point of air, the liquid then commencing to collect at the pressure of the atmosphere.

The improved apparatus of Dr. Hampson is founded on the well-known fact that any gas, when expanding through a small aperture, will perform such work upon itself as to effect a reduction of temperature, and this effect with air, although not large, is still appreciable. The whole of the gas expanded is used to lower, to a small extent, the temperature of the gas passing to the expansion aperture. This results in the gas expanded being somewhat lower in temperature than that previously expanded, and consequently the succeeding gas is cooled to a further reduced temperature, proceeding thus until the gas attains such a temperature that it commences to liquefy, or until such time as the removal of the heat within the apparatus becomes counter-balanced by the access of heat from the exterior thereof.

The apparatus employed is mainly composed of a series of long, well-insulated, fine copper coils, through which the gas passes to the expansion valve, the arrangement being such that the expanded gas has to flow over the entire external surface of the coils before being removed, so as to abstract as much heat as practicable from the entering gas.




FIG. 17.—Diagram showing Hampson's Apparatus for the Production of very Low Temperatures.




FIG. 18.—Diagram showing Linde's Apparatus for the Production of very Low Temperatures.

CAPACITY OF REFRIGERATING MACHINES.

Refrigerating machines are rated in two ways, viz. ice-making capacity, or tons of ice they will produce in one

day of twenty-four hours ; and refrigerating capacity, or cooling work done by one ton of ice melting per day of twenty-four hours. Roughly, the first or ice-making capacity of a machine may be taken to be about one-half of the refrigerating capacity. This, however, is only an approximation, as the tons of ice a refrigerating machine is capable of making depends upon the initial temperature of the water to be frozen. The unit of capacity is one ton of ice made from water at 32° Fahr. into ice at 32° Fahr. per day, which, according to practice here, is equal to 318,080 lbs. of water cooled one degree, or to 318,080 heat units or thermal units ; and, according to American practice, is equal to 284,000 lbs. of water cooled one degree, or 284,000 heat units or thermal units ; and this is the tonnage basis for refrigerating capacity as well as for ice-making capacity when ice is made from water at 32° Fahr. The difference between English and American practice is due to 2240 lbs. being taken to the ton in the former, and 2000 lbs. in the latter case.

The real ice-making capacity of a machine is dependent upon the temperature of the water to be frozen, and is calculated as follows : 1 lb. of ice in melting into water at 32° Fahr. will take up 142 positive units of heat, it follows, therefore, that water at 32° Fahr. will require 142 negative units of heat to make it into ice. Say that if the water to be frozen, for instance, be at a temperature of 72° Fahr., it must first be cooled down to 32° Fahr. before freezing commences ; therefore $72^{\circ} - 32^{\circ} = 40^{\circ} + 142 = 182$ heat units per pound of water frozen. Ice made artificially is usually much below 32° Fahr., as the temperature of the bath in which it is made ranges about 20° below freezing point, and consequently this work has also to be added. Taking into account the specific heat of ice, this additional negative heat approximately equals 10 units, which added to 182 = 192 ; therefore $\frac{142 \times 100}{192} = 73.963$,

or nearly 74 per cent. tons of ice made per ton refrigerating capacity. For greater accuracy, allowances must also be made for losses by ice tank and can exposure, wastage, thawing out of moulds, etc., etc.

TABLE OF COMPRESSOR CAPACITY IN CUBIC INCHES.

(Norman Selfe, "Machinery for Refrigeration.")

The tabular number multiplied by strokes per minute and divided by 1,728 gives cubic feet per minute theoretical capacity of the cylinder.

Cylinder Diameter in inches.	LENGTH OF STROKE IN INCHES.										Cylinder Diameter in inches.
	1	2	3	4	5	6	7	8	9	10	
C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	
1	0.785	1.571	2.356	3.141	3.927	4.712	5.498	6.283	7.068	7.854	1
1½	1.767	3.534	5.301	7.068	8.835	10.602	12.370	14.137	15.905	17.672	1½
2	3.141	6.283	9.425	12.566	15.705	18.849	21.991	25.132	28.274	31.416	2
2½	4.908	9.817	14.726	19.634	24.543	29.452	34.36	39.269	44.178	49.087	2½
3	7.068	14.137	21.206	28.274	35.343	42.411	49.480	56.549	63.617	70.686	3
4	12.566	25.132	37.698	50.265	62.830	75.396	87.962	100.53	113.09	125.66	4
5	19.635	39.270	58.905	78.540	98.175	117.81	137.44	157.08	176.71	196.35	5
6	28.274	56.548	84.822	113.09	141.37	169.64	197.92	226.19	254.46	282.74	6
7	38.484	76.968	115.45	153.93	192.42	230.90	269.39	307.87	346.35	384.84	7
8	50.265	100.53	150.79	201.06	251.32	301.59	351.85	402.12	452.38	502.65	8
9	63.617	127.23	190.85	254.47	318.08	381.70	445.32	508.93	572.55	636.17	9
10	78.540	157.08	235.62	314.16	392.70	471.24	549.78	628.32	706.86	785.40	10

TABLE OF COMPRESSOR CAPACITY IN CUBIC INCHES.—(Continued.)

Cylinder Diameter in inches.	LENGTH OF STROKE IN INCHES.										Cylinder Diameter in inches.
	1	2	3	4	5	6	7	8	9	10	
C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.
11	95.033	190.06	285.09	380.13	475.16	570.19	665.23	760.26	855.29	950.33	11
12	113.09	226.18	339.27	452.30	565.45	678.54	791.63	904.72	1007.8	1120.9	12
13	132.73	265.46	398.19	530.92	663.65	796.38	929.11	1061.8	1194.5	1327.2	13
14	153.93	307.86	461.79	615.72	769.65	923.58	1077.5	1231.4	1385.3	1539.3	14
15	176.71	353.42	530.13	706.84	883.55	1060.2	1236.9	1413.6	1590.3	1767.1	15
16	201.01	402.12	603.18	804.24	1005.3	1206.3	1407.4	1608.4	1809.5	2010.6	16
17	226.98	453.96	680.94	913.49	1134.9	1361.8	1588.8	1815.8	2042.8	2269.8	17
18	254.46	508.92	763.38	1017.8	1272.3	1526.7	1781.2	2035.6	2290.1	2544.6	18
19	283.52	567.04	850.56	1134.0	1417.6	1701.1	1984.6	2268.1	2551.6	2835.2	19
20	314.16	628.32	942.48	1256.6	1570.8	1884.9	2199.1	2513.2	2827.4	3141.6	20
22	330.13	760.26	1140.4	1520.5	1900.6	2280.8	2660.9	3041.0	3421.1	3801.3	22
24	452.39	904.78	1357.1	1809.5	2261.9	2714.3	3166.7	3619.1	4071.5	4523.9	24
26	530.93	1061.8	1592.7	2123.7	2654.6	3185.5	3716.5	4247.4	4778.3	5309.3	26
28	615.75	1231.5	1847.2	2463.0	3078.7	3694.5	4310.2	4926.0	5541.7	6157.5	28
30	706.86	1413.7	2120.5	2827.4	3534.3	4241.1	4948.0	5654.8	6361.7	7068.6	30
32	804.24	1608.4	2412.7	3216.9	4021.2	4825.4	5629.6	6433.9	7238.1	8042.4	32
34	907.92	1815.8	2723.7	3631.6	4539.6	5447.5	6355.4	7263.3	8171.2	9079.2	34
36	1017.8	2034.1	3051.2	4068.3	5085.4	6102.4	7119.5	8136.6	9153.7	10170	36

TABLE OF COMPRESSOR CAPACITY IN CUBIC INCHES.—(Continued.)

Cylinder Diameter in inches.	LENGTH OF STROKE IN INCHES.										Cylinder Diameter in inches.
	11	12	13	14	15	16	18	20	22	24	
	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	
1	8·639	9·425	10·110	10·995	11·781	12·566	14·137	15·708	17·279	18·846	1
1½	9·439	21·206	22·973	24·740	26·507	28·274	31·809	35·343	38·877	42·411	1½
2	34·557	37·699	40·841	43·982	47·124	50·265	56·549	62·832	69·113	73·399	2
2½	53·995	58·904	63·813	68·721	73·630	78·539	88·356	98·174	107·90	117·81	2½
3	77·754	84·823	91·892	98·960	106·03	113·09	127·23	141·37	155·51	169·61	3
4	138·22	150·79	163·36	175·92	188·49	201·05	226·19	251·32	276·55	301·58	4
5	215·98	235·62	255·25	274·89	294·52	314·16	353·43	392·70	431·97	471·24	5
6	311·01	339·29	367·56	395·83	424·11	452·38	508·93	565·48	622·03	678·57	6
7	423·32	461·81	500·29	538·77	577·26	615·74	692·71	769·68	846·65	923·61	7
8	552·91	603·18	653·44	703·71	753·97	804·24	904·77	1005·3	1105·8	1206·3	8
9	699·78	763·40	827·02	890·63	954·25	1017·8	1145·1	1272·3	1399·5	1526·8	9
10	863·94	942·48	1021·0	1099·5	1178·1	1256·6	1413·7	1570·8	1727·8	1884·9	10
11	1045·3	1140·3	1235·4	1330·4	1425·4	1520·5	1710·5	1900·6	2090·7	2280·7	11
12	1233·9	1357·1	1470·2	1583·3	1696·4	1789·5	2035·7	2261·9	2488·1	2714·3	12
13	1459·9	1592·7	1725·5	1858·2	1980·9	2123·7	2389·1	2654·6	2920·1	3185·5	13

TABLE OF COMPRESSOR CAPACITY IN CUBIC INCHES.—(Continued.)

Cylinder Diameter in inches.		LENGTH OF STROKE IN INCHES.										Cylinder Diameter in inches.	
		11	12	13	14	15	16	18	20	22	24		
	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.	C. Ins.		
14	1693.2	1847.2	2001.1	2155.1	2309.0	2463.0	2770.8	3078.7	3386.6	3694.5	4002.4	14	3694.5
15	1943.8	2120.5	2297.2	2474.0	2650.7	2827.4	3180.8	3534.3	3887.7	4241.1	4594.5	15	4241.1
16	2211.6	2412.7	2613.8	2814.8	3015.9	3216.9	3619.1	4021.2	4423.3	4825.4	5227.5	16	4825.4
17	2466.8	2723.7	2980.6	3177.7	3404.7	3631.6	4085.6	4539.6	4993.5	5447.5	5901.5	17	5447.5
18	2799.0	3053.6	3308.0	3562.5	3817.0	4071.5	4580.4	5089.3	5598.3	6107.2	6616.1	18	6107.2
19	3118.7	3402.3	3685.8	3969.4	4252.9	4536.4	5103.5	5670.5	6237.6	6804.7	7371.8	19	6804.7
20	3455.7	3769.9	4084.0	4398.2	4712.4	5026.5	5654.8	6283.2	6911.5	7539.8	8168.1	20	7539.8
22	4181.4	4561.5	4941.7	5321.8	5701.9	6082.1	6842.3	7602.6	8362.9	9123.1	9883.4	22	9123.1
24	4976.2	5428.6	5881.0	6333.4	6785.8	7238.2	8143.0	9047.8	9952.5	10857.0	11761.5	24	10857.0
26	5840.2	6371.1	6902.0	7433.0	7963.9	8494.8	9556.7	10618.0	11680.0	12742.0	13803.5	26	12742.0
28	6773.2	7389.0	8004.7	8620.5	9236.3	9852.0	11083.0	12315.0	13546.0	14778.0	16010.0	28	14778.0
30	7775.4	8482.3	9189.1	9896.0	10602.0	11309.0	12723.0	14137.0	15550.0	16964.0	18378.0	30	16964.0
32	8846.6	9650.9	10455.0	11259.0	12063.0	12868.0	14576.0	16085.0	17693.0	19301.0	20909.0	32	19301.0
34	9987.1	10895.0	11802.0	12710.0	13618.0	14526.0	16342.0	18158.0	19974.0	21790.0	23606.0	34	21790.0
36	11187.0	12214.0	13232.0	14240.0	15258.0	16275.0	18311.0	20347.0	22383.0	24418.0	26454.0	36	24418.0

MEAN PRESSURE OF COMPRESSOR.

The following table from the *De La Vergne* catalogue admits of the mean pressure in the compressor, and indirectly the work of the compressor being approximately ascertained from the refrigerator and condenser pressure and temperature:—

Condenser Pressure.	103	115	127	139	153	168	184	200	218
Condenser Temperature.	65°	70°	75°	80°	85°	90°	95°	100°	105°
Refrigerator Pressure.	Refrigerator Temperature.								
4	41.46	43.91	46.34	48.77	51.23	53.68	56.11	58.54	60.99
6	42.72	45.38	47.90	50.74	53.40	56.08	58.86	61.40	64.08
9	44.40	47.38	50.33	53.29	56.25	59.20	62.16	65.14	68.09
13	45.86	49.15	52.42	55.70	58.97	62.25	65.53	68.81	72.08
16	46.94	50.50	54.16	57.78	62.40	65.00	68.62	72.22	75.84
20	47.74	51.73	55.70	59.68	63.67	67.66	71.62	75.61	79.61
24	48.04	52.40	56.77	61.13	65.51	69.86	74.24	78.59	82.97
28	47.88	52.67	57.44	62.23	67.02	71.81	76.60	81.39	86.18
33	47.08	52.30	57.53	62.75	67.98	73.23	78.46	83.68	88.91
39	45.06	51.34	57.05	62.75	68.46	74.17	79.88	85.58	91.29
45	43.16	49.71	55.92	62.14	68.35	74.56	80.77	86.98	93.19
51	40.52	47.26	54.02	60.76	67.52	74.28	81.02	87.78	94.52

TABLE GIVING NUMBER OF CUBIC FEET OF GAS THAT MUST BE PUMPED PER MINUTE AT DIFFERENT CONDENSER AND SUCTION PRESSURES TO PRODUCE ONE TON OF REFRIGERATION IN 24 HOURS.
(Professor Siebel, "Compend of Mechanical Refrigeration.")

Temperature of Gas in Degrees Fahr.	Corresponding Suction Pressure, lbs. per sq. in.	Temperature of the Gas in Degrees Fahr.									
		65	70	75	80	85	90	95	100	105	
		Corresponding Condenser Pressure (Gauge) lbs. per square inch.									
		103	115	127	139	153	168	184	200	218	
G. Pres.											
-27	1	7.22	7.3	7.37	7.46	7.54	7.62	7.70	7.79	7.88	
-20	4	5.84	5.9	5.96	6.03	6.09	6.16	6.23	6.30	6.43	
-15	6	5.35	5.4	5.46	5.52	5.58	5.64	5.70	5.77	5.83	
-10	9	4.66	4.73	4.76	4.81	4.86	4.91	4.97	5.05	5.08	
-5	13	4.09	4.12	4.17	4.21	4.25	4.30	4.35	4.40	4.44	
0	16	3.59	3.63	3.66	3.70	3.74	3.78	3.83	3.87	3.91	
5	20	3.20	3.24	3.27	3.30	3.34	3.38	3.41	3.45	3.49	
10	24	2.87	2.9	2.93	2.96	2.99	3.02	3.06	3.09	3.12	
15	28	2.59	2.61	2.65	2.68	2.71	2.73	2.76	2.80	2.82	
20	33	2.31	2.34	2.36	2.38	2.41	2.44	2.46	2.49	2.51	
25	39	2.06	2.08	2.10	2.12	2.15	2.17	2.20	2.22	2.24	
30	45	1.85	1.87	1.89	1.91	1.93	1.95	1.97	2.00	2.01	
35	51	1.70	1.72	1.74	1.76	1.77	1.79	1.81	1.83	1.85	

APPROXIMATE ALLOWANCES PER TON CAPACITY TO BE MADE WHEN SELECTING A MACHINE FOR REFRIGERATING PURPOSES.—(*Triumph Ice Machine Company*.)

Beer wort: 15 barrels per ton on Baudelot cooler. One thousand gallons of sweet water per ton from 70° to 40°. Six beeves, 600 to 700 lbs. each, per ton. Ten to twenty hogs. per ton. One thousand cubic feet of space per ton for small machines up to 2 tons. Four thousand cubic feet of space per ton for machine from 10 to 15 tons. Ten thousand cubic feet of space per ton for larger machines used for general purposes.

The above will serve as a guide, but it must be borne in mind that the climate, construction, and exposure of buildings that are to be refrigerated, character of the insulation, management and method of handling work, all have to be taken into consideration. (See also Section on Cold Storage.)

CONDENSERS.

On the efficiency of the condenser largely depends the economical working of the machine. Condensers are of two kinds or classes, viz. the submerged and the open air, or atmospheric, the latter being the more economical in the matter of cooling water, but occupying the larger amount of space.

According to Professor Siebel, under average conditions (incoming condenser water 70°, and outgoing condenser water 80°, more or less), for each ton of refrigerating capacity (or for one half-ton of ice-making capacity) 40 square feet of condenser surface, corresponding to 64 running feet of 2-inch pipe, and to 90 running feet of 1½-inch pipe, will be required in a submerged condenser. The amount of cooling water used varies from 3 to 7 gallons per minute per ton ice-making capacity in twenty-four hours. The pipe required in an open air condenser is 40 square feet per ton of refrigerating capacity (or for one half-ton of ice-making capacity), equivalent to 64 running feet of 2-inch pipe, or 90 running feet of 1½-inch pipe. The amount of cooling water used is about 50 per cent. less than with condensers of the submerged type.

Double pipe condensers are made which are claimed to possess the best qualities of both submerged and open air condensers. This condenser consists of a coil made up with one pipe inside another of larger diameter, the cooling water circulating through the internal pipe, and the compressed gas in the annular space or clearance between the two pipes. The gas is thus exposed to the action of both cooling water and the atmosphere.

EVAPORATION OF LIQUIDS.—(*Lightfoot.*)

Liquid or gas.		Water.	Anhydrous Ammonia.	Sulphuric ether.	Mythylic ether.	Sulphur dioxide.	Pictet's liquid.
Specific gravity of vapour, compared with air = 1·000		0·622	0·59	2·24	1·61	2·24	—
Boiling point at atmospheric pressure		Fahr.	Fahr.	Fahr.	Fahr.	Fahr.	Fahr.
		212°	-37·3°	96°	-10·5	14°	-2·2°
Latent heat of vaporisation at atmospheric pressure		966	900	165	473	182	—
Absolute vapour tensions in lbs. per square inch at different temperatures.	Fahr.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.
	- 40°	—	—	—	—	—	—
	- 20°	—	19·4	—	12·0	5·7	11·6
	0°	—	30·0	1·5	18·7	9·8	15·4
	+ 20°	—	47·7	2·6	28·1	16·9	22·0
	+ 32°	0·089	61·5	3·6	36·0	22·7	27·0
	+ 40°	0·122	73·0	4·5	42·5	27·3	31·3
	+ 60°	0·254	108·0	7·2	61·0	41·4	44·0
	+ 80°	0·503	152·4	10·9	86·1	60·2	60·0
	100°	0·942	210·6	16·2	118·0	84·5	79·1
	120°	1·685	283·7	23·5	—	117·5	99·7
	140°	2·879	—	33·5	—	—	—
	160°	4·731	—	45·6	—	—	—
	180°	7·511	—	62·0	—	—	—
	200°	11·526	—	81·8	—	—	—
	212°	14·7	—	96·0	—	—	—

TABLE SHOWING PRESSURE AND BOILING POINT OF SOME OF THE LIQUIDS AVAILABLE FOR USE IN REFRIGERATING MACHINES.—(*Ledoux.*)

Temperature of Ebullition.	Tension of Vapour, in pounds per square inch, above Zero.					
Deg. Fabr.	Sulphuric Ether.	Sulphur Dioxide.	Ammonia.	Methylic Ether.	Carbonic Acid.	Pictet Fluid.
(1)	(2)	(3)	(4)	(5)	(6)	(7)
-40	—	—	10·22	—	—	—
-31	—	—	13·23	—	—	—
-22	—	5·56	16·95	11·15	—	—
-13	—	7·23	21·51	13·85	251·6	—
- 4	1·30	9·27	27·04	17·06	292·9	13·5
5	1·70	11·76	33·67	20·84	340·1	16·2
14	2·19	14·75	41·58	25·27	393·4	19·3
23	2·79	18·31	50·91	30·41	453·4	22·9
32	3·55	22·53	61·85	36·34	520·4	26·9
41	4·45	27·48	74·55	43·13	594·8	31·2
50	5·54	33·26	89·21	50·84	676·9	36·2
59	6·84	39·93	105·99	59·56	766·9	41·7
68	8·38	47·62	125·08	69·35	864·9	48·1
77	10·19	56·39	146·64	80·28	971·1	55·6
86	12·31	66·37	170·83	92·41	1085·6	64·1
95	14·76	77·64	197·83	—	1207·9	73·2
104	17·59	90·32	227·76	—	1338·2	82·9

TABLE OF SPECIFIC GRAVITIES AND PERCENTAGE OF AMMONIA.—(*Carius.*)

Degrees Beaumé.	Specific Gravity.	Percentage.	Degrees Beaumé.	Specific Gravity.	Percentage.
10	1·000	0	21	0·9271	19·4
11	0·9929	1·8	22	0·921	21·4
12	0·9859	3·3	23	0·915	23·4
13	0·979	5·0	24	0·909	25·3
14	0·9722	6·7	25	0·9032	27·7
15	0·9655	8·4	26*	0·8974	30·1
16	0·9589	10·0	27	0·8917	32·5
17	0·9523	11·9	28	0·886	35·2
18	0·9459	13·7	29	0·8805	..
19	0·9395	15·5	30	0·875	..
20	0·9333	17·4	..	..	..

* Known by the trade as 29½ per cent.

NOTE.—The specific gravity of pure anhydrous ammonia is ·623.

SOLUBILITY OF AMMONIA IN WATER AT DIFFERENT
TEMPERATURES.—(*Sims.*)

Degrees Fahr.	Sb. of NH ₃ to 1 lb. of Water.	Volume of NH ₃ in 1 Volume of Water.	Degrees Fahr.	Sb. of NH ₃ to 1 lb. of Water.	Volume of NH ₃ in 1 Volume of Water.
32.0	0.899	1,180	125.6	0.274	359
35.6	0.853	1,120	129.2	0.265	348
39.2	0.809	1,062	132.8	0.256	336
42.8	0.765	1,005	136.4	0.247	324
46.4	0.724	951	140.0	0.238	312
50.0	0.684	898	143.6	0.229	301
53.6	0.646	848	147.2	0.220	389
57.2	0.611	802	150.8	0.211	277
60.8	0.578	759	154.4	0.202	265
64.4	0.546	717	158.0	0.194	254
68.0	0.518	683	161.6	0.186	244
71.6	0.490	643	165.2	0.178	234
75.2	0.467	613	168.8	0.170	223
78.8	0.446	585	172.4	0.162	212
82.4	0.426	559	176.0	0.154	202
86.0	0.408	536	179.6	0.146	192
89.2	0.393	516	183.2	0.138	181
93.2	0.378	496	186.8	0.130	170
96.8	0.363	478	190.4	0.122	160
100.4	0.350	459	194.0	0.114	149
104.0	0.338	444	197.6	0.106	139
107.6	0.326	428	201.2	0.098	128
111.2	0.315	414	204.8	0.090	118
114.8	0.303	399	208.4	0.082	107
118.4	0.294	386	212.0	0.074	97
122.0	0.284	373	..	..	..

THE FORECOOLER.

This is a supplementary condenser through which the compressed ammonia passes before reaching the main condenser, and cooled by the overflow water from the latter. If composed of one coil, it should be the same size as discharge pipe from compressor; if of a number of coils, the manifold pipe, and the aggregate area openings of small pipes, should be equal to that of the discharge pipe.

SOLUBILITY OF AMMONIA IN WATER AT DIFFERENT TEMPERATURES AND PRESSURES.—(*Sims.*)

1 lb. of water (also unit volume) absorbs the following quantities of ammonia :—

Absolute Pressure in lbs. per sq. in.	32° F.		68° F.		104° F.		212° F.	
	lbs.	vols.	lbs.	vols.	lbs.	vols.	grms.	vols.
14·67	0·899	1·180	0·518	0·683	0·338	0·443	0·074	0·97
15·44	0·937	1·231	0·535	0·703	0·349	0·458	0·078	0·102
16·41	0·980	1·287	0·556	0·730	0·363	0·476	0·083	0·109
17·37	1·029	1·351	0·574	0·754	0·378	0·496	0·088	0·115
18·34	1·077	1·414	0·594	0·781	0·391	0·513	0·092	0·120
19·30	1·126	1·478	0·613	0·805	0·404	0·531	0·096	0·126
20·27	1·177	1·546	0·632	0·830	0·414	0·543	0·101	0·132
21·23	1·236	1·615	0·651	0·855	0·425	0·558	0·106	0·139
22·19	1·283	1·685	0·669	0·878	0·434	0·570	0·110	0·140
23·16	1·336	1·754	0·685	0·894	0·445	0·584	0·115	0·151
24·13	1·388	1·823	0·704	0·924	0·454	0·596	0·120	0·157
25·09	1·442	1·894	0·722	0·948	0·463	0·609	0·125	0·164
26·06	1·496	1·965	0·741	0·973	0·472	0·619	0·130	0·170
27·02	1·549	2·034	0·761	0·999	0·479	0·629	0·135	0·177
27·99	1·603	2·105	0·780	1·023	0·486	0·638	..	..
28·95	1·656	2·175	0·801	1·052	0·493	0·647	..	..
30·88	1·758	2·309	0·842	1·106	0·511	0·671	..	..
32·81	1·861	2·444	0·881	1·157	0·530	0·696	..	..
34·74	1·966	2·582	0·919	1·207	0·547	0·718	..	..
36·67	2·070	2·718	0·955	1·254	0·565	0·742	..	..
38·60	..	..	0·992	1·302	0·579	0·764	..	..
40·53	..	..	..	..	0·594	0·780	..	..

SOLUBILITY OF AMMONIA IN WATER AT DIFFERENT TEMPERATURES.—(*Roscoe.*)

Degrees Celsius.	Degrees Fahrenheit.	lbs. of NH ₃ to 1 lb. of Water.	Degrees Celsius.	Degrees Fahrenheit.	lbs. of NH ₃ to 1 lb. of Water.
0	32·0	0·875	8	46·4	0·713
2	35·6	0·833	10	50·0	0·679
4	39·2	0·792	12	53·6	0·645
6	42·8	0·751	14	57·2	0·612

SOLUBILITY OF AMMONIA IN WATER AT DIFFERENT TEMPERATURES.—(*Roscoe.*) (*Continued.*)

Degrees Celsius.	Degrees Fahrenheit.	lbs. of NH_3 to 1 lb. of Water.	Degrees Celsius.	Degrees Fahrenheit.	lbs. of NH_3 to 1 lb. of Water.
16	60·8	0·582	36	96·8	0·343
18	64·4	0·554	38	100·4	0·324
20	68·0	0·526	40	104·0	0·307
22	71·6	0·499	42	107·6	0·290
24	75·2	0·474	44	111·2	0·275
26	78·8	0·449	46	114·8	0·259
28	82·4	0·426	48	118·4	0·244
30	86·0	0·403	50	122·0	0·229
32	89·6	0·382	52	125·6	0·214
34	93·2	0·362	54	129·2	0·200
			56	132·8	0·186

STRENGTH OF LIQUOR AMMONIA.

Percentage of Ammonia by Weight.	Specific Gravity.	Degrees Beaumé, Water, 10.
0	1·000	10·0
2	0·986	12·0
4	0·979	13·0
6	0·972	14·0
8	0·966	15·0
10	0·960	16·0
12	0·953	17·1
14	0·945	18·3
16	0·938	19·5
18	0·931	20·7
20	0·925	21·7
22	0·919	22·8
24	0·913	23·9
26	0·907	24·8
28	0·902	25·7
30	0·897	26·6
32	0·892	27·5
34	0·888	28·4
36	0·884	29·3
38	0·880	30·2

YIELD, ETC., OF ANHYDROUS AMMONIA FROM AMMONIA SOLUTIONS. — (*Redwood.*)

SOLUTION.			ANHYDROUS AMMONIA.			
Weight of Ice.		Boiling Point.	Volume of Gas (at 32° Fahr., and Atmospheric pressure) in one volume of the Solution.	lbs. in one gallon of the Solution.	Per cent. by Volume.	Per cent. by Weight.
Degrees Beaumé.	lbs. per Gallon.					
34.7	7.09	26°	494	3.077	59.5	43.4
32.8	7.17	38°	456	2.841	54.9	39.6
31.0	7.25	50°	419	2.610	50.7	36.0
29.0	7.34	62°	382	2.379	46.0	32.5
27.2	7.42	74°	346	2.156	41.7	29.1
26.0	7.48	83°	320	1.993	38.5	26.6
25.6	7.50	86°	311	1.937	37.5	25.8
23.7	7.59	98°	277	1.726	33.4	22.8
22.2	7.67	110°	244	1.520	29.4	19.7

TEMPERATURES TO WHICH AMMONIA GAS IS RAISED BY COMPRESSION.

Temperature of Suction.	Absolute Condensing Pressure.	ABSOLUTE SUCTION PRESSURE.					
		20	25	30	35	40	45
0° Fahr.	90	199	165	138	116	98	83
	100	216	181	153	131	113	97
	110	232	196	166	145	126	109
	120	245	211	181	158	138	121
	130	261	222	193	169	150	132
	140	273	235	205	181	161	143
	150	285	246	216	191	171	153
	160	296	257	226	202	181	163

TEMPERATURES TO WHICH AMMONIA GAS IS RAISED BY
COMPRESSION.—(Continued.)

Temperature of Suction.	Absolute Con- densing Pressure	ABSOLUTE SUCTION PRESSURE.					
		20	25	30	35	40	45
5° Fahr.	90	266	172	145	123	104	89
	100	223	186	160	138	119	103
	110	239	203	174	151	132	115
	120	254	218	188	163	145	127
	130	268	230	200	176	156	139
	140	281	242	212	188	167	150
	150	293	254	223	198	178	160
	160	305	265	234	209	188	170
10° Fahr.	90	213	178	151	129	110	96
	100	231	195	167	144	125	109
	110	247	210	181	158	139	122
	120	261	226	195	171	151	134
	130	275	237	207	183	163	145
	140	289	250	219	195	174	156
	150	301	262	231	205	185	167
	160	313	273	241	216	195	176
15° Fahr.	90	221	185	158	135	117	101
	100	238	202	173	151	131	115
	110	254	217	188	164	145	128
	120	269	233	202	178	158	140
	130	283	245	214	191	170	152
	140	297	257	226	202	181	163
	150	309	269	238	213	192	173
	160	321	281	249	223	202	183
20° Fahr.	90	228	192	164	141	123	106
	100	245	209	180	157	137	121
	110	262	224	195	171	150	134
	120	277	240	209	185	164	146
	130	291	252	222	197	176	158
	140	305	265	234	209	188	169
	150	317	277	245	220	198	180
	160	329	288	256	230	209	190
25° Fahr.	90	235	199	171	148	129	111
	100	252	216	187	163	144	127
	110	269	230	200	178	155	140
	120	284	247	216	191	171	153
	130	299	259	229	204	183	165
	140	313	271	241	216	194	176
	150	325	284	253	227	205	187
	160	338	296	264	237	216	197

TEMPERATURES TO WHICH AMMONIA GAS IS RAISED BY
COMPRESSION.—(Continued.)

Temperature of Suction.	Absolute Con- densing Pressure.	ABSOLUTE SUCTION PRESSURE.					
		20	25	30	35	40	45
30° Fahr.	90	242	206	177	154	134	118
	100	260	223	193	170	150	133
	110	277	239	208	184	164	147
	120	292	255	223	198	177	159
	130	307	267	236	211	190	171
	140	321	280	248	223	201	183
	150	334	292	260	234	212	193
	160	346	304	271	245	223	203
- 32° Fahr.	90	245	209	179	157	137	121
	100	263	225	196	173	153	135
	110	280	241	211	187	167	149
	120	295	256	226	201	180	162
	130	310	270	239	213	192	174
	140	324	283	251	226	204	185
	150	337	295	263	237	215	196
	160	350	307	274	248	226	206
35° Fahr.	90	249	213	182	160	141	124
	100	268	229	200	176	156	139
	110	286	246	215	191	170	153
	120	300	260	230	205	184	166
	130	315	274	243	217	196	178
	140	329	288	255	230	208	189
	150	341	300	268	241	219	200
	160	354	312	279	252	230	210

THE ANALYSER.

The analyser is placed in upper part of still or generator of absorption machine, and serves as a dehydrator, also increasing temperature of rich liquor from 150° to 170°, at which it arrives, to about 200°.

The device consists essentially of superimposed shelves down which the rich ammonia liquor is delivered and over which it trickles, whilst the heated vapour from generator passes over them in an upward direction. In this manner

THESE ARE THE RESULTS OF THE
ANALYSIS OF THE WATER SAMPLES
TAKEN AT THE DIFFERENT STATIONS
ON THE 10TH OF MAY 1900

ALL WITH A LARGE
PERCENTAGE BOTH
OF THE PERCENTAGE
OF THE PERCENTAGE

ANALYSIS OF THE WATER SAMPLES

AS—1000 (1000)

STATION	DATE	TIME	TEMPERATURE	WIND	WAVE
1	10/5/00	10.00	10.00	10.00	10.00
2	10/5/00	10.00	10.00	10.00	10.00
3	10/5/00	10.00	10.00	10.00	10.00
4	10/5/00	10.00	10.00	10.00	10.00
5	10/5/00	10.00	10.00	10.00	10.00
6	10/5/00	10.00	10.00	10.00	10.00
7	10/5/00	10.00	10.00	10.00	10.00
8	10/5/00	10.00	10.00	10.00	10.00
9	10/5/00	10.00	10.00	10.00	10.00
10	10/5/00	10.00	10.00	10.00	10.00
11	10/5/00	10.00	10.00	10.00	10.00
12	10/5/00	10.00	10.00	10.00	10.00
13	10/5/00	10.00	10.00	10.00	10.00
14	10/5/00	10.00	10.00	10.00	10.00
15	10/5/00	10.00	10.00	10.00	10.00
16	10/5/00	10.00	10.00	10.00	10.00
17	10/5/00	10.00	10.00	10.00	10.00
18	10/5/00	10.00	10.00	10.00	10.00
19	10/5/00	10.00	10.00	10.00	10.00
20	10/5/00	10.00	10.00	10.00	10.00
21	10/5/00	10.00	10.00	10.00	10.00
22	10/5/00	10.00	10.00	10.00	10.00
23	10/5/00	10.00	10.00	10.00	10.00
24	10/5/00	10.00	10.00	10.00	10.00
25	10/5/00	10.00	10.00	10.00	10.00
26	10/5/00	10.00	10.00	10.00	10.00
27	10/5/00	10.00	10.00	10.00	10.00
28	10/5/00	10.00	10.00	10.00	10.00
29	10/5/00	10.00	10.00	10.00	10.00
30	10/5/00	10.00	10.00	10.00	10.00
31	10/5/00	10.00	10.00	10.00	10.00
32	10/5/00	10.00	10.00	10.00	10.00
33	10/5/00	10.00	10.00	10.00	10.00
34	10/5/00	10.00	10.00	10.00	10.00
35	10/5/00	10.00	10.00	10.00	10.00
36	10/5/00	10.00	10.00	10.00	10.00
37	10/5/00	10.00	10.00	10.00	10.00
38	10/5/00	10.00	10.00	10.00	10.00
39	10/5/00	10.00	10.00	10.00	10.00
40	10/5/00	10.00	10.00	10.00	10.00
41	10/5/00	10.00	10.00	10.00	10.00
42	10/5/00	10.00	10.00	10.00	10.00
43	10/5/00	10.00	10.00	10.00	10.00
44	10/5/00	10.00	10.00	10.00	10.00
45	10/5/00	10.00	10.00	10.00	10.00
46	10/5/00	10.00	10.00	10.00	10.00
47	10/5/00	10.00	10.00	10.00	10.00
48	10/5/00	10.00	10.00	10.00	10.00
49	10/5/00	10.00	10.00	10.00	10.00
50	10/5/00	10.00	10.00	10.00	10.00

VOLUME OF ONE POUND OF AMMONIA GAS AT VARIOUS PRESSURES AND TEMPERATURES.

lbs. per Square Inch Absolute Pressure.	TEMPERATURE IN DEGREES, FAHRENHEIT.							
	5	10	15	20	25	30	35	40
	Volume in Cubic Feet of One lb. of Ammonia Gas.							
15	19.823	20.036	20.263	20.490	20.703	20.930	21.156	21.370
15½	19.175	19.382	19.601	19.821	20.027	20.246	20.466	20.672
16	18.569	18.769	18.982	19.194	19.410	19.607	19.819	20.019
16½	17.999	18.193	18.399	18.605	18.799	19.005	19.211	19.405
17	17.463	17.651	17.865	18.051	18.239	18.439	18.639	18.828
17½	16.958	17.141	17.355	17.529	17.711	17.906	18.101	18.283
18	16.481	16.658	16.847	17.036	17.215	17.403	17.591	17.769
18½	16.029	16.202	16.386	16.570	16.743	16.926	17.110	17.283
19	15.602	15.770	15.949	16.128	16.296	16.475	16.654	16.824
19½	15.196	15.360	15.534	15.709	15.873	16.047	16.222	16.386
20	14.811	14.971	15.141	15.311	15.471	15.642	15.811	15.971
20½	14.444	14.600	14.771	14.932	15.088	15.254	15.420	15.576
21	14.096	14.249	14.410	14.572	14.725	14.887	15.049	15.201
21½	13.763	13.912	14.070	14.228	14.377	14.535	14.693	14.842
22	13.447	13.594	13.747	13.901	14.047	14.201	14.356	14.501
22½	13.143	13.285	13.436	13.588	13.730	13.881	14.032	14.174
23	12.851	12.993	13.141	13.288	13.428	13.576	13.723	13.863
23½	12.576	12.712	12.857	13.001	13.137	13.286	13.427	13.563
24	12.310	12.444	12.585	12.727	12.861	13.004	13.144	13.277
24½	12.055	12.186	12.325	12.464	12.594	12.733	12.872	13.002
25	11.811	11.939	12.075	12.211	12.339	12.473	12.611	12.739

VOLUME OF ONE POUND OF AMMONIA GAS AT VARIOUS PRESSURES AND TEMPERATURES.
 —(Continued.)



lbs. per Square Inch Absolute Pressure.	TEMPERATURE IN DEGREES, FAHRENHEIT.							
	5	10	15	20	25	30	35	40
Volume in Cubic Feet of One lb. of Ammonia Gas.								
25½	11.576	11.702	11.835	11.964	12.094	12.227	12.360	12.486
26	11.350	11.473	11.604	11.735	11.857	11.988	12.119	12.242
26½	11.133	11.254	11.382	11.510	11.631	11.755	11.888	12.008
27	10.923	11.042	11.167	11.294	11.412	11.538	11.664	11.783
27½	10.722	10.838	10.962	11.085	11.202	11.325	11.449	11.565
28	10.527	10.642	10.763	10.885	10.999	11.120	11.242	11.363
28½	10.340	10.452	10.572	10.691	10.803	10.922	11.042	11.154
29	10.159	10.369	10.386	10.504	10.611	10.731	10.848	10.959
29½	9.984	10.093	10.208	10.323	10.432	10.547	10.662	10.770
30	9.813	10.021	10.035	10.148	10.255	10.368	10.482	10.588
30½	9.651	9.756	9.868	9.979	10.084	10.196	10.307	10.412
31	9.493	9.597	9.706	9.816	9.919	10.029	10.139	10.242
31½	9.340	9.442	9.550	9.558	9.759	9.867	9.975	10.077
32	9.192	9.292	9.399	9.505	9.605	9.711	9.817	9.917
32½	9.048	9.147	9.251	9.356	9.454	9.559	9.664	9.762
33	8.909	9.006	9.109	9.212	9.309	9.412	9.515	9.612
33½	8.774	8.870	8.971	9.072	9.168	9.269	9.371	9.467
34	8.644	8.738	8.838	8.938	9.032	9.132	9.232	9.326
34½	8.516	8.608	8.707	8.806	8.899	8.997	9.095	9.188
35	8.391	8.483	8.580	8.677	8.769	8.866	8.962	9.055

VOLUME OF ONE POUND OF AMMONIA GAS AT VARIOUS PRESSURES AND TEMPERATURES.
—(Continued.)

TEMPERATURE IN DEGREES, FAHRENHEIT.								
5	10	15	20	25	30	35	40	
Volume in Cubic Feet of One lb. of Ammonia Gas.								
35½	8.271	8.361	8.457	8.553	8.643	8.739	8.834	8.925
36	8.155	8.244	8.338	8.433	8.521	8.616	8.711	8.799
36½	8.041	8.129	8.222	8.315	8.403	8.496	8.589	8.679
37	7.931	8.017	8.109	8.201	8.288	8.379	8.471	8.558
37½	7.823	7.908	7.999	8.089	8.172	8.265	8.356	8.441
38	7.719	7.803	7.892	7.982	8.066	8.155	8.245	8.329
38½	7.616	7.699	7.788	7.876	7.959	8.047	8.136	8.219
39	7.516	7.599	7.686	7.774	7.856	7.943	8.030	8.113
39½	7.421	7.501	7.587	7.673	7.754	7.840	7.926	8.007
40	7.326	7.406	7.491	7.576	7.656	7.741	7.826	7.906
40½	7.234	7.313	7.397	7.480	7.560	7.643	7.727	7.806
41	7.144	7.222	7.305	7.388	7.466	7.549	7.632	7.710
41½	7.056	7.134	7.215	7.297	7.374	7.456	7.538	7.615
42	6.971	7.047	7.129	7.209	7.286	7.366	7.448	7.524
42½	6.888	6.963	7.043	7.123	7.199	7.279	7.358	7.434
43	6.806	6.881	6.959	7.039	7.113	7.192	7.271	7.346
43½	6.727	6.800	6.879	6.957	7.030	7.108	7.186	7.260
44	6.649	6.722	6.799	6.876	6.949	7.026	7.103	7.176
44½	6.573	6.645	6.721	6.798	6.870	6.946	7.022	7.094
45	6.498	6.569	6.652	6.721	6.792	6.867	6.943	7.014

VOLUME OF AMMONIA GAS AT HIGH TEMPERATURES. —(Redwood.)

GAUGE PRESSURE	TEMPERATURE OF GAS.					
	60°	74°	80°	84°	90°	95°
	VOLUME OF 1 LB. OF GAS IN CUBIC FEET.					
80	3.470					
85	3.292					
90	3.131					
95			3.035			
100			2.900			
105			2.785			
110				2.695		
115				2.590		
120				2.490		
125					2.418	
130					2.333	
135					2.252	
140						2.204
145					2.134	
150						2.088
155						2.037



FIGS. 19 and 20.—Diagrams showing Curves of Latent Heat of Vaporisation (1 lb. each Saturated Vapour), and Curves of Absolute Pressure for Saturated Vapours of NH₃, SO₂, and CO₂, from -40° to +100° Fahr. 1 lb. each Saturated Vapour.—(Murray, *Inst. Engrs. and Shipbuilders, Scotland, 1897.*)

WOOD'S TABLE OF SATURATED AMMONIA.
(Re-calculated by George Davidson, M.E.)

Temperature.	Pressure Absolute.		Gauge Pressure. lb. per sq. inch.	Heat of Vaporisation, thermal units. λ .	Volume of Vapour per lb. cubic feet. v_1 .	Volume of Liquid per lb. cubic feet. v_l .	Weight of Vapour in lbs. per cubic foot.	Weight of Liquid in lbs. per cubic foot.	Temperature. Degrees F.
	Absolute. F.	Lbs. per sq. foot. P.							
-40	420.66	1539.90	10.69	579.67	24.388	0.02348	0.0410	42.589	-40
39	1	1584.43	11.00	579.07	23.735	0.02351	0.0421	42.535	39
38	2	1630.03	11.32	578.42	23.102	0.02354	0.0433	42.483	38
37	3	1676.71	11.64	577.88	22.488	0.02357	0.0444	42.427	37
36	4	1724.51	11.98	577.27	21.895	0.02359	0.0457	42.391	36
-35	425.66	1773.43	12.31	576.68	21.321	0.02362	0.0469	42.337	-35
34	6	1823.50	12.66	576.08	20.763	0.02364	0.0482	42.301	34
33	7	1874.73	13.02	575.48	20.221	0.02366	0.0495	42.265	33
32	8	1927.17	13.38	574.89	19.708	0.02368	0.0507	42.213	32
31	9	1980.78	13.75	574.39	19.204	0.02371	0.0521	42.176	31
-30	430.66	2035.69	14.13	573.69	18.693	0.02374	0.0535	42.123	-30
29	1	2091.83	14.53	573.08	18.225	0.02378	0.0549	42.052	29
28	2	2149.23	14.92	572.48	17.759	0.02381	0.0563	42.000	28
27	3	2207.94	15.33	571.89	17.307	0.02384	0.0577	41.946	27
26	4	2267.97	15.75	571.28	16.869	0.02387	0.0593	41.893	26

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature. Degrees F.	Absolute. °F.	Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. h_v	Volume of Vapour per lb. cubic foot. v_v	Volume of Liquid per lb. cubic foot. v_l	Weight of Vapour in lbs. per cubic foot. w_v	Weight of Liquid in lbs. per cubic foot. w_l	Temperature. Degrees F.
		Lbs. per sq. foot. P .	Lbs. per sq. inch. p .							
-25	435.66	2329.34	16.17	+1.47	570.68	16.446	0.02389	0.0608	41.858	-25
24	6	2392.09	16.61	1.91	570.08	16.034	0.02392	0.0624	41.806	24
23	7	2456.23	17.05	2.35	569.48	15.633	0.02395	0.0640	41.754	32
22	8	2520.45	17.50	2.8	568.88	15.252	0.02398	0.0656	41.701	22
21	9	2588.77	17.97	3.27	568.27	14.875	0.02401	0.0672	41.649	21
-20	440.66	2657.23	18.45	+3.75	567.67	14.507	0.02403	0.0689	41.615	-20
19	1	2727.17	18.94	4.24	567.06	14.153	0.02406	0.0706	41.563	19
18	2	2798.62	19.43	4.73	566.43	13.807	0.02409	0.0725	41.511	18
17	3	2871.61	19.94	5.24	565.85	13.475	0.02411	0.0742	41.460	17
16	4	2946.17	20.46	5.76	565.25	13.150	0.02414	0.0760	41.425	16
-15	445.66	3022.31	20.99	+6.29	564.64	12.834	0.02417	0.0779	41.374	-15
14	6	3100.07	21.53	6.83	564.04	12.527	0.02420	0.0798	41.322	14
13	7	3179.45	22.08	7.38	563.43	12.230	0.02423	0.0818	41.271	13
12	8	3260.52	22.64	7.94	562.82	11.939	0.02425	0.0838	41.237	12
11	9	3343.29	23.22	8.52	562.21	11.659	0.02428	0.0858	41.186	11

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. $^{\circ}$.	Volume of Vapour per lb. cubic feet. v_1 .	Volume of Liquid per lb. cubic feet. v_2 .	Weight of Vapour in lbs. per cubic foot. w_1 .	Weight of Liquid in lbs. per cubic foot. w_2 .	Temperature, $^{\circ}$ Degrees F.
$^{\circ}$ Degrees F.	Absolute.	Lbs. per sq. foot. P .	Lbs. per sq. inch. p .							
-10	450.66	3427.75	23.80	+ 9.10	561.61	11.385	0.02431	0.0878	41.135	-10
9	1	3513.97	24.40	9.70	560.99	11.117	0.02434	0.0899	41.084	9
8	2	3601.97	25.01	10.31	560.39	10.860	0.02437	0.0921	41.034	8
7	3	3691.75	25.64	10.94	559.78	10.604	0.02439	0.0943	41.000	7
6	4	3783.37	26.27	11.57	559.17	10.362	0.02442	0.0965	40.950	6
-5	455.66	3876.85	26.92	+ 12.22	558.56	10.125	0.02445	0.0988	40.900	-5
4	6	3972.62	27.59	12.89	557.94	9.894	0.02448	0.1011	40.845	4
3	7	4069.48	28.26	13.56	557.33	9.669	0.02451	0.1034	40.799	3
2	8	4168.70	28.95	14.25	556.73	9.449	0.02454	0.1058	40.749	2
1	9	4269.90	29.65	14.95	556.11	9.234	0.02457	0.1083	40.700	1
+0	460.66	4373.10	30.37	+ 15.67	555.50	9.028	0.02461	0.1107	40.650	+0
1	1	4478.32	31.10	16.40	554.88	8.825	0.02463	0.1133	40.601	1
2	2	4485.60	31.84	17.14	554.27	8.630	0.02466	0.1159	40.551	2
3	3	4694.96	32.60	17.90	553.65	8.436	0.02469	0.1186	40.502	3
4	4	4806.46	33.38	18.68	553.04	8.250	0.02472	0.1212	40.453	4

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. <i>h</i> .	Volume of Vapour per lb. cubic feet. <i>v</i> .	Volume of Liquid per lb. cubic feet. <i>v</i> _l .	Weight of Vapour in lbs. per cubic foot. <i>w</i> .	Weight of Liquid in lbs. per cubic foot. <i>w</i> _l .	Temperature. Degrees F.
Degrees F.	Absolute.	Lbs. per sq. foot. <i>P</i> .	Lbs. per sq. inch. <i>p</i> .							
+5	465.66	4920.11	34.16	+19.46	552.43	8.070	0.02475	0.1240	40.404	+5
6	59	5035.95	34.97	20.27	551.81	7.892	0.02478	0.1267	40.355	6
7	7	5153.99	35.79	21.09	551.19	7.717	0.02480	0.1296	40.322	7
8	8	5274.28	36.63	21.93	550.58	7.553	0.02483	0.1324	40.274	8
9	9	5396.83	37.48	22.78	549.56	7.388	0.02486	0.1353	40.225	9
+10	470.66	5521.71	38.34	+23.64	549.35	7.229	0.02490	0.1383	40.160	+10
11	1	5649.48	39.23	24.53	548.73	7.075	0.02493	0.1413	40.112	11
12	2	5778.50	40.13	25.43	548.11	6.924	0.02496	0.1444	40.064	12
13	3	5910.52	41.04	26.34	547.49	6.786	0.02499	0.1474	40.016	13
14	4	6044.96	41.98	27.28	546.88	6.632	0.02502	0.1507	39.968	14
+15	475.66	6182.00	42.94	+28.24	546.26	6.491	0.02505	0.1541	39.920	+15
16	6	6321.24	43.90	29.20	545.63	6.355	0.02508	0.1573	39.872	16
17	7	6463.24	44.88	30.18	545.01	6.222	0.02511	0.1607	39.822	17
18	8	6607.77	45.89	31.19	544.39	6.093	0.02514	0.1641	39.777	18
19	9	6754.90	46.91	32.21	543.74	5.966	0.02517	0.1676	39.729	19

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. A.	Volume of Vapour per lb. cubic feet. v.	Volume of Liquid per lb. cubic feet. vl.	Weight of Vapour in lbs. per cubic foot. zv.	Weight of Liquid in lbs. per cubic foot. zl.	Temperature, Degrees F.
Degrees F.	Absolute. Z.	Lbs. per sq. foot. P.	Lbs. per sq. inch. p.							
+ 20	480.66	6904.68	47.95	+ 33.25	543.15	5.843	0.02520	0.1711	39.682	+ 20
21	1	7057.15	49.01	34.31	542.53	5.722	0.02523	0.1748	39.635	21
22	2	7211.33	50.09	35.39	541.90	5.605	0.02527	0.1784	39.572	22
23	3	7370.27	51.18	36.48	541.28	5.488	0.02529	0.1822	39.541	23
24	4	7530.96	52.30	37.60	540.66	5.378	0.02533	0.1860	39.479	24
+ 25	485.66	7694.52	53.43	+ 38.73	540.03	5.270	0.02536	0.1897	39.432	+ 25
26	6	7860.89	54.59	39.89	539.41	5.163	0.02539	0.1937	39.386	26
27	7	8030.16	55.76	41.06	538.78	5.058	0.02542	0.1977	39.339	27
28	8	8202.38	56.96	42.26	538.16	4.960	0.02545	0.2016	39.292	28
29	9	8377.56	58.17	43.47	537.53	4.858	0.02548	0.2059	39.246	29
+ 30	490.66	8555.74	59.42	+ 44.72	536.91	4.763	0.02551	0.2099	39.200	+ 30
31	1	8736.96	60.67	45.97	536.28	4.668	0.02554	0.2142	39.115	31
32	2	8921.26	61.95	47.25	535.66	4.577	0.02557	0.2185	39.108	32
33	3	9108.71	63.25	48.55	535.03	4.486	0.02561	0.2229	39.047	33
34	4	9299.32	64.58	49.88	534.40	4.400	0.02564	0.2273	39.001	34

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. <i>h</i> .	Volume of Vapour per lb. cubic feet. <i>v</i> .	Volume of Liquid per lb. cubic feet. <i>v</i> _l .	Weight of Vapour in lbs. per cubic foot. <i>w</i> .	Weight of Liquid in lbs. per cubic foot. <i>w</i> _l .	Temperature. Degrees F.
Degrees F.	Absolute.	Lbs. per sq. foot. <i>P</i> .	Lbs. per sq. inch. <i>p</i> .							
+ 35	495.66	9493.07	65.92	+ 51.22	533.78	4.314	0.02568	0.2318	38.940	+ 35
36	6	9690.04	67.29	52.59	533.13	4.234	0.02571	0.2362	38.894	36
37	7	9890.75	68.68	53.98	532.52	4.157	0.02574	0.2413	38.850	37
38	8	10093.91	70.09	55.39	531.89	4.068	0.02578	0.2458	38.789	38
39	9	10300.88	71.53	56.83	531.26	3.989	0.02582	0.2507	38.729	39
+ 40	500.66	10511.16	72.99	+ 58.29	530.63	3.915	0.02585	0.2554	38.684	+ 40
41	1	10724.95	74.48	59.78	529.99	3.839	0.02588	0.2605	38.639	41
42	2	10942.18	75.99	61.29	529.36	3.766	0.02591	0.2655	38.595	42
43	3	11162.93	77.52	62.82	528.73	3.695	0.02594	0.2706	38.550	43
44	4	11387.21	79.08	64.38	528.10	3.627	0.02697	0.2757	38.499	44
+ 45	505.66	11615.12	80.66	+ 65.96	527.47	3.559	0.02600	0.2809	38.461	+ 45
46	6	11846.64	82.27	67.57	526.83	3.493	0.02603	0.2863	38.417	46
47	7	12081.80	83.90	69.20	526.20	3.428	0.02606	0.2917	38.373	47
48	8	12320.71	85.56	70.86	525.57	3.362	0.02609	0.2974	38.328	48
49	9	12563.36	87.25	72.55	524.93	3.303	0.02612	0.3027	38.284	49

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. h_v .	Volume of Vapour per lb. cubic feet. v_1 .	Volume of Liquid per lb. cubic feet. v_l .	Weight of Vapour in lbs. per cubic foot. w_v .	Weight of Liquid in lbs. per cubic foot. w_l .	Temperature. Degrees F.
Degrees F.	Absolute.	Lbs. per sq. foot. P .	Lbs. per sq. inch. p .							
+ 50	510.66	12809.91	88.96	+ 74.26	524.30	3.242	0.02616	0.3084	38.226	+ 50
51	1	13080.21	90.70	76.00	523.66	3.182	0.02620	0.3143	38.167	51
52	2	13314.43	92.46	77.76	523.03	3.124	0.02623	0.3201	38.124	52
53	3	13572.52	94.25	79.55	522.39	3.069	0.02626	0.3258	38.080	53
54	4	13834.64	96.07	81.37	521.76	3.012	0.02629	0.3320	38.037	54
+ 55	515.66	14100.74	97.92	+ 83.22	521.12	2.958	0.02632	0.3380	37.994	+ 55
56	6	14370.92	99.80	85.10	520.48	2.905	0.02636	0.3442	37.936	56
57	7	14645.18	101.70	87.00	519.84	2.853	0.02639	0.3505	37.893	57
58	8	14923.98	103.64	88.94	519.20	2.802	0.02643	0.3568	37.835	58
59	9	15206.28	105.60	90.90	518.57	2.753	0.02646	0.3632	37.793	59
+ 60	520.66	15493.09	107.59	+ 92.89	517.93	2.705	0.02651	0.3697	37.736	+ 60
61	1	15784.23	109.61	94.91	517.29	2.658	0.02654	0.3762	37.678	61
62	2	16079.67	111.66	96.96	516.65	2.610	0.02658	0.3831	37.622	62
63	3	16379.51	113.75	99.05	516.01	2.565	0.02661	0.3898	37.579	63
64	4	16683.75	115.86	101.16	515.37	2.520	0.02665	0.3968	37.523	64

WOOD'S TABLE OF SATURATED AMMONIA.--(Continued.)

Temperature.	Degrees F.	Absolute. Z.	Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. λ .	Volume of Vapour per lb. cubic feet. v .	Volume of Liquid per lb. cubic feet. v_l .	Weight of Vapour in lbs. per cubic foot. w_v	Weight of Liquid in lbs. per cubic foot. w_l	Temperature. Degrees F.
			Lbs. per sq. foot. P .	Lbs. per sq. inch. p .							
+65	525.66		16992.50	118.03	+ 103.33	514.73	2.476	0.02668	0.4039	37.481	+59
66	6		17305.70	120.18	105.48	514.09	2.433	0.02671	0.4110	37.439	69
67	7		17623.45	122.38	107.68	513.45	2.389	0.02675	0.4189	37.383	67
68	8		17945.89	124.62	109.92	512.81	2.351	0.02678	0.4254	37.341	68
69	9		18272.81	126.89	112.16	512.16	2.310	0.02682	0.4329	37.285	69
+70	530.66		18604.53	129.19	+ 114.49	511.52	2.272	0.02686	0.4401	37.230	+70
71	1		18941.00	131.54	116.84	510.87	2.233	0.02689	0.4479	37.188	71
72	2		19282.21	133.90	119.20	510.22	2.194	0.02693	0.4558	37.133	72
73	3		19628.32	136.31	121.61	509.58	2.153	0.02697	0.4645	37.079	73
74	4		19979.22	138.74	124.04	508.93	2.122	0.02700	0.4712	37.037	74
+75	535.66		20335.16	141.22	+ 126.52	508.29	2.087	0.02703	0.4791	36.995	+75
76	6		20696.00	143.72	129.02	507.64	2.052	0.02706	0.4873	36.954	76
77	7		21061.85	146.26	131.56	506.99	2.017	0.02710	0.4957	36.900	77
78	8		21432.82	148.84	134.14	506.34	1.995	0.02714	0.5012	36.845	78
79	9		21808.85	151.45	136.75	505.69	1.952	0.02717	0.5123	36.805	79

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.		Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. <i>h</i> .	Volume of Vapour per lb. cubic feet. <i>v</i> .	Volume of Liquid per lb. cubic feet. <i>v_l</i> .	Weight of Vapour in lbs. per cubic foot. <i>w</i> .	Weight of Liquid in lbs. per cubic foot. <i>w_l</i> .	Temperature. Degrees F.
Degrees F.	Absolute. <i>T</i> .	Lbs. per sq. foot. <i>P</i> .	Lbs. per sq. inch. <i>p</i> .							
+ 80	540.66	22190.15	154.10	+ 139.40	505.05	1.921	0.02721	0.5205	36.751	+ 80
81	1	22576.51	156.78	142.08	504.40	1.889	0.02725	0.5204	36.696	81
82	2	22968.88	159.50	144.80	503.75	1.858	0.02728	0.5382	36.657	82
83	3	23365.38	162.26	147.56	503.10	1.827	0.02732	0.5473	36.603	83
84	4	23767.81	165.05	150.35	502.45	1.799	0.02736	0.5558	36.549	84
+ 85	545.66	24175.61	167.88	+ 153.18	501.81	1.770	0.02739	0.5649	36.509	+ 85
86	6	24588.92	170.75	156.05	501.15	1.741	0.02743	0.5744	36.456	86
87	7	25007.80	173.66	158.96	500.50	1.714	0.02747	0.5834	36.407	87
88	8	25432.16	176.61	161.91	499.85	1.687	0.02751	0.5927	36.350	88
89	9	25862.14	179.59	164.89	499.20	1.660	0.02754	0.6024	36.311	89
+ 90	550.66	26297.88	182.62	+ 167.92	498.55	1.634	0.02758	0.6120	36.258	+ 90
91	1	26739.88	185.69	170.99	497.89	1.608	0.02761	0.6219	36.219	91
92	2	27186.56	188.79	174.09	497.24	1.583	0.02765	0.6317	36.166	92
93	3	27639.43	191.94	177.24	496.59	1.558	0.02769	0.6418	36.114	93
94	4	28098.26	195.13	180.43	495.94	1.534	0.02772	0.6518	36.075	94

WOOD'S TABLE OF SATURATED AMMONIA.—(Continued.)

Temperature.	Degrees F.	Pressure Absolute.		Gauge Pressure, lb. per sq. inch.	Heat of Vaporisation, thermal units. λ_v .	Volume of Vapour per lb. cubic feet. v_v .	Volume of Liquid per lb. cubic feet. v_l .	Weight of Vapour in lbs. per cubic foot.	Weight of Liquid in lbs. per cubic foot.	Temperature, Degrees F.
		Lbs. per sq. foot. P .	Lbs. per sq. inch. p .							
+ 95 96 97 98 99	555.66	28563.00	198.35	+ 183.65	495.29	1.510	0.02776	0.6622	36.023	+ 95
	6	29033.86	201.62	186.92	494.63	1.486	0.02780	0.6729	35.971	96
	7	29510.69	204.94	190.24	493.97	1.463	0.02784	0.6835	35.919	97
	8	29993.52	208.29	193.59	493.32	1.442	0.02787	0.6934	35.881	98
	9	30482.52	211.68	196.98	492.66	1.419	0.02791	0.7047	35.829	99
+ 100	560.66	30977.78	215.12	+ 200.42	492.01	1.398	0.02795	0.7153	35.778	+ 100

TABLE SHOWING REFRIGERATING EFFECT OF ONE CUBIC FOOT OF AMMONIA GAS AT DIFFERENT CONDENSER AND SUCTION (BACK) PRESSURE IN B. T. UNITS.—
(Professor Siebel, "Compend of Mechanical Refrigeration.")

Temperature of Gas in Degrees F.	Corresponding Suction Pressure, lbs. per sq. in.	Temperature of the Liquid in Degrees F.									
		65	70	75	80	85	90	95	100	105	
		Corresponding Condenser Pressure (Gauge) lbs. per square inch.									
G. Pres.	I	103	115	127	139	153	168	184	200	218	
		27.30	27.01	26.73	26.44	26.16	25.87	25.59	25.30	25.02	
		33.74	33.40	33.04	32.70	32.34	31.99	31.64	31.30	30.94	
		36.36	36.48	36.10	35.72	35.34	34.96	34.58	34.20	33.82	
		42.28	41.84	41.41	40.97	40.54	40.10	39.67	39.23	38.80	
		48.31	47.81	47.32	46.82	46.33	45.83	45.34	44.84	44.35	
		54.88	54.32	53.76	53.20	52.64	52.08	51.52	50.96	50.40	
		61.50	60.87	60.25	59.62	59.00	58.37	57.75	57.12	56.50	
		68.66	67.97	67.27	66.58	65.88	65.19	64.49	63.80	63.10	
		75.88	75.12	74.35	73.59	72.82	72.06	71.29	70.53	69.76	
		85.15	84.30	83.44	82.59	81.73	80.88	80.02	79.17	78.31	
		95.50	94.54	93.59	92.63	91.68	90.72	89.97	88.81	87.86	
		106.21	105.15	104.09	103.03	101.97	100.91	99.85	98.79	97.73	
		115.69	114.54	123.39	112.24	111.09	109.94	108.79	107.64	106.49	

USEFUL EFFICIENCY OF AMMONIA.

(Denton and Schroeter.)

No. of Test.	Temperature in Degrees Fahr. Corresponding to Pressure of Vapour.		See Melting Capacity per Pound of Coal, assuming Three Pounds per Hour per Horse-power.		
	Con- denser.	Suction.	Theoretical Friction * included.	Actual.	Per Cent. Loss due to Cylinder Super-heating.
1	72.3	26.6	50.4	40.6	19.4
2	70.5	14.3	37.6	30.0	20.2
3	69.2	0.5	29.4	22.0	25.2
4	68.5	11.8	22.8	16.1	29.4
24	84.2	15.0	27.4	24.2	11.7
26	82.7	-3.2	21.6	17.5	19.0
25	84.6	-10.8	18.8	14.5	22.9

* Friction taken at figures observed in the tests, which range from 14 per cent. to 20 per cent. of the work of the steam cylinder.

LIQUID RECEIVER.

This is a vessel placed between the condenser and the expansion valve to receive and store the liquefied ammonia. The dimensions of the liquid receiver should be sufficient to hold about $\frac{1}{2}$ gallon for each ton of refrigerating capacity in 24 hours. The liquid receiver also serves as an additional oil trap. If, as is sometimes the case, the liquid receiver is intended to act as a storage vessel for all the charge of liquefiable ammonia in the plant in case of repairs, etc., it should be provided with valves, which should not be closed when the receiver is over two-thirds full. Preferably the receiver should be made large enough to contain twice the charge of ammonia to avoid explosions. The receiver is provided with oil and liquid gauges.

TABLE SHOWING EFFICIENCY OF AMMONIA COMPRESSION PLANT UNDER DIFFERENT CONDITIONS.

(Professor Siebel, "Compend of Mechanical Refrigeration.")

NO. OF TEST—		1	2	3	4
Temperature of refrigerated brine	{ Inlet, deg. Fahr. . . Outlet, deg. Fahr. . .	43° 194 37° 054	28° 344 22° 885	13° 952 8° 771	-0° 279 -5° 879
Specific heat of brine (per unit of volume)	{	0° 8608 1039° 38	0° 8508 908° 84	0° 8427 633° 89	0° 8374 414° 98
Quantity of brine circulated per hour, cubic feet . .	. . .	1039° 38 342° 909	908° 84 263° 950	633° 89 172° 776	414° 98 121° 474
Cold produced, B.T.U. per hour . .	. . .	342° 909 48° 832	263° 950 49° 476	172° 776 48° 931	121° 474 49° 098
Temperature of cooling water in condenser { Inlet, deg. Fahr. . . Outlet, deg. Fahr. . .	{	60° 724 338° 76	68° 013 260° 83	67° 282 187° 506	67° 267 139° 99
Quantity of cooling water per hour in cubic feet . .	. . .	338° 76 378° 358	260° 83 301° 404	187° 506 214° 796	139° 99 158° 926
Heat eliminated by condenser B.T.U. per hour . .	. . .	378° 358 13° 82	301° 404 14° 29	214° 796 13° 53	158° 926 11° 98
I.H.P. in compressor cylinder . .	. . .	13° 82 15° 80	14° 29 16° 47	13° 53 15° 28	11° 98 14° 24
I.H.P. in steam engine cylinder . .	. . .	15° 80 311° 51	16° 47 335° 98	15° 28 305° 87	14° 24 278° 79
Consumption of steam per hour in lbs. . .	. . .	311° 51 24° 813	335° 98 18° 471	305° 87 12° 770	278° 79 10° 140
Cold produced per hour B.T.U. { Per I.H.P. in comp. cyl. . . Per I.H.P. in steam cyl. . .	{	21° 703 1100° 8	16° 026 785° 6	11° 307 564° 9	8° 530 435° 82
Per lb. of steam . .	. . .	1100° 8	785° 6	564° 9	435° 82

PROPERTIES OF SATURATED CARBONIC ACID GAS.

(Denton and Jacobus.)*

Temperature of Ebullition in Degrees Fahr.	Absolute Pressure in lbs. per sq. in.	Total Heat reckoned from 32° Fahr.	Heat of Liquid reckoned from 32° Fahr.	Latent Heat of Evaporation.	Heat Equivalent of External Work.	Increase of Volume during Evaporation.	Density of Vapour or Weight of One Cubic Foot.
-22	210	98.35	-37.80	136.15	16.20	0.4138	2.321
-13	249	99.14	-32.51	131.65	16.04	0.3459	2.759
-4	292	99.88	-26.91	126.79	15.80	0.2901	3.265
5	342	100.58	-20.92	121.50	15.50	0.2435	3.853
14	396	101.21	-14.49	115.70	15.08	0.2042	4.535
23	457	101.81	-7.56	109.37	14.58	0.1711	5.331
32	525	102.35	0.00	102.35	13.93	0.1426	6.265
41	599	102.84	8.32	94.52	13.14	0.1177	7.374
50	680	103.24	17.60	85.64	12.15	0.0960	8.708
59	768	103.59	28.22	75.37	10.91	0.0763	10.356
68	864	103.84	40.86	62.98	9.29	0.0577	12.482
77	968	103.95	57.06	46.89	7.06	0.0391	15.475
86	1080	103.72	84.44	19.28	2.95	0.0147	21.519

* Transformed to English units from a metric table computed by Prof. Schwoeter.

SATURATED SULPHUR DIOXIDE GAS.

(Ledoux.)

Temperature of Ebullition in deg. F. <i>t</i>	Absolute Pressure in lbs. per sq. in. <i>P+144</i>	Total Heat reckoned from 32° Fahr. <i>h</i>	Heat of Liquid reckoned from 32° Fahr. <i>q</i>	Latent Heat of Evaporation. <i>r</i>	Heat equivalent of External Work. <i>A Pu</i>	Increase of Volume during Evaporation. <i>"</i>	Density of Vapour or Weight of One Cubic Foot.
Deg. Fahr.	lbs.	B.T.U.	B.T.U.	B.T.U.	B.T.U.	Cubic Feet.	lbs.
-22	5.56	157.43	-19.56	176.90	13.59	13.17	0.076
-13	7.23	158.64	-16.30	174.95	13.83	10.27	0.097
-4	9.27	159.84	-13.05	172.89	14.05	8.12	0.123
5	11.76	161.03	-9.79	170.82	14.26	6.50	0.153
14	14.74	162.20	-6.53	168.73	14.46	5.25	0.190
23	18.31	163.36	-3.27	166.63	14.66	4.29	0.232
32	22.53	164.51	0.00	164.51	14.84	3.54	0.282
41	27.48	165.65	3.27	162.38	15.01	2.93	0.340
50	33.25	166.78	6.55	160.23	15.17	2.45	0.407
59	39.93	167.90	9.83	158.07	15.32	2.07	0.483
68	47.61	168.99	13.11	155.89	15.46	1.75	0.570
77	56.39	170.09	16.39	153.70	15.59	1.49	0.669
86	66.36	171.17	19.69	151.49	15.71	1.27	0.780
95	77.64	172.24	22.98	149.26	15.82	1.09	0.906
104	90.31	173.30	26.28	147.02	15.91	0.91	1.046

USEFUL EFFICIENCY OF SULPHUR DIOXIDE.

(Schroeter.)

No. of Test.	Temperature in Degrees Fahr. corresponding to Pressure of Vapour.		Ice Melting Capacity per Pound of Coal, assuming Three Pounds per Hour per Horse-power.		
	Condenser.	Suction.	Theoretical Friction * included.	Actual.	Per Cent. Loss due to Cylinder Super-heating.
11	77.3	28.5	41.3	33.1	19.9
12	76.2	14.4	31.2	24.1	22.8
13	75.2	-2.5	23.0	17.5	23.9
14	80.6	-15.9	16.6	10.1	39.2

* Friction taken at figures observed in the tests which range from 14 per cent. to 20 per cent. of the work of the steam cylinder.




FIG. 21.—Diagram giving Efficiency Curves of a Perfect Refrigerating Machine at Various Limits of Temperature.—(Murray, *Inst. of Engrs. and Shipbuilders, Scotland, 1897.*)

TABLE SHOWING PROPERTIES OF SATURATED VAPOUR OF ETHER.
(*Professor Siebel, "Compend of Mechanical Refrigeration."*)

Temperature, Degrees Fahr.	Pressure in lbs. per square inch.	Heat of the Liquid.	Total Heat.	Heat of Vaporisation.	Heat equivalent of Internal work.	B. T. Units.	Heat equivalent of external work.	B. T. Units.	Specific Volume.	Weight in lbs. of one cubic foot.
		R. T. Units.	B. T. Units.	B. T. Units.	B. T. Units.		B. T. Units.			
32	3.54	0.00	376.00	376.00	345.80		30.20		1.278	0.048
50	5.51	21.28	393.76	372.48	341.48		31.00		0.844	0.073
68	8.31	42.80	411.12	368.32	336.52		31.80		0.574	0.107
86	12.20	64.56	428.00	363.44	330.88		32.56		0.401	0.154
104	17.46	86.42	444.44	357.92	324.60		33.32		0.287	0.232
122	24.32	88.76	460.44	351.68	317.64		34.04		0.210	0.294
140	33.17	131.20	476.00	344.80	310.12		34.68		0.158	0.392
158	44.32	153.92	491.12	337.20	301.96		35.24		0.120	0.515
176	58.13	176.84	505.76	328.92	293.28		35.64		0.093	0.705
194	74.96	200.00	520.00	320.00	284.12		35.68		0.073	0.848
212	95.25	223.44	532.76	310.32	274.48		35.84		0.057	1.074
230	119.51	247.08	547.12	300.04	264.52		35.32		0.005	1.350
248	148.44	270.96	560.00	289.04	254.28		34.76		0.036	1.703

The following particulars regarding an ether machine are given * by Mr. Lightfoot as being the result of actual experiments made in this country, and serving to show what may be expected under ordinary conditions :—

Production of ice per twenty-four hours ..	15 tons.
" " per hour	1,400 lbs.
Heat abstracted in ice-making, per hour ..	245,000 units **
Indicated horse-power in steam cylinder, excluding that required for circulating the cooling water and for working cranes, etc.	83 I.H.P.
Indicated horse-power in ether pump ..	46½ I.H.P.
Thermal equivalent of work in ether pump, per hour	119,261 units **
Ratio of work in pump to work in ice-making	1 to 2.05
Temperature of water entering condenser	52° Fahr.

Mr. Frederick Colyer, C.E., M.I.C.E., states† that he obtained the following results with a first-class apparatus when testing the working of some of the leading ether machines, viz. : "In an ether machine made by Messrs. Siebe, Gorman and Co., capable of cooling 3,200 gallons of water from 60° down to 50°, or abstracting 320,000 heat units** per hour, the average experiments gave 4,250 gallons per hour cooled to 10° Fahr. The temperature of the water at the inlet was 54°, and that of the water used for condensing purposes was the same. The maximum cooling effected was 449,437 heat units** abstracted per hour, being from 35 to 40 per cent. above the nominal power of the machine. The condensing water used per hour was 1,262 gallons, or about 3-10ths of a gallon for every gallon of water cooled. The coal consumed was 3¼ cwts. per hour; it was of indifferent quality, or the consumption would have been smaller. The steam cylinder was 21 in. diameter and 27 in. stroke; the air-pump 24 in. diameter and 27 in. stroke. The speed of the engine was 58 revolutions per minute, with 48 lbs. of steam cut off at one-third of the stroke. The indicated power of the engine was 53 horse-power, and of the air-pump 29.2 horse-power. The boiler was 7 ft. diameter and 24 ft. long, and gave an ample supply of steam."

* "Proceedings, Institution of Mechanical Engineers," 1886, p. 214.

** A thermal unit is that amount of heat required to raise the temperature of 1 lb. of water 1° by the Fahr. scale when at 39.4°.

† "Proceedings, Institution of Mechanical Engineers," 1886, p. 248.

EFFICIENCY OF ETHER MACHINES.

Output of 15 tons of ice in twenty-four hours. Abstraction of heat per hour, 245,000 B.T.U. Indicated horse-power of engine, 83; of which 46 I.H.P. was used for the ether compressor, balance in pumping water, working cranes, friction, etc. Temperature of cooling water, 52°.

Ice production, about 8·3 tons of ice per ton of coal consumed.

PICTET'S LIQUID.

Temperature Degrees Fahr.	Pressure (Absolute) in Atmospheres.	Temperature Degrees Fahr.	Pressure (Absolute) in Atmospheres.
-22	0·77	50	2·55
-13	0·89	50	2·98
-4	0·98	68	3·40
-2·2	1·00	77	3·92
5	1·18	86	4·45
14	1·34	95	5·05
23	1·60	104	5·72
32	1·83	113	6·30
41	2·20	122	6·86

FORMULA FOR CALCULATING THE AMOUNT OF AIR DELIVERED PER HOUR BY COLD-AIR MACHINES, WHEN THE REVOLUTIONS AND THE SIZE OF THE COMPRESSORS ARE KNOWN.

(*Haslam's Catalogue of "Ice-making and Refrigerating Machinery."*)

$$\text{Air discharged per hour} = \frac{A \times N \times 2R \times S \times 60}{1728} \times C$$

Where A = area of each compressor, in inches.

N = number of compressors.

2R = strokes per minute (or twice the revolutions).

60 = minutes per hour.

S = stroke in inches.

1728 = cubic inches in one foot.

C = factor of efficiency which is taken as 0·8 for short strokes, and 0·85 for long strokes.

SECTION II.

COLD STORAGE.

COLD storage may be defined as the preservation of perishable articles by keeping them in rooms or chambers maintained constantly at a low temperature by refrigeration ; and refrigeration may be defined as the maintenance of any place at a lower temperature than that of the atmosphere.

A most important point in the construction of a cold store is the insulation, and it is almost superfluous to observe that the aim is to render this latter as perfect as possible, so as to afford as great a protection as is practicable against the escape of the cold air from the interior and the transmission of heat from the exterior.

The refrigeration of cold stores may be carried out on the brine circulation system, the direct expansion system, and the air-blast system. In the first, refrigerated or cooled brine is circulated through cooling pipes, or their equivalent, arranged in the cold store ; and in the second the ammonia or refrigerating medium is allowed to expand direct in the above pipes. In the third, or air-blast system, air reduced to a low temperature by passing it over cooled pipes or surfaces, or by means of a cold-air machine, is admitted to the store.

The dimensions of cold stores vary, from that of a few cubic feet space, such as those in private houses, hotels, butchers' shops, etc., up to those of several millions of cubic feet. In the case of a large store it is found most advantageous to arrange for the delivery of goods to or from the store to take place from the highest part of the building, as by this means greater obstacles are offered to the transmission of heat from the exterior to the interior

of the store, and also to the escape of the cold air therefrom, which latter, owing to its being heavier than the surrounding atmosphere, and to its consequent tendency to sink to the lowest level, will not escape from above, whilst it does so readily from any open aperture at a lower level.

AMOUNT OF REFRIGERATION REQUIRED.

The refrigeration required will be governed by the size of the store, the amount of and frequency with which the goods are brought into the store and removed from it, the temperature of the goods, and their specific heat, the mean external temperature, the greater or lesser perfection of the insulation, and various other matters, which render it totally impossible to lay down any hard-and-fast rules.

A very usual practice is to provide 1 foot run of 2-inch pipe for every 7 cubic feet of space contained in the store, but sometimes the proportion used is as much as one to five, whilst again it is occasionally reduced to one to twelve. For refrigerating meat, in which case it is not desirable to cool the exterior too rapidly before the interior has had time to cool to a certain extent, the best proportion to employ is one to ten.

AMOUNT OF REFRIGERATING PIPES NECESSARY FOR CHILLING, STORAGE, AND FREEZING CHAMBERS.

Chilling-rooms or Chambers, refrigerated on the direct expansion system, 1 ft. run of 2-in. piping for each 14 c. ft. of space; on the brine-circulation system, 1 ft. run of 2-in. piping for each 8 c. ft. of space.

Freezing-rooms or Chambers, refrigerated on the direct expansion system, 1 ft. run of 2-in. piping for each 8 c. ft. of space; on the brine-circulation system, 1 ft. run for each 3 c. ft. of space.

Storage-rooms or Chambers, refrigerated on the direct expansion system, 1 ft. run of 2-in. piping for each 45 c. ft. of space; on the brine-circulation system, 1 ft. run of 2-in. piping for each 15 c. ft. of space.

THE FOLLOWING TABLE GIVES THE EXTREME LIMITS OF CUBIC FEET OF SPACE PER RUNNING FOOT OF 2-INCH PIPING.—*American Practice.*

Breweries—Medium insulation.

Chip and Stock Rooms 1 to 22

Fermenting and Settling Rooms 1 „ 20

Packing Rooms 1 „ 18

Hop Rooms 1 „ 25

Packing House.

Chill Rooms for Beef 1 „ 12

Hogs 1 „ 10

Freezing Rooms 1 „ 6 or 7

Cold Storage.

Cold Storage Rooms.. .. 1 „ 25 or 30

Cold Storage House and Freezing Rooms.. 1 „ 8

For Eggs, brine preferred 1 „ 12

Cold Storage 1 „ 25

Ice Storage 1 „ 20

Fish Freezing (Direct Expansion) 1 „ 2

The following five tables are given by Prof. Siebel in the “Compend of Mechanical Refrigeration.”

LINEAL FEET OF 1-INCH PIPING REQUIRED PER CUBIC FOOT OF COLD STORAGE SPACE.

Size of Building in Cubic Feet, more or less.	Insulation.	TEMPERATURE, DEGREES FAHR.					
		0°.	10°.	20°.	30°.	40°.	50°.
100	Excellent.	3·0	1·78	0·48	0·36	0·24	0·15
	Poor.	6·0	1·50	0·90	0·66	0·48	0·30
1,000	Excellent.	1·0	0·26	0·16	0·12	0·08	0·05
	Poor.	2·0	0·50	0·30	0·22	0·16	0·10
10,000	Excellent.	0·61	0·16	0·10	0·075	0·055	0·035
	Poor.	1·2	0·33	0·20	0·15	0·11	0·07
30,000	Excellent.	0·5	0·13	0·08	0·06	0·040	0·025
	Poor.	1·0	0·25	0·15	0·11	0·03	0·05
100,000	Excellent.	0·38	0·10	0·06	0·045	0·03	0·009
	Poor.	0·75	0·20	0·12	0·09	0·06	0·018

NOTE.—The above quantities of pipe refer to direct expansion, and should be made one and one-half times to twice the length for brine circulation. To find the corresponding lengths of 1½-inch pipe, divide by 1·25 or multiply by 0·8; of 2-inch pipe divide by 1·08, or multiply by 0·55.

NUMBER OF CUBIC FEET COVERED BY ONE FOOT OF 1-INCH
IRON PIPE.

Size of Building in Cubic Feet more or less.	Insulation.	TEMPERATURE, DEGREES FAHR.					
		0°.	10°.	20°.	30°.	40°.	50°.
100	Excellent.	0·3	1·3	2·1	2·8	4·2	7·0
	Poor.	0·15	0·7	1·1	1·5	2·1	3·5
1,000	Excellent.	1·0	4·0	6·0	8·4	12·4	20·0
	Poor.	0·5	2·0	3·2	4·5	6·2	10·0
10,000	Excellent.	1·7	6·0	10·0	13·0	18·0	28·0
	Poor.	0·85	3·0	5·0	6·5	9·0	14·0
30,000	Excellent.	2·0	8·0	14·0	18·0	25·0	40·0
	Poor.	1·0	4·0	7·0	9·0	13·0	20·0
100,000	Excellent.	2·6	10·0	17·0	22·0	33·0	110·0
	Poor.	1·3	5·0	8·5	11·0	17·0	55·0

NOTE.—The above figures refer to direct expansion, from one-half to two-thirds of the spaces only would be covered by the same amount of pipe in case of brine circulation. To find the corresponding amounts of cubic feet of space which would be covered by one lineal foot of $1\frac{1}{4}$ -in. pipe, multiply by 1·25 or divide by 0·8; of 2-in. pipe, multiply by 1·08 or divide by 0·55.

NUMBER OF CUBIC FEET COVERED BY 1-TON REFRIGERAT-
ING CAPACITY FOR 24 HOURS.

Size of Building in Cubic Feet, more or less.	Insulation.	TEMPERATURE, DEGREES FAHR.					
		0°.	10°.	20°.	30°.	40°.	50°.
100	Excellent.	150	600	800	1000	1600	3000
	Poor.	70	300	400	600	900	2000
1,000	Excellent.	500	2500	3000	4000	6000	12000
	Poor.	250	1500	1800	2500	5000	10000
10,000	Excellent.	700	3000	4000	6000	9000	18000
	Poor.	300	1800	2500	3500	7000	14000
30,000	Excellent.	1000	5000	6000	8000	13000	25000
	Poor.	500	3000	3500	5000	11000	20000
100,000	Excellent.	1500	7500	9000	14000	20000	40000
	Poor.	800	4500	5000	8000	16000	35000

ROUGH ESTIMATE OF REFRIGERATION IN BREWERIES.

A ready method of obtaining a rough estimate in tons of the amount of refrigeration required in a brewery is to divide the capacity of the brewery in barrels by 4.

REFRIGERATING CAPACITY IN B.T.U. REQUIRED PER CUBIC FOOT OF STORAGE ROOM IN TWENTY-FOUR HOURS.

Size of Building in Cubic Feet, more or less.	Insulation.	TEMPERATURE, DEGREES FAHR.					
		0°.	10°.	20°.	30°.	40°.	50°.
100	Excellent.	1,800	480	360	284	180	95
	Poor.	4,000	960	480	470	330	140
1,000	Excellent.	550	110	95	70	47	24
	Poor.	1,100	190	165	110	55	28
10,000	Excellent.	400	95	70	47	30	16
	Poor.	900	160	110	81	40	20
30,000	Excellent.	280	55	47	35	22	11
	Poor.	550	95	81	55	26	14
100,000	Excellent.	190	38	30	20	14	7
	Poor.	350	63	55	35	18	4

VARIATION IN CAPACITY, ETC., OF A REFRIGERATING MACHINE.

The following diagram (Fig. 22) and table (on page 75), showing the variation in capacity, etc., of a refrigerating machine, and the economy of direct expansion, is drawn up by the De La Vergne Company :—




FIG. 22.—Diagram showing Variation in Capacity, Cost of Fuel, and Work Required of a Refrigerating Machine.—(*De La Vergne Company.*)

In the above diagram the line marked "capacity of machine" shows the diminished capacity as the back pressure is reduced. If the machine has a capacity of ten tons at a return pressure of 28 pounds, as shown by vertical height of the curve, it has a capacity of five tons only with a return pressure of six pounds. Under the same circumstances the cost of fuel per ton is increased in the ratio of the vertical heights to the curve marked "cost of fuel," namely, from 14.5 to 25. In other words, the cost per ton is nearly doubled while the capacity is halved. The work, as seen by the curve marked "work required," diminishes very slowly.

This shows very plainly the economy of direct expansion. The ammonia in the coils of the brine tank must be cooled below the brine or the directly expanded ammonia. If the difference be 10° , say 5° instead of 15° , then the capacity of the machine is reduced in the ratio of 10 to 8, or 20 per cent., and the cost for fuel increased in the ratio of from 14.5 to 17.5, or 20 per cent.

These are physical facts which cannot be explained away, and the economy of direct expansion in practice over both brine and air circulation is usually greater than the diagram and table illustrates.

**CUBIC FEET OF AMMONIA GAS PER MINUTE TO PRODUCE
ONE TON OF REFRIGERATION PER DAY.**

CONDENSER.

REFRIGERATOR.	<i>p</i>		103	115	127	139	153	168	185	200	218
	<i>p</i>	<i>t</i>	65°	70°	75°	80°	85°	90°	95°	100°	105°
4	-20°	5.84	5.9	5.96	6.03	6.09	6.16	6.23	6.30	6.43	
6	-15°	5.35	5.4	5.46	5.52	5.58	5.64	5.70	5.77	5.83	
9	-10°	4.66	4.73	4.76	4.81	4.86	4.91	4.97	5.05	5.08	
13	-5°	4.09	4.12	4.17	4.21	4.25	4.30	4.35	4.40	4.44	
16	0°	3.59	3.63	3.66	3.70	3.74	3.78	3.83	3.87	3.91	
20	5°	3.20	3.24	3.27	3.30	3.34	3.38	3.41	3.45	3.49	
24	10°	2.87	2.9	2.93	2.96	2.99	3.02	3.06	3.09	3.12	
28	15°	2.59	2.61	2.65	2.68	2.71	2.73	2.76	2.80	2.82	
33	20°	2.31	2.34	2.36	2.38	2.41	2.44	2.46	2.49	2.51	
39	25°	2.06	2.08	2.10	2.12	2.15	2.17	2.20	2.22	2.24	
45	30°	1.85	1.87	1.89	1.91	1.93	1.95	1.97	2.00	2.01	
51	35°	1.70	1.72	1.74	1.76	1.77	1.79	1.81	1.83	1.85	

DETERMINATION OF MOISTURE IN AIR.—(Siebel.)

The moisture in the atmosphere may be determined by a wet-bulb thermometer, which is an ordinary thermometer, the bulb of which is covered with muslin kept wet, and

which is exposed to the air, the moisture of which is to be ascertained. Owing to the evaporation of the water on the muslin, the thermometer will shortly acquire a stationary temperature, which is always lower than that of the surrounding air (except when the latter is actually saturated with moisture). If t is the temperature of the atmosphere, and t_1 the temperature of the wet-bulb thermometer in degrees Celsius, the tension e , of the aqueous vapour in the atmosphere, is found by the formula—

$$e = e_1 - 0.00077(t - t_1)h_1$$

e_1 being the maximum tension of aqueous vapour for the temperature t_1 as found in table, and h the barometric length in millimeters. (*See table, p. 77.*)

If e_2 is the maximum tension of aqueous vapour for the temperature t , the degree of saturation, H , is expressed by—

$$H = \frac{e}{e_2}$$

and the dew point is also readily found in the same table, it being the temperature corresponding to the tension e .

PSYCHROMETERS.

Instead of the wet-bulb thermometer alone, it is more convenient to use two exact thermometers combined (one with a wet bulb and the other with a dry bulb, to give the temperature of the air), to determine the hygrometric condition of the atmosphere, or of the air in a room. Instruments on this principle can be readily bought, and are called psychrometers. If they are arranged with a handle, so that they can be whirled around, they are called "sling psychrometers." These permit a quicker correct reading of the wet-bulb thermometer than the plain psychrometer, in which the thermometers are stationary and are impracticable at a temperature below 32° Fahr., while the sling instrument can be read down to 27° Fahr.

The following table can be used to ascertain the degree of saturation or the relative humidity of air :—

RELATIVE HUMIDITY—PER CENT.—(*U.S. Weather Bureau.*)

<i>t</i> (Dry Ther.)	Difference between the Dry and Wet Thermometers (<i>t</i> — <i>t</i> ₁).												<i>t</i> (Dry Ther.)
	0°·5	1°·0	1°·5	2°·0	2°·5	3°·0	3°·5	4°·0	4°·5	5°·0	5°·5	6°·0	
28	94	88	82	77	71	65	60	54	49	43	38	33	28
29	94	89	83	77	72	66	61	56	50	45	40	35	29
30	94	89	84	78	73	67	62	57	52	47	41	36	30
31	95	89	84	79	74	68	63	58	53	48	43	38	31
32	95	90	84	79	74	69	64	59	54	50	45	40	32
33	95	90	85	80	75	70	65	60	56	51	47	42	33
34	95	91	86	81	75	72	67	62	57	53	48	44	34
35	95	91	86	82	76	73	69	65	59	54	50	45	35
36	96	91	86	82	77	73	70	66	61	56	51	47	36
37	96	91	87	82	78	74	70	66	62	57	52	48	37
38	96	92	87	83	79	75	71	67	63	58	54	50	38
39	96	92	88	83	79	75	72	68	63	59	55	52	39
40	96	92	88	84	80	76	72	68	64	60	56	53	40

The hygrometer of Professor Marvin is a sling psychrometer of improved construction.

HYGROMETERS.

While the term "hygrometer" applies to all instruments calculated to ascertain the amount of moisture in the air, it is specifically used to designate instruments on which the degree of humidity can be read off directly on a scale without calculation and table. Their operation is based on the change of the length of a hair, or similar hygroscopic substance under different conditions of humidity.

Table giving weights of aqueous vapour held in suspension by 100 lbs. of pure dry air when saturated, at different temperatures, and under the ordinary atmospheric pressure of 29.9 in. of mercury.—(*Box and Lightfoot.*)

Temper- ature.	Weight of vapour.	Temper- ature.	Weight of vapour.
Fahr. degs.	lbs.	Fahr. degs.	lbs.
-20	0.0350	102	4.547
-10	0.0574	112	6.253
0	0.0918	122	8.584
+10	0.1418	132	11.771
20	0.2265	142	16.170
32	0.379	152	22.465
42	0.561	162	31.713
52	0.819	172	46.338
62	1.179	182	71.300
72	1.680	192	122.643
89	2.361	202	280.230
92	3.289	212	Infinite

N.B.—The weight in lbs. of the vapour mixed with 100 lbs. of pure air at any given temperature and pressure is given by the formula—

$$\frac{62.3E}{29.9 - E} \times \frac{29.9}{p}$$

Where E = elastic force of the vapour at the given temperature, in inches of mercury (to be taken from Tables).

p = absolute pressure in inches of mercury.

= 29.9 for ordinary atmospheric pressure.

CORRECT RELATIVE HUMIDITY FOR A GIVEN TEMPERATURE IN EGG ROOMS.—(*Madison Cooper.*)

TEMPERATURE IN DEGREES FAHR.	RELATIVE HUMIDITY PER CENT.
28	80
29	78
30	76
31	74
32	71
33	69
34	67
35	65
36	62
37	60
38	58
39	56
40	53

SPECIFIC HEAT AND COMPOSITION OF VICTUALS.

	Water.	Solids.	Specific Heat above Freezing Calc.	Specific Heat below Freezing Calc.	Latent Heat of Freezing Calc.
Lean beef ..	72·00	28·00	0·77	0·41	102
Fat beef ..	51·00	49·00	0·60	0·34	72
Veal ..	63·00	37·00	0·70	0·39	90
Fat pork ..	39·00	61·00	0·51	0·30	55
Eggs ..	70·00	30·00	0·76	0·40	100
Potatoes ..	74·00	26·00	0·80	0·42	105
Cabbages ..	91·00	9·00	0·93	0·48	129
Carrots ..	83·00	17·00	0·87	0·45	118
Cream ..	59·25	30·75	0·68	0·38	84
Milk ..	87·50	12·50	0·90	0·47	124
Oysters ..	80·38	19·62	0·84	0·44	114
White fish ..	78·00	22·00	0·82	0·43	111
Eels ..	62·07	37·93	0·69	0·38	88
Lobsters ..	76·62	23·38	0·81	0·42	108
Pigeons ..	72·40	27·60	0·78	0·41	
Poultry ..	73·70	26·30	0·80	0·42	

TEMPERATURES ADAPTED FOR THE COLD STORAGE OF VARIOUS ARTICLES.

Degrees Fahrenheit.

Article.	Wallis-Taylor.	Siebel.	Schmidt.	Getty.	Ice and Refrigeration.	Ice and Cold Storage.	Rane.	Madison Cooper.
Ale	—	33-42	—	—	—	—	—	—
Apples	32-36	33	32-36	32	32-36	33-36	—	31
Apples (Summer) ..	—	—	—	—	—	—	38-42	—
Apples (Winter) ..	—	—	—	—	—	—	32-35	—
Apple and Peach Butter ..	—	—	—	40	—	—	—	42
Asparagus	34	34	34-35	34	34	35	34	33
Bananas	40-45	34-36	34	35	40-45	40-45	—	36
Beans (dried)	32-40	—	—	32-40	—	32-40	—	40
Beef (fresh)	—	—	—	37-39	—	—	—	35
Beef (dried)	—	—	—	36-45	—	—	—	—
Beer (in casks or barrels) ..	33-42	33-42	33-35	—	33-42	33-40	—	—
Beer (in bottles) ..	45	45	45	—	45	45	—	45
Berries (fresh, for ten days) ..	36-40	—	—	35	—	36-40	—	40
Buckwheat flour	40	—	—	—	—	40	—	42
Butter	32-38	32-35	18-25	32-35	32-38	25-30	—	14
Butter (to freeze) ..	—	—	—	20	—	—	—	—
Butterine	35	—	—	—	—	35	—	20
Cabbages	34	—	—	33	—	35	—	32
Cantaloupes	40	—	—	—	—	40	—	40
Carrots	34	—	—	34	—	35	—	33

TEMPERATURES ADAPTED FOR THE COLD STORAGE OF VARIOUS ARTICLES.—(Continued.)

Article.	Wallis-Taylor.	Siebel.	Schmidt.	Getty.	Ice and Refrigeration.	Ice and Cold Storage.	Rane.	Madison Cooper.
Celery ..	..	32-34	33-35	34	32-34	35	—	32
Cheese ..	..	32-33	32-33	31-32	32-33	32-33	—	35
Chestnuts ..	..	33	—	33	—	33	—	40
Chocolate (to cool)	..	40	—	—	—	—	—	—
Cider ..	..	30-40	30-40	—	30-40	35-40	—	32
Cigars ..	..	35	—	35	—	35	—	42
Clarets ..	..	—	45-50	—	—	—	—	42
Corn Meal ..	..	—	—	—	—	—	—	45
Corn (dried)	..	35	—	35	—	35	—	33
Cranberries ..	..	34-36	—	—	—	34-36	—	—
Cream ..	..	35	—	—	—	—	38-40	38
Cucumbers ..	..	—	—	—	—	—	—	32
Currants ..	..	—	—	—	—	—	—	45
Dates ..	..	55	—	—	—	55	—	30
Eggs ..	..	33-35	32-33	—	32-35	33-35	—	28
Ferns ..	..	—	—	—	—	—	—	—
Figs ..	..	55	—	35	—	—	—	28
Fish (fresh)	..	25-30	20	25	25-30	25-30	—	17
Fish (fresh water, frozen)	..	—	—	—	—	—	—	14
Fish (salt water, frozen)	..	—	—	—	—	—	—	—
Fish (canned)	..	—	—	35	—	—	—	40
Fish (dried)	..	35	35-36	36	35	35	—	5
Fish (to freeze)	..	—	—	40	40	—	—	—
Flour, &c.	..	—	36-40	—	—	—	—	—
Fruits ..	..	26-55	—	38	—	35-40	—	40
Fruits (dried)	..	35-40	—	35	—	35	—	30
Fruits (canned)	..	35	—	—	—	—	—	—

TEMPERATURES ADAPTED FOR THE COLD STORAGE OF VARIOUS ARTICLES.—(Continued.)

Article.	Wallis-Taylor.	Siebel.	Schmidt.	Getty.	Ice and Refrigeration.	Ice and Cold Storage.	Rane.	Madison Cooper.
Furs (undressed)	35	35	—	35	35	—	—	35
Furs (dressed)	25-32	25-32	28-35	25-32	25-32	35	—	25
Game (frozen)	25-28	25-28	25-28	27	25-28	25-28	—	28
Game (to freeze)	15-28	—	—	0-5	—	15-28	—	—
Game (long storage)	—	—	—	—	—	—	—	—
Grapes	36-38	32-40	34-36	32-40	36-38	36-38	38-40	10
Ginger ale	36	36	—	—	—	35	—	34
Hams	—	—	—	30-35	—	—	—	36
Hogs	—	—	—	30-33	—	—	—	20
Hops	33-40	33-36	32-40	35	33-40	35-40	—	—
Hops (frozen)	—	—	—	—	—	28	—	35
Honey	45	36-40	45	37-40	45	45	—	45
Lard	—	—	—	34-45	—	—	—	—
Lemons	36-40	36-45	33-36	35-45	36-40	36-40	—	38
Liver	—	—	—	30	—	—	—	20
Maple syrup sugar	—	—	—	40-45	—	—	—	45
Margarine	—	35	18-25	—	35	—	—	—
Meat (brined)	—	—	—	35-40	—	—	—	—
Meat (canned)	35	—	—	35	—	35	—	30
Meat (fresh)	34	35	35-40	—	34	35	—	35
Melons (for 3 or 4 weeks)	—	—	—	32	—	—	—	—
Milk	—	—	—	33-36	—	—	—	—
Mutton (fresh)	—	—	—	—	—	—	—	—

TEMPERATURES ADAPTED FOR THE COLD STORAGE OF VARIOUS ARTICLES.—(Continued.)

Article.	Wallis-Taylor.	Siebel.	Schmidt.	Getty.	Ice and Refrigeration.	Ice and Cold Storage.	Range.	Madison Cooper.
Mutton (frozen) ..	25—28	—	—	—	—	—	—	—
Nuts (in shells) ..	35	35—38	35—40	35—38	35	35	—	40
Oatmeal ..	40	—	—	—	—	40	—	42
Oleomargarine ..	35	—	—	—	—	35	—	20
Oil ..	35	—	—	35	—	35	—	45
Onions ..	34—40	32—33	36	32	34—40	35—40	34—40	32
Oranges ..	45—50	36	34—36	35—36	45—50	45—50	—	34
Oysters ..	33—35	—	—	—	—	33—35	—	33
Oysters (in tubs)	25	—	—	35	—	25	—	35
Oysters (in shells)	33	—	—	40	—	30	—	43
Ox tails ..	—	—	—	32	—	—	—	—
Parsnips ..	34	—	—	34	—	35	—	32
Peaches ..	45—55	35—45	34—36	35—45	45—55	45—55	36—38	36
Pears ..	34—36	33—36	34—36	38	34—36	35	33—38	33
Peas (dried)	40	—	—	40	—	40	—	45
Plums ..	—	—	—	—	—	—	38—40	32
Porter ..	—	33—42	—	—	—	—	—	—
Pork ..	34	—	—	—	—	—	—	—
Potatoes ..	36—40	34—36	—	35	36—40	36—40	36—40	34
Poultry (frozen) ..	28—30	28—30	20—28	29	28—30	28—30	—	28
Poultry (to freeze)	18—22	—	—	5—10	—	18—22	—	—
Poultry (long storage)	—	—	—	—	—	—	—	10
Sardines (canned)	35	—	—	—	—	35	—	40

TEMPERATURES ADAPTED FOR THE COLD STORAGE OF VARIOUS ARTICLES.—(Continued.)

Article.	Wallis-Taylor.	Siebel.	Schmidt.	Getty.	Ice and Refrigeration.	Ice and Cold Storage.	Rane.	Madison Cooper.
Sauerkraut ..	35—38	—	—	36—38	—	35—38	—	38
Sausage casings ..	—	—	—	30—35	—	—	—	20
Sugar, &c. ..	40—45	—	—	—	—	40—45	—	45
Sweet corn ..	—	—	—	35	—	—	—	—
Syrup ..	35	—	—	35	—	35	—	45
Tenderloin, butts, ribs, ..	—	—	—	30—35	—	—	—	—
Tomatoes ..	—	—	38—42	35	—	35	38—42	42
Tobacco ..	35	34—35	—	35	—	35	—	42
Veal ..	—	—	—	32—36	—	—	—	—
Vegetables ..	34—40	—	—	—	—	—	—	—
Water-melons ..	34	—	—	—	—	35	—	40
Wheatflour ..	40	—	—	—	—	40	—	42
Wines ..	40—45	40—45	40—45	—	40—45	45—50	—	42
Woollens, &c. ..	25—32	25—32	28—35	25—32	25—32	25—30	—	—

MEAN TEMPERATURES OF PRINCIPAL CITIES OF THE WORLD.

CITIES.	Spring.	Summer.	Autumn.	Winter.	Annual.
ENGLAND.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.
Birmingham ..	48·0	62·0	50·0	34·2	48·2
Bristol ..	49·7	63·0	51·5	40·0	51·05
Liverpool ..	48·8	62·9	51·8	39·8	50·8
London ..	49·0	62·8	51·3	39·5	50·6
Manchester ..	48·0	62·0	50·5	34·8	48·8
SCOTLAND.					
Edinburgh ..	45·7	57·9	48·0	38·5	47·5
Glasgow ..	47·9	60·9	50·5	39·9	49·8
IRELAND.					
Belfast ..	—	—	—	—	52·1
Dublin ..	—	—	—	—	50·1
FRANCE.					
Bordeaux ..	—	—	—	—	57·0
Boulogne ..	—	—	—	—	54·4
Marseilles ..	—	—	—	—	58·3
Nice ..	55·9	72·5	63·0	48·7	60·1
Paris ..	—	—	—	—	51·3
GERMANY.					
Berlin ..	46·4	63·1	47·8	30·6	47·5
Breslau ..	—	—	—	—	46·7
Buda Pesth ..	—	—	—	—	47·5
Dresden ..	—	—	—	—	49·1
Frankfort ..	—	—	—	—	49·6
Hamburg ..	—	—	—	—	48·0
Leipsic ..	—	—	—	—	46·4
Munich ..	—	—	—	—	48·4
Trieste ..	53·8	71·5	56·6	39·5	55·8
Vienna ..	49·5	63·9	52·8	39·9	—
ITALY.					
Florence ..	—	—	—	—	59·2
Genoa ..	—	—	—	—	61·1
Milan ..	—	—	—	—	55·1
Naples ..	59·5	74·5	62·5	49·9	61·6
Palermo ..	59·5	74·5	65·9	52·0	63·1
Rome ..	57·4	73·2	61·7	46·6	59·7
Turin ..	53·1	71·6	53·8	33·4	53·1
Venice ..	—	—	—	—	55·4

**MEAN TEMPERATURES OF PRINCIPAL CITIES OF THE
WORLD.—(Continued.)**

CITIES.	Spring.	Summer.	Autumn.	Winter.	Annual.
	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.
SPAIN & PORTUGAL.					
Barcelona ..	—	—	—	—	63·0
Madrid ..	57·6	74·1	56·7	42·1	57·6
Lisbon ..	59·9	71·1	62·5	52·3	61·4
SWITZERLAND.					
Berne ..	45·8	60·4	47·3	30·4	46·0
Geneva ..	—	—	—	—	52·7
HOLLAND.					
Amsterdam ..	—	—	—	—	49·9
Rotterdam ..	—	—	—	—	51·0
BELGIUM.					
Brussels ..	—	—	—	—	50·7
NORWAY & SWEDEN.					
Christiania ..	39·2	59·5	42·4	25·2	41·7
Stockholm ..	38·3	61·0	43·8	25·4	42·1
DENMARK.					
Copenhagen ..	43·7	63·0	48·5	31·5	46·8
RUSSIA.					
Moscow ..	43·3	62·6	34·9	13·5	38·5
Nicolaief ..	49·3	72·2	50·0	25·9	48·7
St. Petersburg..	35·1	60·3	40·5	16·6	38·3
Warsaw ..	44·6	63·5	46·4	27·5	45·5
TURKEY.					
Bucharest ..	—	—	—	—	46·4
Constantinople.	51·8	73·4	60·4	40·6	56·7
PALESTINE.					
Jerusalem ..	60·6	72·6	66·3	49·6	62·2
EGYPT.					
Cairo ..	71·6	84·6	74·3	58·5	72·3
ALGERIA.					
Algiers ..	63·0	74·5	70·5	50·4	64·6
Tunis ..	—	—	—	—	68·8

**MEAN TEMPERATURES OF PRINCIPAL CITIES OF THE
WORLD.—(Continued.)**

CITIES.	Spring.	Summer.	Autumn.	Winter.	Annual.
NORTH AMERICA.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.	Degs. Fahr.
Baltimore ..	60·0	83·0	64·6	43·5	54·9
Boston ..	48·0	66·0	53·0	28·0	49·0
Chicago ..	52·8	74·5	61·3	38·5	45·9
Cincinnati ..	63·2	81·8	66·4	46·6	54·7
Mexico ..	53·6	63·5	65·1	60·2	60·5
Montreal ..	44·2	69·1	47·1	17·5	43·7
New Orleans ..	73·0	84·0	72·0	58·0	72·0
New York ..	50·0	72·0	56·0	33·0	53·0
Philadelphia ..	52·0	76·0	57·0	34·0	55·0
Quebec ..	—	—	—	—	40·3
San Francisco ..	58·0	59·0	60·0	53·0	57·5
St. Louis ..	84·6	67·8	44·6	46·0	55·0
Washington ..	69·0	79·0	58·0	38·0	59·0
SOUTH AMERICA.					
Buenos Aires ..	59·4	73·0	64·6	52·5	62·5
Lima ..	63·0	73·2	69·6	59·0	66·2
Quito ..	60·3	60·1	62·5	59·7	60·1
Rio Janeiro ..	72·5	79·0	74·5	68·5	73·6
Valparaiso ..	—	—	—	—	64·0
EAST INDIES.					
Bombay ..	—	—	—	—	81·3
Calcutta ..	82·6	83·3	80·0	67·8	78·4
Madras ..	—	—	—	—	81·9
WEST INDIES.					
Havanna ..	—	—	—	—	79·1
Kingstown ..	78·3	81·3	80·0	76·3	79·0
Port of Spain ..	—	—	—	—	81·5
CHINA.					
Canton ..	69·8	82·0	72·9	54·8	69·8
Pekin ..	56·6	77·8	54·9	29·0	52·6
AUSTRALASIA.					
Melbourne ..	—	—	—	—	57·0
Paramatta ..	66·6	73·9	64·8	54·5	64·6
Sydney ..	—	—	—	—	65·8
CANARY ISLANDS.					
Funchal ..	63·5	70·0	67·6	61·3	65·7
NEW ZEALAND.					
Auckland ..	60·1	66·7	58·0	53·5	59·6

MEAN TEMPERATURE BY SEASONS AND EXTREMES, FOR THE YEAR, OF TWENTY STATIONS
IN THE ARGENTINE REPUBLIC.—(*Degrees Fahrenheit.*)
(*Especially compiled by the Argentine Meteorological Office.*)

Station.	Summer.	Autumn.	Winter.	Spring.	Annual.	Extremes.	
						Max.	Min.
<i>Capital of the Republic.</i>							
Buenos Aires	73·4	62·6	51·8	61·4	62·3	104·0	28·4
<i>Province of Buenos Aires.</i>							
Bahia Blanca	71·6	59·0	47·0	59·5	59·3	105·8	23·0
<i>Province of Santa-Fé.</i>							
Rosario	76·5	62·0	50·5	63·1	63·0	111·1	17·7
<i>Province of Entre-Rios.</i>							
Paraná	76·5	66·2	55·4	66·2	66·1	107·6	30·2
Concordia	77·5	65·0	54·8	65·0	65·6	107·6	30·2
<i>Province of Corrientes.</i>							
Corrientes	79·4	71·0	61·3	71·0	70·7	107·6	37·4
<i>Province of Córdoba.</i>							
Córdoba	73·4	61·3	51·8	64·4	62·7	111·1	15·8
<i>Province of Tucumán.</i>							
Tucumán	75·2	65·6	57·8	68·0	66·6	111·1	26·6
<i>Province of Salta.</i>							
Salta	71·6	62·6	54·2	66·2	63·6	95·0	24·8
<i>Province of Santiago del Estero.</i>							
Santiago del Estero	80·6	69·2	58·5	72·8	70·3	109·4	28·4

MEAN TEMPERATURE BY SEASONS AND EXTREMES, FOR THE YEAR, OF TWENTY STATIONS
IN THE ARGENTINE REPUBLIC.—(*Degrees Fahrenheit.*) (Continued.)
(Especially compiled by the Argentine Meteorological Office.)

Station.	Summer.	Autumn.	Winter.	Spring.	Annual.	Extremes.	
						Max.	Min.
<i>Province of Mendoza.</i>							
Mendoza	74·6	60·8	48·2	64·4	62·0	107·6	17·6
<i>Province of San Juan.</i>							
San Juan	78·8	64·4	51·2	68·0	65·4	111·1	28·4
<i>Province of Jujuy.</i>							
Jujuy	78·2	70·4	59·5	72·8	70·2	104·0	30·2
<i>Province of Catamarca.</i>							
Andalgala	78·2	66·2	53·6	69·2	66·8	104·0	28·4
<i>Province of San Luis.</i>							
San Luis	74·0	59·5	49·5	63·2	61·6	102·2	23·0
<i>Province of Rioja.</i>							
Rioja	76·3	66·8	54·6	71·4	67·3	109·4	32·0
<i>Territorio Nacional Chubut.</i>							
Rawson	68·5	54·2	42·8	57·2	55·7	102·2	14·0
<i>Territorio Nacional Neuquén.</i>							
Chos Malal	71·6	56·6	45·2	57·2	57·6	102·2	14·0
<i>Territorio Nacional Misiones.</i>							
Posadas	79·2	72·2	59·6	73·2	71·0	100·4	35·6
<i>Territorio Nacional Formosa.</i>							
Formosa	80·0	71·0	63·1	71·6	71·4	104·0	30·2

CONDITIONS OF DEPOSIT AND REGULATIONS.

The Conditions of Deposit are as follows :—

The Cambria Cold Storage and Ice Co., Ltd., receive goods on the following conditions only :—

- 1.—No goods will be given up without the production of a ticket, which is delivered to the person when goods are brought to Stores, or satisfactory evidence of ownership.
- 2.—All consignments to the Stores must be plainly marked with the owner's name and address, and date.
- 3.—All payments for storage must be made when the goods are delivered.
- 4.—The Company will not be responsible for any loss or damage to goods stored by them, through maintaining too high or too low a temperature in the Stores, failure of machinery, fire, or any other cause whatsoever; but the Company will always, and at all times, use their utmost endeavours to prevent any such damage, and will render all assistance in their power to properly preserve and keep goods entrusted to their care.
- 5.—The Company reserve to themselves the right to refuse any goods that, in the opinion of the Manager, or his representative, are unfit to store.
- 6.—The Company will hold all goods stored by them subject to a general lien for all debts due by Depositors on account of Storage.
- 7.—Stores open for receiving and delivering goods :—" Week-days, 6 a.m. to 5 p.m.; Saturday, 6 a.m. to 5 p.m., and 10.30 p.m. to 11.30 p.m."

COLD STORAGE CHARGES (*United States*).

Substance.	Temperature. Degrees.	Month.	For the Season.	Remarks.
Salt meat ..	32 to 36	25 to 35 cents	—	Per tierce.
" ..	32 to 36	20 to 25 "	—	Per barrel.
Dried beef ..	32 to 36	35 "	—	—
Fresh meat ..	38	$\frac{1}{4}$ "	—	Per pound.
Veal" ..	38	25 "	—	Per quarter.
Lamb ..	36	25 "	—	Per pound.
Game ..	32 to 36	15 "	—	"
" ..	Below 20	$\frac{1}{2}$ "	15 cents	"
Venison and				
poultry	Below 20	$\frac{1}{2}$ "	—	Per lb. gross.
Ducks, grouse,				
and quail	32 to 35	—	15 "	Per dozen.
Quails ..	Below 20	—	15 "	"
Fish ..	25 to 30	$\frac{1}{2}$ to $\frac{1}{4}$ "	—	—
Storage Room	—	25 dollars and upwards	—	Per 1,000 cubic feet

COLD STORAGE CHARGES.—(*United States.*)*(Compend of Mechanical Refrigeration.)*

GOODS AND QUANTITY.	First Month.	Each Succeeding Month.	In Large Quantities. Per Month.	Season Rate per Barrel of 100 lbs.	Season Ends.
Apples, per bbl.	\$0.15	\$0.12½	\$0.12½	\$0.45	May 1.
Bananas, per bunch	0.15	0.10	0.10	—	—
Beef, Mutton, Pork, and Fresh Meat per lb.	0.00½	0.00½	0.00½	—	—
Beer and Ale, per bbl.	0.25	0.25	—	—	—
Beer and Ale, per ½ bbl.	0.15	0.15	—	—	—
Beer and Ale, per ¼ and ⅛ bbl.	0.10	0.10	—	—	—
Beer, bottled, per case.	0.10	0.10	—	—	—
Beer, bottled, per bbl.	0.20	0.20	—	—	—
Berries, fresh of all kinds, per quart	0.00½	0.00½	0.00½	—	—
Berries, fresh of all kinds, per stand	0.10	—	—	—	—
Butter and Butterine, per lb.	0.00½	0.00¼	0.00½	—	—
Buckwheat Flour, per lb.	0.15	0.12½	0.10	0.50—0.75	Jan. 1. Oct. 1.
Cabbages, per bbl.	0.25	0.25	0.20	0.50	—
Cabbages, per crate	0.10	0.10	0.08	—	—
Calves (per doz.) each	0.10	—	—	—	—
Calves, per lb.	0.00½	0.00½	0.00½	—	—
Canned and Bottled Goods, per lb.	0.00¼	0.00½	0.00½	—	—
Celery, per case	0.15	0.10	0.10	—	—

COLD STORAGE CHARGES.—United States. (Continued.)

GOODS AND QUANTITY.	First Month.	Each Succeeding Month.	In Large Quantities. Per Month.	Season Rate per Barrel of 100 lbs.	Season Ends.
Cheese, per lb. ..	\$0.00½	\$0.00½	\$0.00½	\$0.50—'60	Jan. 1.
Cherries, per quart ..	0.00½	0.00½	0.00½	—	—
Cider, per bbl. ..	0.25	0.15	0.15	—	—
Cigars, per lb. ..	0.00½	0.00½	0.00½	—	—
Cranberries, per bbl. ..	0.25	0.20	0.15	—	—
Cranberries, per case ..	0.10	—	—	—	—
Corn Meal, per bbl. ..	0.15	0.12½	0.10	—	—
Dried and boneless Fish, etc., per lb. ...	0.00 1—5	0.00½	0.00½	0.50	Nov. 1.
Dried Corn, per bbl. ..	0.12½	0.10	0.10	—	—
Dried and evaporated Apples, per lb. ..	0.00½	0.00½	—	0.50	Nov. 1.
Dried Fruit, per lb. ..	0.00 1—6	0.00 1—10	0.00½	0.40—'50	Nov. 1.
Eggs, per case ..	0.15	0.00½	0.10	0.50—'60	Jan. 1.
Figs, per lb. ..	0.00½	0.12½	0.00 1—10	—	—
Fish, per bbl. ..	0.20	0.00½	0.15	0.75	Oct. 1.
Fish, per tierce ..	0.15	0.13	0.12½	0.50	Oct. 1.
Fruits, fresh, per crate. .	0.25	0.20	0.20	—	—
Furs, Undressed, hydraulic	0.10	0.08	0.08	—	—
" Pressed, per lb. ..	0.00½	0.00½	0.00½	1.00	Oct. 1.
" Dressed, per lb. ..	0.03	0.02½	0.02	8.00	Oct. 1.
Ginger Ale, bottled, per bbl. ..	0.20	0.15	0.15	—	—
Grapes, per lb. ..	0.00½	0.00½	0.00½	2.00	May 1.
Grapes, per basket ..	0.03	0.02	0.01	—	—

COLD STORAGE CHARGES.—United States.—(Continued.)

GOODS AND QUANTITY.	First Month.	Each Succeeding Month.	In Large Quantities. Per Month.	Season Rate per Barrel of 100 lbs.	Season Ends.
Grapes, Malaga, etc., per keg..	\$0.15	\$0.12½	\$0.12½	\$ —	—
Hops, per lb. ..	0.00½	0.00½	0.00½	—	—
Lard, per tierce..	0.25	0.20	0.20	1.00	Nov. 1.
Lard Oil, per cask ..	0.25	0.20	0.20	1.00	Nov. 1.
Lemons, per box ..	0.15	0.12½	0.10	0.50	Nov. 1.
Macaroni, per bbl. ..	0.20	0.15	0.12½	—	—
Maple Sugar, per lb. ..	0.00½	0.00½	0.00½	0.40—0.50	Nov. 1.
Maple Syrup, per gallon ..	0.01½	0.01½	0.01	—	—
Meats, fresh, per lb. ..	0.00½	0.00½	0.00½	—	—
Nuts of all kinds, per lb. ..	0.00½	0.00½	0.00½	0.40—0.50	Nov. 1.
Oatmeal, per bbl. ..	0.20	0.15	0.12½	—	—
Oil, per cask ..	0.25	0.20	—	—	—
Oil, per hhd. ..	1.00	0.80	—	—	—
Oleomargarine, per lb..	0.00½	0.00½	0.00½	—	—
Onions, per bbl..	0.15	0.12½	0.10	0.50—0.60	May 1.
Onions, per box..	0.12½	0.10	—	—	—
Oranges, per box ..	0.15	0.12½	0.10	0.50	Nov. 1.
Oysters in tubs, per gal. ..	0.05	0.04	—	—	—
Oysters in shells, per bbl. ..	0.50	0.40	0.30	—	—
Peaches, per basket ..	0.10	0.08	0.07	2.00	Jan. 1.
Pears, per box ..	0.20	0.15	—	0.60	May 1.
Pears, per bbl. ..	0.40	0.30	—	1.20	May 1.

COLD STORAGE CHARGES.—United States.—(Continued.)

GOODS AND QUANTITY.	First Month.	Each Succeeding Month.	In Large Quantities, Per Month.	Season Rate per Barrel of 100 lbs.	Season Ends.
Pigs' Feet, per lb.	\$0.004	\$0.004	\$0.004	\$1.00	Nov. 1.
Pork, per tierce..	0.20	0.15	0.15	—	—
Potatoes, per bbl.	0.25	0.20	0.20	—	—
Preserves, jellies, jams, etc., per lb.	0.004	0.004	0.004	—	—
Provisions, per bbl.	0.25	0.20	0.20	—	—
Rice Flour, per bbl.	0.20	0.15	0.15	—	—
Sauerkraut, per cask	0.25	0.20	0.15	0.60—0.75	Nov. 1.
Sauerkraut, per 1/2-bbl.	0.15	0.12 1/2	0.12 1/2	—	—
Sauerkraut, per 1/3-bbl.	0.30	0.25	0.10	1.00	Oct. 1.
Syrup, per bbl.	0.003	0.004	0.20	—	—
Tobacco, per lb.	0.25	0.20	0.004	—	—
Vegetables, fresh, per bbl.	0.15	0.10	0.15	—	—
Vegetables, fresh, per case	0.25	0.20	0.08	—	—
Wine, in wood, per bbl.	0.10	0.25	—	—	—
Wine, in bottles, per case	0.10	0.10	—	—	—

RATES FOR FREEZING POULTRY, GAME, FISH, MEATS,
BUTTER, EGGS, ETC., UNITED STATES.

The rates for freezing goods, or for storing goods at a freezing temperature when they are already frozen, are as follows :—

POULTRY, GAME, ETC., IN UNBROKEN PACKAGES.

Poultry, including turkeys, fowl, chickens, geese, etc., and rabbits, squirrels, and ducks when picked.

Four rates, A, B, C, and D, for storing poultry, and the rate to be charged will be determined by the amount of such goods as may be frozen and stored during a season of six months, usually from October or November 1st to April or May 1st.

RATE A.—For customers storing fifty or more tons of poultry, the rate to be one-third cent per pound for the first month stored, and one-fourth cent per pound for each month or fraction of a month, including the first month, if stored for more than one month.

RATE B.—For customers storing five or more, but less than fifty tons of poultry, the rate to be one-third cent per pound for the first month stored, and one-fourth cent per pound for each month or fraction of a month thereafter.

RATE C.—For customers storing one or more, but less than five tons of poultry, the rate to be three-eighths cent per pound for the first month stored, and one-fourth cent per pound for each month or fraction of a month thereafter.

RATE D.—For customers storing less than one ton of poultry, the rate to be one-half cent per pound for the first month stored, and three-eighths cent per pound for each month or fraction of a month thereafter.

Venison, etc., and ducks when unpicked, one to one-half cent per pound per month, according to quality and length of time stored.

Grouse and part ridges, three cents to five cents per pair per month. Woodcock, one cent to two cents per pair per month.

Squabs and pigeons, four cents to six cents per dozen

per month. Quail, plover, snipe, etc., three cents to five cents per dozen per month.

When a portion of the goods is removed from a package, storage to be charged for the whole package as it was received, until the balance of the package is removed from the freezer.

For goods received loose, when to be taken out of the packages in which they are received, or when to be laid out, the following rates to be charged :—

Poultry, including turkeys, chickens, geese, etc., and rabbits and squirrels, one-half cent to one-fourth cent per pound extra, according to quality and length of time stored.

Grouse, partridges, woodcock, squabs, pigeons, quail, plover, and snipe, 50 per cent. more than the rates as above specified.

Ducks weighing less than two pounds each, two cents to three cents each per month. Ducks weighing two pounds or more each, three cents to four cents each per month.

For all kinds of poultry and birds not herein specified, the rate from one cent to one-half cent per pound per month, according to quantity and length of time stored.

SUMMER FREEZING RATES.

Freezing rates for the summer months, 50 per cent. more than the specified winter rates for the first month stored, and the same as the winter rates for the second and succeeding months.

STORING UNFROZEN POULTRY, ETC.

For holding poultry, game, etc., which are not frozen, at a temperature which shall be about 30° Fahr., the rate to be one-fifth cent to two-fifths cent per pound according to quantity, for any time not exceeding two weeks.

FREEZING RATES FOR FISH AND MEATS.

Salmon, blue fish, and other fresh fish in packages, one-half cent per pound for the first month stored, three-eighths cent per pound per month thereafter.

Fresh fish of all kinds when to be hung up or laid out, three-fourths cent per pound for the first month stored, one-half cent per pound per month thereafter.

Fish in small quantities, 50 per cent. more than the above rates.

Special rates for large lots of large fish.

Scallops, three-fourths cent per pound, gross, per month.

Sweetbreads, and lamb fries, one cent per pound, gross, per month.

Beef, mutton, lamb, pork, veal, tongues, etc., three-fourths cent to one-half cent per pound, net, for the first month stored, one-fourth cent to three-eighths cent per pound per month thereafter.

BUTTER FREEZING RATES.

For freezing and storing butter in a temperature of 20° Fahr. or lower, the rate to be charged will be determined by the amount of such goods that may be frozen and stored during the season of eight months from April 1st to December 1st, or from May 1st to January 1st. There will be three rates, A, B, and C.

RATE A.—For customers storing thirty-five (35) or more tons of butter, the rate to be fifteen cents per 100 pounds, net, per month.

RATE B.—For customers storing five or more, but less than thirty-five tons of butter, the rate to be eighteen cents per 100 pounds, net, per month.

RATE C.—For customers storing less than five tons of butter, the rate to be twenty-five cents per 100 pounds, net, per month.

EGG FREEZING RATES.

For freezing broken eggs in cans, the charge to be one-half cent per pound, net weight, per month, and for a season of eight months the rate to be one and one-half cents per pound, net weight.

RENT OF ROOMS.

For freezing temperatures, four cents to five cents per cubic foot per month.

TERMS OF PAYMENT OF COLD STORAGE AND
FREEZING RATES.

All the above rates are to be charged for each month, or fraction of a month, unless otherwise specified; and in all cases fractions of months to be charged as full months.

Charges to be computed in all cases when possible upon the marked weights and numbers of all goods at the time they are received.

All storage bills are due and payable upon the delivery of a whole lot, or balance of a lot of goods, or every three months, when goods are stored more than three months.

Unless special instructions regarding insurance accompany each lot of goods, they are held at owner's risk.

COLD STORAGE CHARGES (*France*).*Public Abattoir, Chambéry.*

Rent of cold storage chamber 500 francs (£20) per annum. An ordinary cold storage chamber contains 17 or 18 hooks, each capable of supporting about 100 kilogrammes (220·4 lbs.) of meat, and 17 or 18 S-hooks, each capable of receiving 10 kilogrammes (22·04 lbs.), in small pieces. The weights of the meat suspended from the hooks and S-hooks are never to exceed the above. In all cases where such weights are exceeded the butchers will be held responsible for any damage and breakages which may result.

Where a cold storage chamber is let to a number of persons, the rent to be per hook, at the rate of 40 francs (32 shillings) a year, that is to say, for the time during which the cold store is in operation. The S-hook situated above is included with each hook.

SECTION III.

ICE-MAKING AND STORING ICE.

ICE-MAKING.

ARTIFICIAL ice is either what is known as clear, transparent, or crystal ice, or milky, opaque, or tombstone ice. The latter is generally used where appearance is of no consequence, and cheapness is the main consideration, and it does not necessarily possess any unwholesome qualities, but it has the objection of very considerably reduced keeping powers, and should be used immediately. The opacity of ice is mainly due to rapid freezing preventing the air contained in solution in the water from escaping.

Clear or crystal ice can be made by using distilled or de-aërated water, or by agitation of the water during the freezing process. This latter has been carried out in a number of different ways, of which the most common and practical is the reciprocating movement of agitators or paddles in the ice can or mould, or in the ice-box, accordingly as the can system or the stationary cell system is in use. Many other devices have, however, been used, amongst which may be mentioned the imparting of a rotary motion to the freezer, rods or plungers moving up and down in cans, oscillating rods or agitators, forcing cold air through the freezing water, shaking cans or moulds, removing water and refilling it by pumping, water injection with pressure reduction, taking water from one point of one can and pumping it into another, rotating stirrer or agitator, freezing ice in very cold air, freezing ice very slowly, freezing ice in very thin slabs.

A white core in ice is due to the presence of carbonite of lime and magnesia or other minerals in the water. A red core in ice is due to the separation of oxide of iron in ice which was maintained in solution in the water in the form of carbonate of iron, and the sediment usually comes from

the iron of the plant. Pure distilled, carefully filtered water should be alone used for making ice intended for domestic consumption. The three most used types of ice-making apparatus are those working on the can system, the stationary cell system, and the plate or wall system.

In ice-making, where it is important to secure the maximum production at the minimum cost, it is necessary to work both day and night so as to render the operation a continuous one. Likewise such routine must be followed as will ensure the largest possible output and the best quality. With this purpose in view, great care must be exercised to maintain all the parts of the apparatus perfectly clean, and in first-class working order. A regular and systematic plan of drawing the ice must be settled upon and strictly adhered to, and with this object a distinctive number or letter should be stamped or painted upon each can or mould, and so many drawn regularly per hour.

TABLE GIVING SIZES AND CAPACITIES OF ICE-MAKING PLANTS, ETC.

(H. H. Kelley, "The Engineer," New York.)

Tons *per 24 Hours.	Size of Engine.	Revs.	Size of Com- pressor.	Size of Blocks of Ice.	Gallons of Water per Hour.	Tons of Coal.	No. of Engineers.	No. of Firemen.	No. of Labourers.
1	7 x 9	90	15 x 10	8 x 8 x 28	5	1/2	1	..	..
3	8 x 16	80	5 x 15	8 x 15 x 28	15	1	2	2	2
5	10 x 20	75	6 x 18	8 x 15 x 28	20	1 1/2	2	2	2
10	12 x 30	70	8 x 20	11 x 22 x 28 11 x 11 x 28	30	2	2	2	3
10 1/2	14 x 30	65	8 x 25	11 x 22 x 28 11 x 11 x 28	35	2 1/2	2	2	3
15	14 x 30	65	10 x 20	11 x 22 x 28 11 x 11 x 28	40	3	2	2	4
20	16 x 30	55	10 x 30	11 x 22 x 28 11 x 11 x 28	50	4	2	2	5
30	16 x 42	52	11 x 30	11 x 22 x 28 11 x 11 x 28	60	5	2	2	6
40	18 x 36	50	12 x 30	11 x 11 x 28	90	6 1/2	2	2	7
45	20 x 36	50	15 x 30	11 x 11 x 28	94	8	2	2	8
60	24 x 36	45	16 x 36	11 x 11 x 28	96	10	2	2	9
80	26 x 48	45	20 x 36	11 x 22 x 28	100	13	2	2	10

* 2,000 pounds.

† One cylinder.

PURE WATER.

If properly distilled water, or ice made from such water, be evaporated slowly on a piece of platinum foil over a spirit-lamp or a Bunsen gas-burner, there should be no residuum whatever.

In the manufacture of ice intended for domestic consumption, the use of pure water is a matter of paramount importance, consequently it is well to define what pure water is, and as very much the same requirements that are made by authorities with respect to potable water, also apply to ice, we will give some of the demands made in the former case. Pure water is soft, is transparent, has a certain amount of sparkle, is sufficiently aërated, has no matter held in suspension that is visible, is completely tasteless, and is either entirely colourless or has a slight bluish tint. The requirements of some authorities in the United States in this direction—great care being there exercised—are given by Prof. Siebel as follows: "1. Such water should be clear, temperature not above 15° C. 2. It should contain some air. 3. It should contain in 1,000,000 parts: Not more than 20 parts of organic matter. Not more than 0.1 part of albuminoid ammonias. Not more than 0.5 part of free ammonia. 4. It should contain no nitrates, no sulphuretted hydrogen, and only traces of iron, aluminium, and magnesium. Besides the mentioned substances, it should not contain anything that is precipitable by sulphuretted ammonia. 5. It must not contract any odour in closed vessels. 6. It must contain no saprophites and leptothrix, and no bacteria and infusoria in notable quantities. 7. Addition of sugar must cause no development of fungoid growth. 8. On gelatine it must not generate any liquefying colonies of bacteria."

SIMPLE RULES FOR ASCERTAINING THE QUALITY OF SO-CALLED MINERAL WATER.—(*Frick Company.*)

Water turning blue litmus paper red before boiling, which after boiling will not do so; and if the blue colour can be restored by warming, then it is carbonated (containing carbonic acid).

If it has a sickening odour, giving a black precipitate

with acetate of lead, it is sulphurous (containing sulphuretted hydrogen).

If it gives a blue precipitate with yellow or red prussiate of potash by adding a few drops of hydrochloric or muriatic acid, it is chalybeate (carbonate of iron).

If it restores blue colour to litmus paper after boiling, it is alkaline.

If it has none of the above properties in a marked degree and leaves a large residue after boiling, it is a saline water (containing salts).

TESTING BY REAGENTS.

If water becomes turbid or opaque by using the following reagents, it is not pure:—

With baryta water, indicating carbonic acid.

With chloride of barium, indicates sulphate.

With nitrate of silver, indicates chloride.

With oxalate of ammonia, indicates lime salts.

With sulphide of hydrogen, slightly acid, indicates presence of antimony, arsenic, tin, copper, gold, platinum, mercury, silver, lead, bismuth, and cadmium.

With sulphide of ammonia, alkaloid by ammonia, indicates nickel, cobalt, manganese, iron, zinc, alumina, and chromium.

With chloride of mercury or gold and sulphate of zinc, indicates organic matter.

FREEZING TANK OR BOX.

These are constructed of sheet iron and steel, and also of wood and cement. The amount of pipe required is about 250 feet of 2-inch pipe, or 350 feet of $1\frac{1}{4}$ -inch pipe, or their equivalent per ton of ice per twenty-four hours, in accordance with the temperature of the brine and the capacity of the machine. Less pipe than the above, says Prof. Siebel, is employed in the United States, even as low as 150 feet of 2-inch pipe, and 200 feet of $1\frac{1}{4}$ -inch pipe per ton of ice-making capacity (in twenty-four hours), but in that case the back pressure must be carried excessively low, which duly increases the consumption of coal and the wear and tear of the machinery.

The freezing tank may be cooled on either the indirect or the direct expansion system.

The size and length of pipe in the brine tank, it is recommended by the above-mentioned authority, should be arranged in such a manner that each row of moulds or cans is passed by an ammonia pipe on each side, preferably on the wide side of the mould or can. The series of pipes in the ice tank or box are connected by a manifold, the liquid ammonia entering the manifold at the lower extremity, and the vapour leaving by the suction manifold placed at the higher extremity of the refrigerating coils.

When working with the wet vapour of ammonia, the liquid must be admitted at the upper extremity of the refrigerating coils, and be drawn off to the compressor at their lower extremity.

BRINE FOR USE IN REFRIGERATING AND ICE-MAKING PLANTS.

A brine suitable for the above purpose can be made with from 3 to 5 lbs. of chloride of calcium, or muriate of lime, in accordance with its degree of purity, dissolved in each gallon of water. The density of this solution is about 23° Beaumé, its weight about $13\frac{1}{2}$ lbs. per gallon, and the freezing-point is -9° Fahr. As the above standard of density must be kept up, in order to prevent the brine from becoming congealed in the refrigerator, or the ice-making tanks or boxes, it is desirable to test it periodically with a salinometer.

In the best American practice first quality medium ground salt, preferably in bags for convenience of handling, is employed, the proportions being about 3 lbs. of salt to each gallon of water. The brine is made in a brine mixer, consisting of a water-tight box or tank about 4 ft. $\times$ 8 ft. $\times$ 2 ft., having a suitably perforated false bottom, and a small compartment, partitioned off at one extremity, communicating with the main compartment through an overflow situated at the upper end of the partition, and fitted with a large strainer, to prevent the passage into the small compartment of salt or foreign bodies. The water is admitted through a perforated pipe situated beneath, and running the full length of the false bottom, and the brine is removed through a pipe from the

upper part of the end compartment, at the lower extremity of which latter pipe is a strainer-box and strainer through which the brine passes before delivery into the brine-tank. A salt gauge, salinometer, or hydrometer is also placed in the small or end compartment.

The salt should be dissolved in the water until it reaches a density of about 90° by the hydrometer. To facilitate dissolution it is desirable to stir the salt in the mixer with some handy implement, the salt being shovelled in as fast as it can be got to dissolve.

By the use of this mixture the settlement of salt on the bottom, and on the coils in the brine tank, which inevitably results when the dissolution is effected directly in the latter, is avoided.

To maintain the strength of the brine it is recommended to suspend bags filled with the salt in the brine tank, or to pass the return brine through the above-described brine maker or mixer.

A cheap and easily constructed apparatus for mixing brine can be made out of an old barrel in which a perforated false bottom is fixed a short distance above the bottom, the water to form the solution being delivered to the space between the two bottoms, and an overflow pipe fitted with a suitable strainer and a well to receive a salinometer being provided near the top to draw off the brine.

SOLUTIONS OF CHLORIDE OF CALCIUM (CaCl_2).

(Manufacturer of Chloride of Calcium, U.S.)

Specific Gravity at 64° Fahr.	Degree Beaumé at 64° Fahr.	Degree Salinometer at 64° Fahr.	Per cent. of Chloride of Calcium.	Freezing-point Degrees Fahr.	Ammonia Gauge. Lbs. per square inch at Freezing-point.
1.007	1	4	0.943	+31.20	46
1.014	2	8	1.886	+30.40	45
1.021	3	12	2.829	+29.60	44
1.028	4	16	3.772	+28.80	43
1.035	5	20	4.715	+28.00	42
1.043	6	24	5.658	+26.89	41
1.050	7	28	6.601	+25.78	40
1.058	8	32	7.544	+24.67	38
1.065	9	34	8.487	+23.56	37
1.073	10	40	9.430	+22.09	35.5

SOLUTIONS OF CHLORIDE OF CALCIUM (CaCl_2).*(Manufacturer of Chloride of Calcium, U.S.)*

Specific Gravity at 64° Fahr.	Degree Beaumé at 64° Fahr.	Degree Salinometer at 64° Fahr.	Per cent. of Chloride of Calcium.	Freezing-point Degrees Fahr.	Ammonia Gauge, Lbs. per square inch at Freezing-point.
1·081	11	44	10·373	+20·62	34
1·089	12	48	11·316	+19·14	32·5
1·097	13	52	12·259	+17·67	30·5
1·105	14	56	13·202	+15·75	29
1·114	15	60	14·145	+13·82	27
1·112	16	64	15·088	+11·89	25
1·131	17	68	16·031	+9·96	23·5
1·140	18	72	16·974	+7·68	21·5
1·149	19	76	17·917	+5·40	20
1·158	20	80	18·860	+3·12	18
1·167	21	84	19·803	-0·84	15
1·176	22	88	20·746	-4·44	12·5
1·186	23	92	21·689	-8·03	10·5
1·196	24	96	22·632	-11·63	8
1·205	25	100	23·575	-15·23	6
1·215	26	104	24·518	-19·56	4
1·225	27	108	25·461	-24·43	1·5
1·236	28	112	26·404	-29·29	1 ⁶⁶ vacuum
1·246	29	116	27·347	-35·30	5 ⁶⁶
1·257	30	120	28·290	-41·32	8·5 ⁶⁶
1·268	31	—	29·233	-47·66	12 ⁶⁶
1·279	32	—	30·176	-54·00	15 ⁶⁶
1·290	33	—	31·119	-44·32	10 ⁶⁶
1·302	34	—	32·062	-34·66	4 ⁶⁶
1·313	35	—	33·000	-25·00	1·5 lbs.

PROPERTIES OF SOLUTION OF CHLORIDE OF CALCIUM.

(Prof. Siebel, "Compend. of Mechanical Refrigeration.")

Percentage by Weight.	Specific Heat.	Specific Gravity at 60° Fahr.	Freezing-point Degrees Fahr.	Freezing-point Degrees Cels.
1	0·996	1·009	31	-0·5
5	0·964	1·043	27·5	-2·5
10	0·896	1·087	22	-5·6
15	0·860	1·134	15	-9·6
20	0·834	1·182	5	-14·8
25	0·790	1·234	-8	-22·1

PROPERTIES OF SOLUTION OF CHLORIDE OF CALCIUM (CaCl_2).
(H. J. West & Co., Ltd., "Catalogue of Ice-Making and Refrigerating Machinery.")

Degrees on Various Scales.			Specific Gravity at 60° Fahr. Water=1.	Percentage of CaCl_2 by Weight.	Weight of 1 Gal. of Solution.			Freezing Temp.	
Salinometer.	Beaumé.	Twaddell.			Water, lbs.	CaCl_2 , lbs.	Total lbs.	Fahr.	Celsius.
24	6	9	1.043	5	9.908	0.521	10.43	27.5°	-2.5°
47	12	17	1.087	10	9.783	1.087	10.87	22.0°	-5.6°
68	17	27	1.134	15	9.639	1.701	11.34	15.0°	-9.6°
92	23	36	1.182	20	9.456	2.364	11.82	5.0°	-14.8°
112	28	46	1.234	25	9.255	3.085	12.34	-8.0°	-22.1°

PROPERTIES OF SOLUTION OF CHLORIDE OF SODIUM (COMMON SALT).

Degrees on Various Scales.			Specific Gravity at 60° Fahr. Water=1.	Percentage of NaCl by Weight.	Weight of 1 Gal. of Solution.			Freezing Temp.	
Salinometer.	Beaumé.	Twaddell.			Water, lbs.	Salt, lbs.	Total lbs.	Fahr.	Celsius.
20	5	7	1.037	5	9.851	0.518	10.37	25.2°	-3.8°
40	10	15	1.073	10	9.657	1.073	10.73	18.7°	-7.4°
60	15	23	1.115	15	9.475	1.672	11.15	12.2°	-11.0°
80	19	30	1.150	20	9.200	2.300	11.50	6.1°	-14.4°
100	24	38	1.191	25	8.923	2.977	11.91	0.5°	-17.8°

COMPARISON OF VARIOUS HYDROMETER SCALES.—(*Varyan.*)

Degrees Baumé.	Specific Gravities.		Degrees Densimetric 15° C.	Degrees Twaddell 60 Fahr. 1° = 200 (Sp. gr. - 1).	Degrees Brix. Official Prussian Hydrometer 15° C. Sp. gr. = $\frac{400}{400 - Bx^{\circ}}$	Degrees Beck 12° C. Sp. gr. = $\frac{170}{170 - Bk^{\circ}}$	Degrees Brix Saccharimetric (per cent. Sugar).	Gay-Lussac (Centigrade). Sp. gr. = $\frac{100}{100 - C^{\circ}}$
	Standard adopted by U.S. Chem. Mfg. Ass. 15° C. Sp. gr. = 145°04 - B	Modulus 144°38. Custom in France.						
0	1'000	1'0000	0'0	0'0	0'0	0'0	0'0	0'0
1	1'007	1'0070	0'7	1'4	2'8	1'2	1'8	0'4
2	1'014	1'0140	1'4	2'8	5'5	2'3	3'6	1'4
3	1'021	1'0215	2'1	4'2	8'2	3'5	5'4	2'1
4	1'028	1'0285	2'8	5'6	10'9	4'6	7'1	2'7
5	1'036	1'0380	3'6	7'2	13'9	5'9	9'0	3'5
6	1'043	1'0435	4'3	8'6	16'5	7'0	10'7	4'1
7	1'051	1'0510	5'1	10'2	19'4	8'3	12'6	4'8
8	1'058	1'0585	5'8	11'6	21'9	9'3	14'3	5'5
9	1'066	1'0665	6'6	13'2	24'8	10'4	16'1	6'2
10	1'074	1'0745	7'4	14'8	27'5	11'7	18'0	6'9
11	1'082	1'0825	8'2	16'4	30'3	12'9	19'8	7'6
12	1'090	1'0905	9'0	18'0	33'0	14'1	21'5	8'3
13	1'098	1'0990	9'8	19'6	36'0	15'2	23'3	8'9
14	1'107	1'1075	10'7	21'4	39'0	16'4	25'2	9'7
15	1'115	1'1160	11'5	23'0	41'3	17'6	27'0	10'3
16	1'124	1'1245	12'4	24'8	44'2	18'8	28'9	11'0
17	1'133	1'1335	13'3	26'6	46'5	20'0	30'7	11'7
18	1'142	1'1425	14'2	28'4	49'7	21'2	32'6	12'4
19	1'151	1'1515	15'1	30'2	52'5	22'3	34'4	13'1
20	1'160	1'1607	16'0	32'0	55'2	23'5	36'2	13'8
21	1'169	1'1705	16'9	33'8	57'8	24'6	38'0	14'5
22	1'179	1'1795	17'9	35'8	60'7	25'8	40'0	15'2
23	1'188	1'1895	18'8	37'6	63'3	26'9	41'7	15'8
24	1'198	1'1995	19'8	39'6	66'1	28'1	43'6	16'5
25	1'208	1'2095	20'8	41'6	68'9	29'3	45'5	17'2
26	1'218	1'2195	21'8	43'6	71'6	30'4	47'3	17'9
27	1'229	1'2300	22'9	45'8	74'5	31'7	49'4	18'6
28	1'239	1'2405	23'9	47'8	77'2	32'8	51'2	19'3
29	1'250	1'2515	25'0	50'0	79'3	34'0	53'2	20'0
30	1'261	1'2625	26'1	52'2	82'8	35'2	55'1	20'7
31	1'272	1'2735	27'2	54'4	85'5	36'4	57'0	21'4
32	1'283	1'2850	28'3	56'6	88'3	37'5	58'9	22'1
33	1'295	1'2960	29'5	59'0	91'1	38'8	60'9	22'8
34	1'306	1'3080	30'6	61'2	93'7	39'9	62'7	23'4
35	1'318	1'3200	31'8	63'6	96'5	41'0	64'7	24'1

COMPARISON OF VARIOUS HYDROMETER SCALES.—(Continued.)

Degrees Baumé.	Specific Gravities.		Degrees Densimetric 15° C.	Degrees Twaddell 60 Fahr. 1° = 200 (Sp. gr.—1).	Degrees Brix, Official Prussian Hydrometer 15° C. $\frac{400}{100} = 400 - Bx^{\circ}$	Degrees Beck 12½° C. $Sp. gr. = \frac{170}{170 - Bk^{\circ}}$	Degrees Brix Saccharimetric (per cent. Sugar).	Gay-Lussac (Centigrade). $Sp. gr. = \frac{100}{100 - C^{\circ}}$
	Standard adopted by U.S. Chem. Mfg. Ass. 15°. $Sp. gr. = \frac{145.04}{145.04 - B}$	Modulus 144.38. Custom in France.						
36	1.330	1.3320	33.0	66.0	99.2	42.2	66.7	24.8
37	1.342	1.3445	34.2	68.4	101.9	43.3	68.6	25.5
38	1.355	1.3570	35.5	71.0	104.7	44.6	70.7	26.2
39	1.368	1.3700	36.8	73.6	107.6	45.8	72.7	26.9
40	1.381	1.3830	38.1	76.2	110.3	46.9	74.7	27.6
41	1.394	1.3955	39.4	78.8	113.5	48.0	76.7	28.3
42	1.408	1.4100	40.8	81.6	115.9	49.3	78.8	28.9
43	1.421	1.4240	42.1	84.2	118.5	50.4	80.8	29.6
44	1.436	1.4380	43.5	87.0	121.3	51.5	82.9	30.3
45	1.450	1.4525	45.0	90.0	124.1	52.8	85.1	31.0
46	1.465	1.4675	46.5	93.0	126.7	53.9	87.2	31.7
47	1.479	1.4827	48.0	96.0	129.7	55.1	89.4	32.4
48	1.495	1.4980	49.5	99.0	132.4	56.3	91.5	33.1
49	1.510	1.5135	51.0	102.0	135.1	57.4	93.6	33.8
50	1.526	1.5300	52.6	105.2	137.9	58.6	..	34.5
51	1.542	1.5460	54.2	108.4	140.6	59.8	..	35.2
52	1.559	1.5630	55.9	111.8	143.4	61.0	..	35.9
53	1.576	1.5800	57.6	115.2	146.2	62.2	..	36.6
54	1.593	1.5965	59.3	118.6	148.9	63.3	..	37.2
55	1.611	1.6150	61.1	122.2	151.7	64.5	..	37.9
56	1.629	1.6335	62.9	125.8	154.5	65.7	..	38.6
57	1.648	1.6520	64.8	129.6	157.3	66.9	..	39.3
58	1.666	1.6715	66.7	133.4	160.0	68.0	..	40.1
59	1.686	1.6910	68.6	137.2	162.8	69.2	..	40.7
60	1.706	1.7110	70.6	141.2	165.5	70.4	..	41.4
61	1.726	1.7315	72.6	145.2	168.3	71.5	..	42.1
62	1.747	1.7525	74.7	149.4	171.0	72.7	..	42.8
63	1.768	1.7740	76.8	153.6	173.8	73.8	..	43.4
64	1.790	1.7950	79.0	158.0	176.5	75.0	..	44.1
65	1.812	1.8185	81.2	162.4	179.3	76.2	..	44.8
66	1.835	1.8420	83.5	167.0	182.0	77.4	..	45.5
67	1.859	1.8660	85.9	171.8	184.8	78.6	..	46.2
68	1.883	1.8910	88.3	176.6	187.5	79.7	..	46.9
69	1.907	1.9151	90.7	181.4	190.2	80.9	..	47.6
70	1.933	1.9410	93.3	186.6	193.0	82.1	..	48.3
72.5	2.000	2.0085	100.0	200.0	200.0	85.0	..	50.0

FREEZING TIMES FOR DIFFERENT TEMPERATURES AND THICKNESSES OF CAN ICE.

(Siebert.)

Thickness.	1 in.	2 in.	3 in.	4 in.	5 in.	6 in.	7 in.	8 in.	9 in.	10 in.	11 in.	12 in.
Temperature 10°	0'32	1'28	2'86	5'10	8'00	11'5	15'6	20'4	25'8	31'8	38'5	45'8
" 12°	0'35	1'40	3'15	5'60	8'75	12'6	17'3	22'4	28'4	35'0	42'3	50'4
" 14°	0'39	1'56	3'50	6'22	9'70	14'0	19'0	25'0	31'5	39'0	47'0	56'0
" 16°	0'44	1'75	3'94	7'00	11'0	15'8	21'5	28'0	35'5	43'7	53'0	63'0
" 18°	0'50	2'00	4'50	8'00	12'5	18'0	24'5	32'0	40'5	50'0	60'5	72'0
" 20°	0'58	2'32	5'25	9'30	14'6	21'0	28'5	37'3	47'2	58'3	70'5	84'0
" 22°	0'70	2'80	6'30	11'2	17'5	25'2	34'3	44'8	56'7	70'0	84'7	100'0
" 24°	0'88	3'50	7'86	14'0	21'0	31'5	42'8	56'0	71'0	87'5	106'0	126'0

TIME REQUIRED FOR WATER TO FREEZE IN ICE CANS.

(The Triumph Ice Machine Company, Catalogue.)

Cans, size, 6 in. by 12 in. by 24 in. Weight of cake, 50 lbs. Time to freeze, 20 hours.

Cans, size, 8 in. by 18 in. by 32 in. Weight of cake, 100 lbs. Time to freeze, 36 hours.

Cans, size, 8 in. by 16 in. by 40 in. Weight of cake, 150 lbs. Time to freeze, 36 hours.

Cans, size, 11 in. by 22 in. by 32 in. Weight of cake, 200 lbs. Time to freeze, 55 hours.

Cans, size, 11 in. by 22 in. by 44 in. Weight of cake, 300 lbs. Time to freeze, 60 hours.

Cans, size, 11 in. by 22 in. by 57 in. Weight of cake, 400 lbs. Time to freeze, 60 hours.

NOTE.—Temperature of bath 14 to 18 degrees Fahrenheit. As a rule, the higher the bath temperature the slower the process of freezing, but the finer and clearer the ice.

STORING ICE.

For storing purposes ice should be clear, solid, and devoid of core. In America some persons insist that ice for storage should not be made at temperatures higher than 10° to 14° in brine tank.

The first requisite for a storage house for artificial ice, as also for natural ice, is of course the best possible insulation; other necessary points to be attended to are drainage and ventilation. The best shape for an ice storage house is square, or as nearly approaching this form

as possible, and the roof should have a good pitch. An ante-room or lobby is also desirable, as by the provision of this latter the necessity for the frequent opening of the main store is done away with.

To preserve the ice, the storage rooms as well as the ante-chambers or lobbies must be refrigerated, and the amount of the latter required may be roughly estimated, according to Prof. Siebel, at from about ten to sixteen British thermal units of refrigeration per cubic feet contents for twenty-four hours. About one foot of 2-inch pipe (or its equivalent in other size pipe) per fourteen to twenty cubic feet of space is frequently allowed, says the same gentleman, in ice storage houses for direct expansion, and about one-half to one-third more for brine circulation. The pipes should be located on the ceiling of the ice storage house.

The ventilation of an ice storage house should be carefully attended to, and ventilators fitted with suitable regulators should be provided both in the highest part of the roof and also in the gable ends. The drainage should be such as to absolutely prevent the accumulation of any moisture beneath the bed of ice. It is recommended to paint an ice store white, preferably with a mineral paint such as barytes, or patent white.

Respecting the best method to adopt for packing the ice in the store, considerable diversity of opinion seems to exist. It is well to provide a bed of from eighteen inches to two feet of cinders, as this tends to improve the drainage of the house. In one method the blocks are placed on edge and as closely packed together as possible, the blocks in each succeeding layer being placed exactly over those beneath and all breaking of joints being avoided. The ice is covered between the times of storing with dry sawdust or soft wood shavings, and the uppermost layer is invariably covered with dry sawdust or shavings.

Mr. R. Thompson, writing to the *Canadian Farming World*, says that in filling the house he puts the ice on edge, placing every alternate layer crossways, which plan, he claims, enables ice to keep better and come out easier.

Others recommend that the ice be stored with alternate ends touching, and alternately from one and a half to two

inches apart, so as to prevent the ice from freezing together. The cakes or slabs of ice should not be parallel to each other, and storage should only be made when the temperature is at or below freezing. Or, again, $\frac{1}{2}$ -inch strips placed between the layers of ice in the store so as to separate the cakes or blocks top, side, and bottom, from all others in the house.

For packing the ice, sawdust, rice chaff, straw, hay—marsh or prairie hay being said to be preferable—are employed, the latter materials being the best, and rice chaff being capable of being dried and re-used. Six inches of well-packed hay should be placed between the ice and the walls, and no covering until the store is full.

A cubic foot of ice is taken to weigh 57.5 lbs. approximately at 32° Fahr. A cubic foot of water frozen at 32° will make 1.0855 cubic foot of ice, thus showing an expansion of 8.5 per cent. due to freezing. A cubic foot of pure water at 39° Fahr., its point of greatest density, weighs 62.43 lbs. Fifty cubic feet of ice, as usually stored, equals about one American or short ton of ice (2000 lbs.), or 62 cubic feet one English ton. In small ice houses, in which the ice is closely packed, a short ton of ice can be got into from 40 to 45 cubic feet.

When withdrawing ice from a store, breaking out bars for bottom and side breaking are required, and if properly skilled assistance is not available a considerable amount of the ice will in all probability be broken up and wasted.

The wastage of ice in an ice store not artificially cooled from January to July is, in the United States, at the rate of about 0.1 lb. of ice per twenty-four hours for each square foot of wall surface, or say from 5 to 10 per cent. of the ice stored during the six months.

The amount of heat that will pass through a square foot of ice one inch in thickness is put at 10 British thermal units per hour for each degree Fahrenheit difference between the respective temperatures on each side of the sheet of ice.

In handling and selling ice, the waggon should be clean and sanitary, the men in charge should avoid walking about in them with dirty boots, and blocks of ice should not be deposited and slid about on filthy pavements. These

matters are attended to in the United States, but here they are totally neglected.

In the United States the selling and delivery of ice is generally done by the coupon system, which is thus described by Prof. Siebel: "It is a system of keeping an accurate account with each customer of the delivery of and the payment for ice by means of a small book containing coupons, which in the aggregate equal 500 or 1000 or more pounds of ice taken by the customer every time ice is delivered. These books are used in the delivery of ice in like manner as mileage books or tickets are used on the railroad. A certain number of coupons are printed on each page, each coupon being separated from the others by perforation, so that they are easily detached and taken up by the driver, when ice is delivered. Such books are each supplied with a receipt or due bill, so that if the customer purchases his ice on credit, all that is necessary for the dealer to do is to have the customer sign the receipt or due bill and hand him the book containing coupons equal in the aggregate to the number of pounds of ice set forth in the receipt or due bill. The dealer then has the receipt or due bill, and the customer has the book of coupons. The only entry which the dealer has to enter against such purchaser in his books is to charge him with coupon book number, as per number on book, to the amount of 500, 1000, or more pounds of ice, as the value of the book so delivered may be. The driver then takes up the coupons as he delivers the ice from day to day."

SECTION IV.

INSULATION.

IN addition to non-conducting qualities, a good insulating material should be non-odorous, non-hygroscopic, not liable to silt, and both vermin and fire-proof.

Perfect insulation would be attained when there was absolutely no transmission of heat through the walls of the building, which state of things is practically an impossibility. Every one should, however, endeavour to secure as near an approximation to the above as possible, and it should be remembered that poor insulation is a constant drain upon the machinery and pocket of the owner, as a very large percentage of the actual work of a refrigerating machine is that required to make up for the transfer of heat through the walls, floor, and ceiling of the cold store, resulting from defective insulation.

In the following tables the results of a number of tests as to the values of different insulating materials are given, and from these tables may be deduced sufficient information to enable an intelligent choice to be made. In Australia pumice stone is much used, and is said to give good results. In this country and the United States silicate cotton or slag-wool; cork, in slabs, bricks, and granulated; and charcoal are employed, and there is something to be said in favour of each of these materials.

When charcoal is employed it should be well dried, and packed as nearly as possible to a consistency of 11 lbs. per cubic foot. Silicate cotton or slag-wool is usually packed to a consistency of about 12 lbs. per cubic foot, one ton equalling about 187 cubic feet. Some engineers prefer, however, to use 13 lbs. per cubic foot.

An advantage possessed by granulated cork is its extreme lightness. One cubic foot weighs only $4\frac{1}{2}$ lbs., and one ton occupies about 450 cubic feet.

TRANSMISSION OF HEAT THROUGH VARIOUS INSULATING STRUCTURES.—(*Starr, American Warehousemen's Assoc.*)

Col. I. gives B.T.U. per square foot per day per degree of difference of temperature. Col. II. gives meltage of ice in pounds per day by heat coming through 100 square feet at a difference of 40°.

	Col. I.	Col. II.
One $\frac{7}{8}$ -in. board, $2\frac{1}{2}$ -in. mineral wool, paper, one $\frac{7}{8}$ -in. board	3·62	101·9
Two $\frac{7}{8}$ -in. double boards and two papers, 1-in. hair-felt	3·318	93·4
Two $\frac{7}{8}$ -in. boards and paper, 1-in. sheet cork, two $\frac{7}{8}$ -in. boards and paper	3·30	92·9
One $\frac{7}{8}$ -in. board, paper, 2-in. calcined pumice, paper, and $\frac{7}{8}$ -in. board	3·38	95·2
One $\frac{7}{8}$ -in. board, paper, 3-in. sheet cork, paper, one $\frac{7}{8}$ -in. board	2·10	60·0
Double boards and papers, 4-in. granulated cork, double boards and paper	1·70	48·0

RESULTS OF TESTS TO DETERMINE THE NON-CONDUCTIVE VALUES OF DIFFERENT MATERIALS.

(*H. F. Donaldson, M.I.C.E., Proceedings, Inst. C.E.*)

EXPERIMENT NO. 1.

—	Thickness of Insulating Material.	Original Weight of Ice.	Weight after		Loss after Seventy-two Hours.
			Twenty-four Hours.	Seventy-two Hours.	
	Inches.	Ozs.	Ozs.	Ozs.	Per cent.
Peat (compressed and set in Fossil Meal)	9	95	81	59	37·89
Charcoal	11	96 $\frac{1}{2}$	79 $\frac{1}{2}$	56	41·97
Silicate Cotton ..	4 $\frac{1}{2}$	92 $\frac{1}{2}$	73 $\frac{1}{2}$	40 $\frac{1}{2}$	56·21
Magnesia and Asbestos Fibre ..	4 $\frac{1}{2}$	93	73	40 $\frac{1}{2}$	56·45

NOTE.—The author thought it undesirable to consider further compressed peat set in fossil meal, as he found by experiment its powers of absorption of moisture to be so great as to constitute in his opinion a source of danger.

EXPERIMENT No. 2.

—	Thickness of Insulating Material.	Original Weight of Ice.	Weight after			Loss after Ninety- six Hours.
			Twenty- four Hours	Forty- eight Hours.	Ninety- six Hours.	
	Inches.	Ozs.	Ozs.	Ozs.	Ozs.	Per cent.
Silicate Cotton	6	104	88½	76½	58½	43·75
Sawdust ..	9	103½	86½	71	48	52·62
Peat	9	104	77½	56	26½	74·75
Charcoal ..	9	104	88½	78½	60½	41·82

EXPERIMENT No. 3.

—	Thickness of Insulating Material.	Original Weight of Ice.	Weight after		Loss after Seventy- two Hours.
			Twenty- four Hours.	Seventy- two Hours.	
	Inches.	Ozs.	Ozs.	Ozs.	Per cent.
Silicate Cotton ..	9	92	83½	72½	21·19
Charcoal	11	92	82½	70½	23·36

EXPERIMENT No. 4.

—	Thickness of Insulating Material.	Original Weight of Ice.	Weight after		Loss after Ninety- six Hours.
			Twenty- four Hours.	Ninety- six Hours.	
	Inches.	Ozs.	Ozs.	Ozs.	Per cent.
Silicate Cotton (loosely packed)	9	110	103	84½	23·41
Silicate Cotton ..	9	110	101½	80½	26·59
Charcoal	11	110	100½	79	28·18
Vegetable Silica ..	11	110	101½	76½	30·22
Diatomite	11	110	99	73½	32·95

RESULTS OF TESTS TO DETERMINE THE NON-CONDUCTIVE VALUES OF VARIOUS MATERIALS.

(Dr. Wm. Wallace.)

MATERIALS.	Cubic Centimetres (grammes) of water melted in 12 days.	Average c.c.'s per day.
Silicate Cotton	9,470	789
Flake Charcoal	11,010	917
Felt	11,760	980
Fossil Meal	12,530	1,044
Twig Charcoal	13,590	1,132
Plain Cork Slabs	14,020	1,168
Tarred Cork Slabs	14,610	1,217
Broken Lump Charcoal	15,916	1,326
Ashes	23,316	1,943

Coleman's method was used in making the above tests, with walls 6 in. thick.

RATE OF PASSAGE OF HEAT THROUGH VARIOUS MATERIALS.—(Alex. Marcet.)

British Thermal Units per hour per superficial foot through materials 6 in. thick.						
	T = 60°		T = 50°		T = 40°	
	Dry.	Wet.	Dry.	Wet.	Dry.	Wet.
Silicate Cotton ..	4.11	14.05	2.34	8.57	1.17	6.70
Cow Hair ..	4.11	8.80	2.34	5.30	1.17	3.50
Charcoal ..	4.70	12.30	2.93	7.50	1.76	4.40
Sawdust ..	6.75	15.60	4.40	9.60	2.34	5.50
Infusorial Earth ..	10.00	—	6.18	—	3.57	—
Cork Bricks ..	5.87	—	3.20	—	2.90	—

T = The Difference of Temperature (Fahr.) on the two sides of the material.

RESULTS OF TESTS ON THE HEAT CONDUCTIVITY OF DIFFERENT SUBSTANCES.

(Various authorities.)

(Silicate Cotton being taken at 100.)

SUBSTANCE.	C. E. Emery, 1881.	J. J. Cole- man, 1884.	W. H. Collins, 1891.	Prof. Jamieson 1894.
Silicate Cotton or Slag Wool ..	100	100	100	100
Hair-Felt or Fibrous Composition	—	117	114	112
Papier-Maché	—	—	147	111
Kieselguhr Composition	—	136	—	112
Sawdust	122	163	142	—
Charcoal	132	140	—	—
Cotton Wool	—	122	—	—
Sheep's Wool	—	136	—	—
Pine Wood (across the grain) ..	150	—	—	—
Loam	—	—	—	—
Gasworks Breeze or Coal Ashes ..	240	230	299	—
Asbestos	229	—	179	—

TABLE GIVING THE RELATIVE HEAT CONDUCTIVITY OF VARIOUS BOILER-COVERING MATERIALS.

(The "American Engineer.")

Silicate Cotton or Mineral Wool	100
Hair Felt	117
Cotton Wool	122
Sheep's Wool	136
Infusorial Earth	136
Charcoal	140
Sawdust	163
Gasworks Breeze	230
Wood and air space	280

RESULTS OF EXPERIMENTS REGARDING NON HEAT-CONDUCTING PROPERTIES OF VARIOUS SUBSTANCES.—
(*Prof. J. M. Ordway.*)

Coverings 1 inch thick.						Pounds of Water heated 10° F. per hour by 1 sq. foot.
*	1	"Silicate Cotton" or "Slag Wool"	..	..	..	13.0
	2	Paper	..	..	..	14.0
	3	Cork Strips, bound on	..	..	..	14.6
	4	Straw Rope, wound spirally	..	..	..	18.0
	5	Loose Rice Chaff	..	..	..	18.7
	6	Blotting Paper, wound tight	..	..	..	21.0
†	7	Paste of Fossil Meal and Hair	..	..	..	16.7
	8	Loose Bituminous Coal Ashes	..	..	..	21.0
	9	Paste of Fossil Meal with Asbestos	..	..	..	22.0
	10	Loose Anthracite Coal Ashes	..	..	..	27.0
	11	Paste of Clay and Vegetable Fibre	..	..	..	30.9
	12	Dry Plaster of Paris	..	..	..	30.9
	13	Asbestos Paper, wound tight	..	..	..	21.7
	14	Air alone	..	..	..	48.0
	15	Fine Asbestos	..	..	..	49.0
	16	Sand	..	..	..	2.16

* These substances are not well suited for covering heated surfaces—owing to their nature they soon become carbonised.

† Hard substances that, with the action of the heat, break, powder, and fall off.

N.B.—The Asbestos of 15 had smooth fibres, which could not prevent the air from moving about. Later trials with an Asbestos of exceedingly fine fibre have made a somewhat better showing, but Asbestos is really one of the poorest non-conductors. By reason of its fibrous character it may be used advantageously to hold together other incombustible substances, but the less the better.

NON HEAT-CONDUCTING PROPERTIES OF VARIOUS SUBSTANCES.—(*From "Engineering."*)

Prepared Mixtures, for Covering Boilers, Pipes, &c.	Pounds of Water heated 10° Fahr. per hour, per square foot.
Slag Wool (Silicate Cotton) and Hair Paste ..	10.0 lbs.
Fossil Meal and Hair Paste	10.4 "
Paper Pulp alone	14.7 "
Asbestos Fibre, wrapped tightly	17.9 "
Fossil Meal and Asbestos Powder	26.3 "
Coal Ashes and Clay Paste, wrapped with Straw..	29.9 "
Clay, Dung, and Vegetable Fibre Paste	39.6 "
Paper Pulp, Clay and Vegetable Fibre	44.6 "

RESULTS OF EXPERIMENTS REGARDING NON HEAT-CONDUCTING PROPERTIES OF VARIOUS SUBSTANCES.

(Walter Jones, "Heating by Hot Water.")

Frame Filled with	Left for	Highest Temp. Registered.
Leroy's Boiler-covering Composition ..	3 hours	94°
Asbestos Powder	4 "	86°
Hair Felt	9 "	77°
Silicate Cotton	9 "	76°

HEAT IN UNITS TRANSMITTED PER SQUARE FOOT PER HOUR THROUGH VARIOUS SUBSTANCES.

(Peclet.)

Materials.	Units of heat transmitted.	Materials.	Units of heat transmitted.
Gold	625	Guttapercha	1·37
Platinum	600	India-rubber	1·36
Silver	595	Brickdust, sifted	1·33
Copper	520	Coke, in powder	1·29
Iron	230	Iron filings	1·26
Zinc	225	Cork	1·15
Tin	178	Chalk, in powder	0·86
Lead	113	Charcoal (wood) in powder	0·63
Marble	24	Straw, chopped	0·56
Stone	14	Coal, powder sifted	0·54
Glass'	6·6	Wood ashes	0·53
Terra-cotta	4·8	Mahogany dust	0·52
Brickwork	4·8	Canvas, hempen new	0·41
Plaster	3·8	Calico, new	0·40
Sand	2·17	Writing-paper, white	0·34
Oak, against the grain or fibre	1·7	Cotton and sheep's wool	0·32
Walnut, with the grain or fibre	1·4	Eiderdown	0·31
Fir, with the grain or fibre	1·37	Blotting-paper, grey	0·26

RELATIVE AND ABSOLUTE THERMAL CONDUCTIVITY OF
SUBSTANCES USED AS LAGGING FOR STEAM BOILERS.—
(*Professor Jamieson.*)

RESULTS OF THE TESTS.

Name of Material.	Weight of Sample (including Tin).	Total fall of Tempera- ture in 120 minutes.	Thermal Conductivity in Absolute Measure.	Conductivity as Compared with Dry Still Air.
	lbs. oz.	Deg. Cent.		
Dry air	—	6.0	0.0000558	1.00
Fossil meal composition .	7 2	21.5	0.0002689	4.82
Cement with hair felt* .	5 15	30.0	0.0003613	6.47
Silicate cotton,† or slag wool	—	29.0	0.0003875	6.95
Kieselguhr‡ composition	7 13	29.0	0.0004336	7.77
Papier maché composition§	7 6	35.5	0.0004424	7.93
Fibrous composition (flax, hemp, cow-hair, and clay)	9 9	34.5	0.0004550	7.98
Papier maché composition	8 12	37.5	0.0005019	8.99

* The outside diameter of this sample was about $\frac{1}{4}$ in. smaller than the inside diameter of the middle tin-case or vessel, and it had consequently a slight advantage over the other samples in having a thin layer of air between its outer surface and the latter.

† The silicate cotton was pressed together tightly, and thus its conductivity appears greater than would have been the case had it been more loosely packed.

‡ The Kieselguhr employed consisted on the average of Silica 83.8, Magnesia 0.7, Lime 0.8, Alumina 1.0, Peroxide of Iron 2.1, Organic Matter 4.5, Moisture and Loss, 7.1. It was employed in conjunction with 10 per cent. of binding material, viz., fibre and mucilaginous extract of several vegetable matters.

§ Papier maché composition, consisting of paper pulp mixed with clay and carbon, together with hair and fragments of hemp rope.

|| A lighter modification of above.

The quantity of heat in units, transmitted through one square foot of plate per hour, may be found thus: Subtract

the temperature of the cooler side from that of the hotter side of the plate, then multiply the result by the number in the table on p. 121 corresponding to the material used, and divide the product by the thickness of plate in inches. Thus an iron plate 2 in. thick, having a temperature of 60° on one side and 80° on the other, will transmit $80 - 60 \times \frac{230}{2} = 2300$ units of heat per square foot per hour.

HEAT-CONDUCTING POWER OF VARIOUS SUBSTANCES,
SLATE BEING 1000.—(*Molesworth.*)

Slate	1,000	Chalk	564
Lead	5,210	Asphalt	451
Flagstone	1,110	Oak	336
Portland stone	750	Lath and plaster	255
Brick	600 to 730	Cement	200
Fire-brick	620		

TESTS REGARDING CONDUCTIVITIES OF ASBESTOS AND
KIESELGUHR.—(*J. G. Dobbie.*)

RESULTS OF TESTS.

	Asbestos.	Kieselguhr Com- position.
	Water Condensed in Inches.	Water Condensed in Inches.
After 15 minutes . . .	4 $\frac{1}{2}$	2 $\frac{1}{2}$
„ 30 „ . . .	3 $\frac{1}{2}$	2 $\frac{1}{2}$
„ 45 „ . . .	3 $\frac{1}{2}$	2 $\frac{1}{2}$
„ 60 „ . . .	3 $\frac{1}{2}$	2 $\frac{1}{2}$
Totals in one hour . .	14 $\frac{1}{2}$	9 $\frac{1}{2}$

RESULTS OF DIFFERENT EXPERIMENTS ON THE HEAT CONDUCTIVITIES OF VARIOUS SUBSTANCES.—(*W. H. Collins.*)(*Silicate cotton being taken as 100.*)

Substance.	C. E. Emery. 1881.	J. J. Coleman. 1884.	W. H. Collins. 1891.	Prof. Jamieson. 1894.
Fossil meal composition . . .	∞	∞	∞	70
Cement with hair-felt . . .	83	∞	∞	93
Silicate cotton or slag wool . .	100	100	100	100
Hair-felt or fibrous composition .	∞	117	114	112
Papier-maché . . .	∞	∞	147	111
Kieselguhr composition . . .	∞	136	∞	112
Sawdust . . .	122	163	142	∞
Charcoal . . .	132	140	∞	∞
Cotton wool . . .	∞	122	∞	∞
Sheeps' wool . . .	∞	136	∞	∞
Pine wood (across the grain) . .	150	∞	∞	∞
Loam . . .	∞	∞	∞	∞
Gasworks breeze or coal ashes . .	240	230	299	∞
Asbestos . . .	229	∞	179	∞

EXPERIMENTS BY T. B. LIGHTFOOT AND G. A. BECKS.

EXPERIMENT NO. I.

Duration of experiment, 48 hours. Average temperature of room or chamber, 90° F.

A piece of ice 23 lbs. in weight was placed in a zinc box 12 in. cube, and covered with 2 in. silicate cotton, this latter being provided with an outer cover, also of zinc. When the ice was taken out it weighed 10½ lbs., showing a loss of 12½ lbs.

$12\frac{1}{2}$ lbs. $\times$ 142 (latent heat of ice) = 1775 thermal units passed through in 48 hours. $\frac{1775}{48} = 36.979166$ thermal units passed through in 1 hour.

Difference in temperature between inner box and outer air = 58° F. $\frac{36.9}{58} = 0.63$ thermal unit transmitted per hour per degree difference in temperature. Area of zinc boxes: inner box, 6 sq. ft.; outer, 10.6 sq. ft.; mean, 8.1 sq. ft.

Thermal units transmitted through the three areas—

$$\therefore \frac{0.63}{6} = 0.105, \frac{0.63}{8.1} = 0.07, \frac{0.63}{10.6} = 0.059$$

which being multiplied by 2 for the thickness of cotton, gives thermal units per hour, per degree difference in temperature, per square foot, per inch of thickness, as follows: 0.210 inner tin, 0.118 outer tin, 0.14 mean.

EXPERIMENT No. 2.

Duration, 48 hours. Average temperature of room, 90° F.

A piece of ice 26 lbs. in weight, covered with 6 in. of charcoal. When taken out it weighed 7½ lbs., showing a loss of 18½ lbs. $18.5 \times 142 = 2627$ thermal units in 48 hours. $\frac{2627}{48} = 54.72$ thermal units per hour. $\frac{54.72}{6} = 9.12$ thermal units per hour, per degree difference in temperature between inner box and outer air. Area of tins: inner box, 6 sq. ft.; outer, 24 sq. ft.; mean, 13.5 sq. ft.

The number of thermal units transmitted per hour, per degree, per square foot—

$$\frac{9.12}{6} = 1.52, \frac{9.12}{13.5} = 0.675, \frac{9.12}{24} = 0.38$$

which being multiplied by 6 for the thickness of charcoal, gives thermal units transmitted per hour, per degree, per square foot, per inch of thickness; 0.90 inner tin, 0.234 outer tin, 0.14 mean.

FORMULA FOR ASCERTAINING UNITS OF REFRIGERATION (R) REQUIRED IN 24 HOURS, TO CARRY OFF HEAT RADIATED THROUGH SQ. FT. (f) OF WALL, FLOOR, AND CEILING.

$$R = fn(t - t_1)HU$$

HU = heat units of 772 ft. lbs., t = internal temperature, t_1 = external temperature, and n = heat units transmitted per 24 hours per sq. ft. of surface for difference of 1° Fahr. between internal and external temperature.

TRANSMISSION OF HEAT THROUGH VARIOUS INSULATING STRUCTURES.—(*Starr, American Warehousemen's Assoc.*)

Insulating Structures.	B. T. U. per sq. ft. per day per deg. of difference of tempera- ture.	Meltage of ice in lbs. per day by heat coming through 100 sq. ft. at a difference of 40°.
$\frac{3}{4}$ -in. oak, paper, 1-in. lampblack, $\frac{3}{4}$ -in. pine (ordinary Stock family refrigerator) ..	5·7	160·7
$\frac{7}{8}$ -in. board, 1-in. pitch, $\frac{7}{8}$ -in. board ..	4·90	138·0
Four $\frac{7}{8}$ -in. spruce boards, two papers, solid, no air-space	4·28	120·0
Two double boards and paper (four $\frac{7}{8}$ -in. boards), and one air-space	3·71	105·0
$\frac{7}{8}$ -in. board, 2-in. pitch, $\frac{7}{8}$ -in. board ..	4·25	119·7
$\frac{7}{8}$ -in. board, 2½-in. mineral wool, paper, $\frac{7}{8}$ -in. board	3·62	101·9
Two $\frac{7}{8}$ -in. double boards, and two papers, 1-in. hair felt	3·318	93·4
Two $\frac{7}{8}$ -boards and paper, 1-in. sheet cork, two $\frac{7}{8}$ -in. boards and paper	3·30	92·9
$\frac{7}{8}$ -in. board, paper, 2-in. calcined pumice, paper, and $\frac{7}{8}$ -in. board	3·38	95·2
Four double $\frac{7}{8}$ -in. boards with paper between (eight boards), and three 8-in. air-spaces	2·7	76·0
Hair quilt insulator, four boards, four quilts hair	2·517	70·9
7-in. board, 6-in. pat. silicated straw-board, air-cell finished inside with thin layer of patent cement	2·48	69·8
$\frac{7}{8}$ -in. board, paper, 3-in. sheet cork, paper, $\frac{7}{8}$ -in. board	2·10	60·0
Two $\frac{7}{8}$ -in. boards and paper, 8-in. mill shavings and paper, two $\frac{7}{8}$ -in. boards and paper	1·35	38·3
Same, slightly moist	1·80	50·7
Same, damp	2·10	60·0
Double boards and paper, 1-in. air, 4-in. sheet cork, paper, $\frac{7}{8}$ -in. board	1·20	33·6
Same, with 5-in. sheet cork	0·90	25·3
$\frac{3}{4}$ -in. board, paper, 1-in. mineral wool, paper, $\frac{7}{8}$ -in. board	4·6	130·0
Double boards and papers, 4-in. granulated cork, double boards and paper	1·7	48·0

WALLS FOR COLD STORES.

The following materials and dimensions have been recommended for walls of cold chambers :—

14 in. brick wall, $3\frac{1}{2}$ in. air space, 9 in. brick wall, 1 in. layer of cement, 1 in. layer of pitch, 2 in. by 3 in. studding, layer of tar paper, 1 in. tongued and grooved boarding, 2 in. by 4 in. studding, 1 in. tongued and grooved board, layer of tar paper, and, finally, 1 in. tongued and grooved boarding, the total thickness of these layers or skins being 3 ft. 3 in.

36 in. brick wall, 1 in. layer of pitch, 1 in. sheathing, 4 in. air space, 2 in. by 4 in. studding, 1 in. sheathing, 3 in. layer of mineral or slag-wool, 2 in. by 4 in. studding, and, finally, 1 in. sheathing; total thickness, 4 ft. 7 in.

14 in. brick wall, 4 in. pitch and ashes, 4 in. brick wall, 4 in. air space, 14 in. brick wall; total thickness, 3 ft. 4 in.

14 in. brick wall, 6 in. air space, double thickness of 1 in. tongued and grooved boards, with a layer of waterproof paper between them, 2 in. layer of the best quality hair felt, second double thickness of 1 in. tongued and grooved boards, with a similar layer of paper between them; total thickness, 2 ft. 2 in.

14 in. brick wall, 8 in. layer of sawdust, double thickness of 1 in. tongued and grooved boards, with a layer of tarred waterproof paper between them, 2 in. layer of hair felt, second double thickness of 1 in. tongued and grooved boards, with a similar layer of paper between them; total thickness, 2 ft. $4\frac{1}{2}$ in.

Brick wall, 3 in. scratched hollow tiles, 4 in. silicate cotton or slag-wool, 3 in. scratched hollow tiles, and layer of cement plaster.

Brick wall, 1 in. air spaces between fillets or strips, 1 in. tongued and grooved boarding, two layers of insulating paper, 1 in. tongued and grooved boarding, 2 in. by 4 in. studs, 16 in. apart, spaces filled in with silicate cotton, 1 in. tongued and grooved boarding, two layers of insulating paper, air spaces between fillets, or strips 1 in. by 2 in. spaced 16 in. apart from centres, 1 in. tongued and grooved boarding, two layers of insulating paper, and 1 in. tongued and grooved boarding.

Brick or stone wall, well coated on inside with pitch, or asphaltum, 2 in. by 3 in. studding, 24 in. centres spaces between filled in with silicate cotton, $\frac{3}{4}$ in. rough tongued and grooved boarding, two layers waterproof insulating paper, $\frac{3}{4}$ in. rough tongued and grooved boarding, 2 in. by 3 in. studding 24 in. centres in spaces between, $\frac{3}{4}$ in. rough tongued and grooved boarding, two layers of waterproof insulating paper, $\frac{3}{4}$ in. rough tongued and grooved boarding, 2 in. by 3 in. studding, 24 in. centres spaces between filled in with silicate cotton, $\frac{3}{4}$ in. rough tongued and grooved boarding, two layers of waterproof insulating paper, and $\frac{3}{4}$ in. tongued and grooved match-boarding. Paper to be laid one-half lap and cemented at all joints.

Brick wall 2 in. air space, 2 in. thicknesses of tongued and grooved boards with three layers of paper between, 2 in. air space, 2 in. thicknesses of tongued and grooved boards with three layers of paper between, 2 in. air space and 2 in. thicknesses of tongued and grooved boards with three layers of paper between.

Brick wall well coated with pitch, 2 in. air space, 2 in. thicknesses of tongued and grooved boards with three layers of paper between, 2 in. space filled with slag-wool or cork, 2 in. thicknesses of tongued and grooved boards, with three layers of paper between, 2 in. space filled with slag-wool or cork, 2 in. thicknesses of tongued and grooved boards with three layers of paper between. Shelving should be fixed horizontally in the spaces packed with slag-wool or cork at about 16 in. apart.

Brick wall, 1 in. air space, $\frac{3}{4}$ in. match-boarding, 9 in. slag-wool or silicate cotton, layer of insulating paper, and $\frac{3}{4}$ in. match-boarding.

Brick wall, 1 in. air space, 6 in. slag-wool or silicate cotton, 1 in. silicate of cotton slab, layer of insulating paper, $\frac{1}{2}$ in. air space, and $\frac{3}{4}$ in. match-boarding.

Brick wall, 1 in. air space, 1 in. silicate of cotton slab, 4 in. silicate of cotton, 1 in. silicate of cotton slab, $\frac{1}{2}$ in. air space, and $\frac{3}{4}$ in. match-boarding.

Brick wall well coated with pitch, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 4 in. slag-wool or silicate cotton, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of

paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

Brick wall, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

Brick wall, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, one layer of paper, 4 in. slag-wool or silicate cotton, $\frac{7}{8}$ in. tongued and grooved boarding, one layer of paper, 4 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

Brick wall, layer of pitch, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, one layer of paper, 3 in. cork dust, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

Brick wall, $2\frac{1}{2}$ in. air space ventilated by air-bricks every 5 feet in all directions, 1 in. tongued and grooved boarding, layer of insulating paper, 1 in. tongued and grooved boarding, 12 in. charcoal supported by horizontal shelving 28 in. centres apart, 1 in. tongued and grooved boarding, two thicknesses of brown paper, and 1 in. tongued and grooved boarding.

Wall of cold storage room when made of wood: 2 in. thicknesses of tongued and grooved boarding with three layers of paper between, 2 in. air space, 2 in. thicknesses of tongued and grooved boarding with three layers of paper between, 2 in. air space, 2 in. thicknesses of tongued and grooved boarding with three layers of paper between, 2 in. air space, 2 in. thicknesses of tongued and grooved boarding with three layers of paper between, 8 in. slag-wool or silicate cotton, and 1 in. tongued and grooved boarding.

2 in. boards, $5\frac{1}{2}$ in. by 3 in. uprights, spaces between filled with carefully dried wood charcoal, $1\frac{1}{4}$ in. boarding, layer of insulating paper, and $1\frac{1}{4}$ in. boarding.

Outside siding, two layers of insulating paper, 1 in. tongued and grooved boarding, 2 in. by 6 in. studdings, 16 in. apart from centres, 1 in. tongued and grooved boarding,

two layers of insulating paper, 1 in. tongued and grooved boarding, 2 in. by 4 in. studding 16 in. apart from centres, spaces filled in with silicate cotton, 1 in. tongued and grooved boarding, two layers of insulating paper, 2 in. by 2 in. fillets or strips 16 in. apart from centres, 1 in. tongued and grooved boarding, two layers of insulating paper, and 1 in. tongued and grooved boarding.

DIVISIONAL PARTITIONS FOR COLD STORES.

Tongued and grooved match-boarding, wire netting, 6 in. silicate of cotton or slag-wool, wire netting, tongued and grooved match-boarding. The object of the netting is to render the partition fire-proof by supporting the silicate of cotton after the match-boarding might have burnt away.

$\frac{3}{4}$ in. match-boarding, $\frac{1}{2}$ in. air space, 1 in. silicate cotton slab, 4 in. of silicate of cotton or slag-wool, 1 in. silicate of cotton slab, $\frac{1}{2}$ in. air space, and 1 in. silicate of cotton slab.

2 in. tongued and grooved boarding, with three layers of paper between, 2 in. silicate of cotton or cork, 2 in. tongued and grooved boarding with three layers of paper between, 2 in. silicate of cotton or cork, 2 in. tongued and grooved boarding with three layers of paper between.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 4 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 6 in. silicate of cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, 2 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space, $\frac{7}{8}$ in.

tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 8 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 4 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

$\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. hair felt, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

FLOORING FOR COLD STORES.

2 in. flooring, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space between fillets or scantlings, $\frac{7}{8}$ in. tongued and grooved boarding, 12 in. joists, spaces between packed with silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space between fillets and scantlings, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and $\frac{7}{8}$ in. tongued and grooved boarding.

2 in. cement, 3 in. concrete, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, 2 in. flooring, 4 in. silicate cotton between fillets or scantlings, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, and 2 in. flooring boards on fillets or scantlings set in concrete.

2 in. asphalte, $\frac{7}{8}$ in. tongued and grooved boarding, two layers of paper, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space between scantlings, $\frac{7}{8}$ in. tongued and grooved boarding, 3 in. silicate cotton or slag-wool between fillets or scantlings, $\frac{7}{8}$ in. tongued and grooved boarding, 2 in. air space between fillets or scantlings, concrete.

1 in. asphalte, 2 in. concrete, $\frac{1}{2}$ in. pitch, 2 in. concrete, brick arches.

$1\frac{1}{4}$ in. tongued and grooved flooring, layer of insulating

paper, 2 in. by 9 in. joists, 12 in. centres apart, spaces filled with silicate cotton or slag-wool, wire netting, layer of insulating paper, $\frac{3}{4}$ in. match-boarding on 2 in. by 2 in. fillets or scantlings air spaces between, existing wooden or concrete flooring. The wire netting secured to the under side of the joists serves to retain the silicate cotton in case of fire.

1 in. tongued and grooved boarding, three layers of insulating paper, 1 in. tongued and grooved boarding, 2 in. by 9 in. joists, spaces between filled in with silicate cotton or cork, 1 in. tongued and grooved boarding, three layers of insulating paper, and 1 in. tongued and grooved boarding.

$1\frac{1}{4}$ in. tongued and grooved flooring, layer of insulating paper, 2 in. by 9 in. joists, 12 in. centres apart, spaces between filled in with silicate cotton or slag-wool, 1 in. silicate cotton slab on $\frac{1}{2}$ in. by 2 in. fillets air spaces between, and $\frac{3}{4}$ in. match-boarding. The 1 in. silicate of cotton slab is nailed on the under side of joists and is claimed to render the floor fire-proof, and to prevent radiation through the joists.

2 in. matched flooring, two layers of insulating paper, 1 in. matched sheathing, 4 in. by 4 in. sleepers 16 in. apart from centres, spaces between filled in with silicate cotton, double 1 in. matched sheathing with twelve layers of paper between, and 4 in. by 4 in. sleepers 16 in. apart from centres imbedded in 12 in. of dry underfilling.

Ground, concrete, layer of asphalte, 1 in. tongued and grooved match-boarding well tarred, two layers of stout brown paper, 1 in. tongued and grooved match-boarding, floor joists 3 in. by 11 in. spaced 21 in. apart, binder joists 11 in. by 4 in., bearing edges of floor joists protected by strips of hair felt $\frac{1}{4}$ in. thick and spaces between joists filled in with flake charcoal, and $1\frac{1}{4}$ in. tongued and grooved flooring boards.

As a further example of methods that have been actually successfully employed for insulation, it will be interesting to know that the cold storage chambers built at the St. Katherine Dock, London, were constructed as follows:—

On the concrete floor of the vault, as it stood originally, a covering of rough boards $1\frac{1}{4}$ in. in thickness were laid

longitudinally. On this layer of boards were then placed transversely, bearers formed of joists $4\frac{1}{2}$ in. in depth by 3 in. in width, and spaced 21 in. apart. These bearers supported the floor of the storage chamber, which consisted of $2\frac{1}{2}$ in. battens tongued and grooved. The $4\frac{1}{2}$ in. wide space or clearance between this floor and the layer or covering of rough boards upon the lower concrete floor was filled with well-dried wood charcoal.

FLOORING FOR ICE HOUSES.

Floor to incline 3 in. towards central drain, and cross channelled fillets or scantlings on $1\frac{1}{2}$ in. flooring, 2 in. cement, 6 in. concrete, ground.

1 in. tongued and grooved match-boarding, three layers of paper, 1 in. tongued and grooved match-boarding (to incline 3 in. towards central drain) on fillets or scantlings, air spaces between, 1 in. tongued and grooved match-boarding, three layers of paper, 1 in. tongued and grooved match-boarding, 2 in. by 9 in. joists spaces between filled with 4 in. silicate of cotton or slag-wool kept in position by $\frac{3}{4}$ in. boards secured by cleats to joists.

CEILINGS FOR COLD STORES AND ICE HOUSES.

1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 2 in. air spaces between strips or fillets, 1 in. tongued and grooved boarding, three layers of insulating paper, 1 in. tongued and grooved boarding, joists spaces between filled with silicate cotton or cork, 1 in. tongued and grooved match-boarding, three layers of insulating paper, and 1 in. tongued and grooved match-boarding.

Insulated flooring, joists, $\frac{7}{8}$ in. tongued and grooved match-boarding, two layers of insulating paper, $\frac{7}{8}$ in. tongued and grooved match-boarding, 2 in. spaces between strips or fillets filled in with silicate cotton or cork, $\frac{7}{8}$ in. tongued and grooved match-boarding, three layers of insulating paper, and $\frac{7}{8}$ in. tongued and grooved match-boarding.

1 in. tongued and grooved boarding, two thicknesses of

brown paper, 1 in. tongued and grooved boarding, joists with spaces between packed with silicate cotton, 1 in. tongued and grooved boarding, Willesden paper, and 1 in. tongued and grooved boarding.

Concrete floor, 3 in. book tiles, 6 in. dry underfilling, double space hollow tile arches and layer of cement plaster.

Double 1 in. floor with two layers of insulating paper between, 2 in. by 2 in. strips or fillets 16 in. apart from centres, spaces filled in with silicate cotton, two layers of insulating paper, 1 in. tongued and grooved match-boarding, 2 in. by 2 in. strips 16 in. apart, spaces filled in with silicate cotton, two layers of insulating paper, 1 in. tongued and grooved match-boarding, joists and double 1 in. flooring with two layers of insulating paper between.

DOOR INSULATION.

1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 2 in. by 1 in. fillets or strips, with spaces between filled in with silicate cotton or cork, 1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 2 in. by 1 in. fillets or strips, spaces between filled in with silicate cotton or cork, 1 in. tongued and grooved match-boarding, three layers of insulating paper, and 1 in. tongued and grooved match-boarding.

1 in. tongued and grooved match-boarding, two layers of insulating paper, 1 in. tongued and grooved match-boarding, 12 in. space filled in with silicate cotton, 1 in. tongued and grooved match-boarding, two layers of insulating paper, and 1 in. tongued and grooved match-boarding.

WINDOW INSULATION.

Windows are better dispensed with in cold stores and artificial light resorted to; where present, three sashes spaced a few inches apart and glazed at both sides should be used.

TANK INSULATION.

Tank sides: 4 in. air space between studding, 1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 4 in. space filled with cork, 1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 2 in. air space, 1 in. tongued and grooved match-boarding, three layers of insulating paper, and 1 in. tongued and grooved match-boarding. Bottom: 1 in. space between strips, fillets or studding, well tarred before tank is placed in position, 1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, 1 in. air space between strips, fillets or studding, 1 in. tongued and grooved match-boarding, three layers of insulating paper, 1 in. tongued and grooved match-boarding, and 2 in. by 9 in. joists on concrete or ground spaces between filled with cinders.

Tank: 2 in. air space between fillets, $\frac{7}{8}$ in. tongued and grooved match-boarding, two layers of insulating paper, $\frac{7}{8}$ in. tongued and grooved match-boarding, 4 in. silicate cotton or slag-wool, $\frac{7}{8}$ in. tongued and grooved match-boarding, two layers of insulating paper, and $\frac{7}{8}$ in. tongued and grooved match-boarding.

Tank: 2 in. air space between studding, layer of insulating paper, 2 in. flooring, two layers of insulating paper, $\frac{7}{8}$ in. tongued and grooved boarding, joists, spaces between filled with charcoal for three-quarters depth, $\frac{7}{8}$ in. tongued and grooved match-boarding, two layers of insulating paper, $\frac{7}{8}$ in. tongued and grooved match-boarding, ground or concrete.

SECTION V.

TESTING AND MANAGEMENT OF REFRIGERATING MACHINERY.

TESTING.

THE testing of a refrigerating plant is carried out for the purpose of ascertaining what it is capable of performing under comparable normal conditions, and as to the amount of refrigeration produced in relation with the expenditure of work, and the coal consumption.

To determine the efficiency of an installation on the compression system, the following instruments and fittings are required, viz. : An indicator, so that diagrams can be taken from the compressor ; stroke counters, to enable the number of strokes made by the steam-engine and brine pumps to be ascertained ; and mercury wells to admit of the temperature being obtained at various points throughout the system.

In making a test it is desirable that it should last at the very least for fully 12 hours, and it is better to carry it on for 24 hours. The number of readings which it is desirable should be taken from the various instruments will vary in accordance with whether or not the work is steady or otherwise, and the person carrying out the test will have, of course, to use his own judgment on this head. Where artificial ice is made, for example, twice an hour will be sufficient, whilst on the other hand, four or more readings per hour should be taken in cases where the variation in the temperature of the materials to be cooled is wide. Indicator diagrams should be taken from both the steam-engine cylinder and the compressor cylinder every two hours.

A mercury well, for an horizontal pipe, when the latter is of sufficient dimensions, consists usually in a short piece of tubing closed at its lower end, and fitted into the pipe by means of a suitable bushing. It is filled about three parts full of mercury, and the thermometer, which should have an elongated cylindrical bulb, is held in position therein by means of a perforated cork. For vertical pipes, or pipes of very small dimensions, where this arrangement would be impracticable, the well is generally formed by means of a wooden or other block, one side of which is shaped to the outline of the pipe to which it is to be applied, and has a suitable recess formed therein. This block is firmly secured against the pipe by metal strips in such a manner that a portion of the wall of the well will be formed by the pipe, the latter being scraped perfectly clean at that part. The joint between the block and the pipe must be made perfectly tight, which can easily be effected by means of a little white-lead paint, there being no pressure, and the whole should be surrounded by a thick layer of non-conducting composition, through which the stem of the thermometer is permitted to project.

The points in the system where it is desirable to locate the mercury wells are: The suction pipe just at its connection with the compressor; the discharge pipe, as close as possible to its connection with the compressor; the ammonia discharge pipe from the condenser, as near the latter as practicable. Where a brine circulation is employed: The pipe or manifold supplying the various coils or sets of pipes in the refrigerator; the discharge pipe of the refrigerator; the brine discharge pipe, at the point where it connects to the refrigerator; and the brine return pipe in proximity to where it connects with the refrigerator.

INTERPRETATION OF COMPRESSOR DIAGRAM.

The interpretation of a compressor diagram with respect to the working, valves, defects, etc., of the latter are given as follows by Hans Lorenz, in "Neuere Kuehlmaschinen," Muenchen and Leipzig, 1899.

Assuming all the parts of the machine to be in good order, then the diagram will have the general appearance

shown in Fig. 23. The suction line S is only slightly below the suction pressure line V, and the pressure line D is only slightly above the condenser pressure K. Small projections at the pressure and suction line indicate the work required to open the compressor valves, and the effect of clearance is shown by the curve R, which latter cuts the back pressure line after the piston has commenced to perform its return or back stroke, and consequently reduces the suction volume to that amount. It can also be seen from this diagram that the vapours are taken in by the compressor, not at the back pressure, but at what may be called the suction pressure, which is somewhat lower. This is the reason that the compression curve C does not intersect the back pressure line until after the piston has changed its direction of movement. The theoretical volume of the compressor, as indicated by the line V, is consequently reduced in practical working for vapours possessing a certain tension.

In Fig. 24 is shown a diagram taken from a compressor having an excessive amount of clearance. In this case, it will be seen, the back expansion line R passes through a flat course, and thereby reduces the useful volume of the compressor.

Fig. 25 is a diagram which indicates the binding of the pressure valve, which may be due to an inclined position of the guide rod of the valve. This deficiency also frequently causes a delay in the opening of the pressure valves, a state of things indicated by a too great projection in the pressure line. As soon as the valve is once opened the pressure line pursues its normal course until the piston commences its return stroke, when the defect is again manifested in the back pressure line, as mentioned.

Fig. 26 shows a diagram indicating too great a resistance in the pressure and suction pipes respectively, when the valves are over-weighted. In this case the pressure and suction line are at a comparatively great distance from the condenser pressure line and the back pressure line. The remedy for this is to replace the valve springs by weaker ones; and should there be then no marked effect, then the pipe-lines and shutting-off valves should be inspected, and, if found necessary, cleaned.




FIG. 23.—Diagram from Compressor with all parts in good order.




FIG. 24.—Diagram from Compressor with excessive amount of clearance.




FIG. 25.—Diagram from Compressor indicating the binding of the Pressure Valve.




FIG. 26.—Diagram from Compressor indicating too great a resistance in the Pressure and Suction Valves.




FIG. 27.—Diagram from Compressor indicating the binding of the Suction Valve.




FIG. 28.—Diagram from Compressor indicating leaking of Compressor Valves.




FIG. 29.—Diagram from Compressor indicating Defective Packing of Piston.

Fig. 27 indicates the binding of the suction valve by which a considerable decline is caused in the pressure at the beginning of the suction, which is consequently shown by an increased projection in the commencement of the suction line. At the beginning of compression this defect makes itself felt by causing a delay in the latter, which effect is also shown on this diagram.

Fig. 28 shows leaking of the compressor valves. In this diagram the projections in the compression and suction line do not appear, but the compression line gradually merges into the pressure line, and the back expansion line passes gradually into the suction line. If the leak in the pressure valve is the predominant one, then the compression curve will be almost in a straight line and very steep; if, on the contrary, the leak in the suction valve is the predominant one, then the compression line will run a rather flat course.

Fig. 29 indicates that the piston is not well packed, and, being leaky, the vapours are permitted to pass from one side of the piston to the other, thus causing a very gradual compression, and as a result a compression line having a flat course. On the other hand, a longer time will be taken before the suction line reaches its normal level on the return or backward stroke, inasmuch as the suction valve is prevented from opening until such time as the velocity of the piston becomes such that the amount of vapours leaking past the piston is insufficient in amount to fill the suction space. The pressure then gradually diminishes and the suction valve then begins to act, as is shown on the diagram.

It is to be understood that several of the defects above mentioned may exist at the same time.

MANAGEMENT OF AMMONIA COMPRESSION MACHINES.

Every particular type of machine working on this principle has, as a rule, certain distinctive or characteristic features, and will, of course, so far at least as these are concerned, require special care and adjustment, and it would consequently be totally impossible to lay down an arbitrary set of rules for working that would be suitable to

all; nor is this necessary or required, as full particulars relating to the manipulation of each particular machine are invariably supplied by the makers. The following points, however, are more or less applicable to all machines working on the ammonia compression principle, and should therefore be familiar to those in charge of the same.

Before charging an empty machine with anhydrous ammonia, all air must first be carefully expelled. This is effected by working the pumps so as to discharge the air through special valves which are usually provided on the pump dome for that purpose.

The entire system should have been previously to this thoroughly tested by working the compressor, and permitting air to enter at the suction through the special valves provided for that purpose, and it should be perfectly tight at 300 lbs. air pressure on the square inch, and should be able to hold that pressure without loss. Whilst testing the system under air pressure, it should be also carefully blown through and thoroughly cleansed from all dirt, every trace of moisture being also removed.

It is totally impossible to eject all air from the plant by means of the compressor, therefore it is advisable to insert the requisite charge of ammonia gradually and not all at once, the best practice being to put in from 60 to 70 per cent. of the full charge at first, and cautiously permit the air still remaining to escape through the purging-cocks with as little loss of gas as possible, subsequently inserting an additional quantity of ammonia once or twice a day, until all the air has been got rid of by displacement, and the complete charge has been introduced.

To charge the machine, the dryer or dehydrator of the apparatus for manufacturing or generating anhydrous ammonia, or where no such apparatus is included in the installation, the drum or iron or steel flask of anhydrous ammonia should be connected, through a suitable pipe, to the charging valve; the expansion valve must be then closed, and the valve communicating with the dryer or dehydrator, or that in the flask or bottle, opened. The machine should be run at a slow speed when sucking ammonia from the drier, or whilst the flask is being emptied, with the discharge and suction valves full open.

In the latter case, when one of the said flasks or bottles has been completely emptied, it must be removed, the charging-valve having been first closed, and another placed in position, until the machine is sufficiently charged to work, when the charging-valve should be finally closed, and the main expansion valve opened and regulated. A glass gauge upon the liquid receiver will show when the latter is partially filled, and the pressure gauges, and the gradual cooling of the brine in the refrigerator (in the case of a brine circulation or ice-making apparatus), and the expansion pipe leading to the refrigerator coils becoming covered with frost, indicate when a sufficient amount to start working has been inserted.

It is sometimes advisable to slightly warm the vessels or bottles containing the anhydrous ammonia by means of a gas jet, or in some other convenient manner, whilst transferring their contents to the machine, as otherwise, if frost forms on the exterior of the said bottles, they will not be completely discharged, and loss of ammonia will ensue.

The flasks, bottles, or other receptacles containing the anhydrous ammonia should be always kept in a tolerably cool and a perfectly safe situation, and they should moreover be moved and handled with the utmost caution and care.

In the event of an accident occurring, and any considerable quantity of the ammonia becoming spilt, it is well to remember that it is so extremely soluble in water that one part of the latter at a temperature of 60° Fahr. will absorb some 800 parts of the ammonia gas, therefore water should be employed to kill or neutralise it, and any person attempting to penetrate an atmosphere saturated with this gas should not fail to place a cloth well saturated with water over his nose and mouth.

The machine having been started, and the regulating valve opened, it is essential to note carefully the temperature of the delivery pipe on the compressor, and if it shows a tendency to heat, then the said regulating valve must be opened wider; whilst, on the contrary, should it become cold, this valve must be slightly closed, the regulation or adjustment thereof being continued until the normal

temperature of the delivery pipe is the same as that of the cooling water leaving the condenser. When the charge of ammonia in the machine is insufficient, the delivery pipe will become heated, and that even when the regulating valve is wide open.

There are many additional signs of the healthy working of the apparatus other than the fact that it is satisfactorily performing its proper refrigerating duty, which soon become easily recognisable to those in charge; for example, every stroke of the piston will be clearly marked by a corresponding vibration of the pointers or indexes of the pressure and vacuum gauges. The frost visible on the exterior of the ammonia pipes leading to and from the refrigerator will be about the same. The liquid ammonia can be distinctly heard passing in a continuous and uninterrupted stream through the regulating valve. The temperature of the condenser will be about 15° higher than that of the cooling water running from the overflow. And finally, the temperature of the refrigerator will be about 15° lower than the actual temperature of the brine or the water being cooled.

Air will find its way into the system through leaky stuffing-boxes, improper regulation of the expansion valve, etc. Its presence in any considerable volume is shown by a kind of whistling noise, the liquid ammonia passing through the expansion valve in an intermittent manner, a rise of pressure in the condenser, and also loss of efficiency thereof, and other obvious signs. In this case the above air must be got rid of through the purging-cocks in a similar manner to that which remains in the system when first charging the machine.

The presence of any considerable amount of oil or water in the system, which may result from careless distillation, will cause a reduction in efficiency, and will be evidenced by shocks within the compressor cylinder.

The temperature can be regulated either by running the machine at a higher speed or by increasing the back pressure, or by a combination of both. The back pressure can be regulated by means of an expansion valve or valves fitted between the receiver and the refrigerator evaporating coils or pipes in the main liquid pipe.

LEAKS IN AMMONIA APPARATUS.

Leaks are readily detected by the smell of the escaping ammonia gas when the machine is being filled ; at a later stage, when working, their detection is not so easy. During the operation of the machine, when the liquor or brine in the tanks commences to smell of ammonia, it indicates a considerable leakage. It is recommended to test the liquor or brine periodically with Nessler's solution or otherwise.

Nessler's reagent, which is the best to use for the discovery of traces of ammonia in water or brine, consists of 17 grms. of mercuric chloride dissolved in about 300 cc. of distilled water, to which are added 35 grms. potassium iodide dissolved in 100 cc. of water, and constantly stirred until a slight permanent red precipitate is produced. To the solution thus formed are added 120 grms. of potassium hydrate dissolved in about 200 cc. of water, allowed to cool before mixing ; the amount is then made up to 1 ltr., and mercuric chloride added until a permanent precipitate again forms. After standing for a sufficient time, the clear solution can be placed in glass-stoppered blue bottles and kept in a dark place.

If a few drops of this reagent be added to a sample of the suspected brine or water in a test-tube, or other small vessel, and the slightest trace of ammonia is present, a yellow colouration of the liquid will take place ; a large quantity of ammonia will produce a dark-brown.

When the leaks are comparatively insignificant they can be closed in the usual way, by solder, using as a flux muriatic or hydrochloric acid killed with zinc. In some instances electric welding may be resorted to with advantage, or the leak may be closed by means of a composition of litharge and glycerine mixed into a stiff paste, bound with sheet-rubber, and covered with sheet-iron clamped firmly in position. When, however, the leak is at all serious, it is usually the better plan to at once put in a new coil, or a new length of pipe.

LEAKS IN CARBONIC ACID MACHINES.

To detect these, smear the joints with a solution of soap and water, and any leakage of gas will be evidenced by the

formation of bubbles. Carbon dioxide or carbonic acid being a completely inodorous gas, precautions are required to prevent the unnoticed occurrence of leakage.

Before closing this chapter, a few words upon the excess condensing pressure invariably found in ammonia compression machines will not be out of place. This excess of the actual working condensing pressure over the theoretical is caused by the ammonia gas being imprisoned in the comparatively confined space afforded by the coils or pipes in the refrigerator, and the excess pressure is more marked in a horizontal compressor running at a high speed of, say, 140 revolutions per minute, than it is in vertical ones having only a low speed of from 35 to 60 revolutions per minute; it varies, moreover, in almost every make of compressor. At a low suction pressure of about 15 lbs. it should not be more than 10 lbs., but with a suction pressure of, say, 27 or 28 lbs. it may rise to 50 lbs., or even more.

The condensing pressure affords a means of ascertaining whether or not the apparatus contains the proper full charge of ammonia, or if the losses sustained by leakage are sufficient to render it necessary to insert an additional supply. For this reason it is advisable for the person in charge to keep a record in a proper book, suitably ruled for the purpose, of the temperature of the condensed ammonia when leaving the condenser, and also of the condensing and suction pressures, at regular intervals of, say, three hours. This will enable him to follow the state of the ammonia charge; for example, if the condensing pressure is found to be gradually falling during a three months' period, as compared with the average condensing pressure of the previous three months, whilst at the same time the condensing temperature and the suction pressure remain constant, it will be evident that the charge of ammonia has become reduced by leakage to a sufficient extent to require replenishing. This reduction in the condensing pressure is caused by the diminution in the charge of ammonia giving larger condenser space, the gas having thus a much more extended worm, coil, or tube space wherein to condense and liquefy, and hence the decrease. As a general rule, it may be taken that, whenever the condensing pressure is found to have fallen about

8 lbs., enough ammonia to restore the original condensing pressure should be inserted into the machine.

LUBRICATION OF REFRIGERATING MACHINERY.

This important point is apt to be as much neglected by users of refrigerating machinery as it is by those of other types of machinery. It would be well for these gentlemen to at once dismiss from their minds the idea that low-priced inferior quality oils are really the cheapest, and understand that, on the contrary, not only are high-grade oils necessary to ensure the highest efficiency of the machinery, but that they are also the least expensive in the long run.

In refrigerating machinery the use of three different kinds of oil is demanded, viz. steam cylinder oil; oil for general use; and compressor pump oil:—

Oil for the steam cylinder. Good cylinder oil is entirely free from grit, does not gum up the valves and cylinder, and does not evaporate rapidly on exposure to the heat of the steam. The quality of a cylinder oil is demonstrated on removal of the cylinder head. If the oil is of good quality, the wearing surfaces should appear well coated with lubricant, which will not show a gummy deposit, or blacken on the application of clean waste.

Oil for general use on all the bearings and wearing surfaces of the machine proper: This may be any oil that will not gum, is not too limpid, possesses a good body, is free from grit and acids, is of good wearing quality, and flows freely from the oil-cups at a fine adjustment without a tendency to clog. For the larger bearings it is well to use a heavier grade of oil.

Oil for use in compressor pumps: This should be what is known as zero oil, or cold test oil, that is to say, it should be capable of withstanding a very low temperature without freezing, and it should be of the best quality. American makers recommend the use of the best paraffin oil, and clear West Virginia crude oil.

SUGGESTED FORM FOR ENGINEER'S DAILY REPORT.

Department No.

Engineer's Daily Report.

Date

Engine Room.				Refrigerator Temperature.										Water Condenser.		Weather.		Remarks.														
Direct pressure.		Suction pressure.		Revolutions.		Brine or salt water column.		Steam.		Vacuum.		No. 1 Room.	No. 2 Room.	No. 3 Room.	No. 4 Room.	No. 5 Room.	No. 6 Room.			No. 7 Room.	No. 8 Room.	No. 9 Room.	No. 10 Room.	No. 11 Room.	No. 12 Room.	Initial temperature to ammonia condenser.	Temperature of water on entering steam condenser.	Final temperature of water on leaving steam condenser.	Temperature.	Conditions.		
Hour.																																
Engine.	Up to present date.	To-day.	Total.	Boilers. Hours run.		Fuel. Coal receipts.		Refrigeration daily in tons.		Brine or salt water column.		Gallons to date.																				
No. 1				No. 1																												
" 2				" 2																												
" 3				" 3																												
" 4				" 4																												
" 5				" 5																												
" 6				" 6																												
" 7				" 7																												
" 8				" 8																												
" 9				" 9																												
" 10				" 10																												
" 11				" 11																												
" 12				" 12																												

Engineer's Signature

LIGHTING COLD STORES.

It is desirable that daylight should not be allowed to enter a cold store, and therefore artificial light is usually resorted to, electric light being invariably employed, owing to there being practically an absence of heat therefrom.

Incandescent lamps should be always used inside the cold stores, but arc lamps may be placed, if desired, in the engine-room, and employed for the external lighting of the premises. Lower voltage lamps are the most durable, and serve the purpose quite as well as those of a higher voltage.

The mains should be kept as far as practicable in the corridors, and tinned cables of high conductivity and with rubber insulation should preferably be employed.

Iron piping, steel conduits, or wood casing, may be used for carrying the main cables, the latter being the cheapest both in cost of material and in fixing, and also lending itself more readily to any subsequent alterations that may become necessary. Steel conduits, however, possess several important advantages. The steel-armoured insulating conduit material now much used is installed in a similar manner to ordinary gas-pipe construction, the principal difference in electric piping being that specially insulated boxes, bends, elbows, etc., are substituted for the ordinary tees or angles of a gas-pipe system. The use of the conduit system ensures a mechanically and electrically protective duct for the installation of the electric conductors.

When wood casing is used, the interior should be painted with asbestos paint, and the cover fixed with brass screws on each edge, not in the central fillet.

Iron piping has an internal lining of suitable insulating material, and is, as a rule, coated with a bituminous compound of some description intended to act as a preservative.

There are two systems of carrying out wiring now in use, viz. the tree system, and the distributing-board system.

In the first of these, or the tree system, two main cables are carried through the building, the branch circuits being all taken from these cables or mains. In the second, or distributing-board system, a main switchboard is placed close to the dynamo, from which main switchboard cables are carried to supplementary distributing boards located at convenient points, from which the lamps are wired.

An obvious advantage of this latter plan is that all the joints are readily get-at-able, being at the distributing boards and fittings. The insulation of the cable is left completely intact.

In fixing wood casing all joints should be united, and no sharp edges or corners left for the cable to pass over. The casing is ordinarily secured by screws to the walls, floors, and ceilings, and either on the surface, partially sunk, or sunk flush therewith. In very damp situations, however, the casing should be supported, so as to be clear of the surfaces, by means of small porcelain insulators.

The circuits may be arranged either on the series system or on the parallel arrangement, the latter being the most common, and the former being, as a rule, only employed where a number of arc lamps are used. The series circuit and parallel circuit are shown in the diagrams (Figs. 30 and 31), the dynamos, main cables, lamps, and switches being indicated thereon.

In the series circuit the current is maintained constant in value, the difference in pressure varying with the work on the circuit.

In the parallel circuit all the lamps are connected as separate paths between the two main leads, each path being quite independent of the other paths. The difference of electrical pressure is maintained constant, the current varying with the work that is on the circuit. The switching off of a lamp causes a break in the wires connecting the lamp to the circuit.




FIG. 30.—Diagram illustrating Arrangement of Electric Lighting on the Series Circuit System.




FIG. 31.—Diagram illustrating Arrangement of Electric Lighting on the Parallel Circuit System.

SECTION VI.

GENERAL TABLES AND MEMORANDA.

EXPERIMENTS IN WORT COOLING.

THE following tabulated experiments of the performance of a tubular refrigerator for wort cooling are gleaned from *Engineering*. The water and wort are moved in opposite directions, the former through thin metallic tubes, which are surrounded by the wort to be cooled :—

Area of Cooling Surface of Refrigerator.	WORT.					WATER.			
	Specific Gravity.	Quantity passed through per Hour.	Initial Temperature.	Final Temperature.	Cooled down.	Quantity passed through per Hour.	Initial Temperature.	Final Temperature.	Warmed up.
Square Feet.		Bbls.	Fahr.	Fahr.	Fahr.	Bbls.	Fahr.	Fahr.	Fahr.
No. 1. 881	—	33·9	212°	72°	140°	61·1	65°	169°	104°
No. 2. 514	1·104	36·1	155	59	96	75·5	54	100	46
No. 3. 514	1·188	36·6	191	59	132	99·5	54	100	46
No. 4. 514	1·035	47·3	193	59	134	90·7	54	100	46
No. 5. 514	1·018	48·0	178	59	119	102·0	54	100	46

NOTE 1.—A barrel contains thirty-six gallons, or 360 lbs. of water.

NOTE 2.—The temperature of the air in Nos. 2 and 4 was 44° F., and in Nos. 3 and 5, 40° F.

TABLE SHOWING THE TENSION OF AQUEOUS VAPOUR IN
MILLIMETRES OF MERCURY, FROM -30° C. TO 230° C.
—(*Siebert.*)

Temp.	Tension.	Temp.	Tension.	Temp.	Tension.	Temp.	Tension.
-30°	0.39	21°	18.5	94.0°	610.4	104°	876
-25	0.61	22	19.7	94.5	622.2	105	907
-10	0.9	23	20.9	95.0	633.8	107	972
-15	1.4	24	22.7	95.5	645.7	110	1,077
-10	2.1	25	23.6	96.0	657.5	115	1,273
-5	3.1	26	25.0	96.5	669.7	120	1,491
-2	4.0	27	26.6	97.0	682.0	125	1,744
-1	4.3	28	28.1	97.5	694.6	130	2,030
0	4.6	29	29.8	98.0	707.3	135	2,354
1	4.95	30	31.6	98.5	721.2	140	2,717
2	5.3	35	41.9	99.0	732.2	145	3,125
3	5.7	40	55.0	99.1	735.9	150	3,581
4	6.1	45	71.5	99.2	738.5	155	4,088
5	6.5	50	92.0	99.3	741.2	160	4,551
6	7.0	55	117.5	99.4	743.8	165	5,274
7	7.5	60	148.0	99.5	746.5	170	5,961
8	8.0	65	186.0	99.6	749.2	175	6,717
9	8.6	70	232.0	99.7	751.9	180	7,547
10	9.1	75	287.0	99.8	754.6	185	8,453
11	9.7	80	354.0	99.9	757.3	190	9,443
12	10.4	85	432.0	100.0	760.0	195	10,520
13	11.1	90	525.4	100.1	762.7	200	11,689
14	11.9	90.5	535.5	100.2	765.5	205	12,956
15	12.7	91.0	545.8	100.4	772.0	210	14,325
16	13.5	91.5	556.2	100.6	776.5	215	15,801
17	14.4	92.0	566.2	101.0	787.0	220	17,390
18	15.3	92.5	577.8	102.0	816.0	225	19,097
19	16.3	93.0	588.4	103.0	845.0	230	20,926
20	17.4	93.5	599.5				

Degrees C.....	120	134	144	152	159	171	180	190	213	235
Atmospheres ..	2	3	4	5	6	8	10	15	20	25

TABLE OF PHYSICAL CONSTANT OF GASES.—(Peckham.)

	Critical Temp. Centigrade.	Critical Pressure Atmospheres.	Boiling-point at Ordinary Pressure.	Freezing-point Centigrade.	Freezing Pressure Mm.	Density of Gas.	Density of Liquid at Boiling-point.	Colour of Liquid.
Carbon Dioxide, CO ₂	31.0 ¹	77.0	-78.2 ⁰³	-79.0 ^a	760	22	0.83 c o ⁴	Colourless
Ethylene, C ₂ H ₄	95.0	{ 44.0 } { 58.0 }	-110 ⁵	...	...	14	...	...
Hydrogen, H ₂	{ -234.5 ⁶ } { (Theor.) }	20.0	{ -243.5 ⁶ } { (Theor.) }	...	...	1	...	Colourless
Nitrogen, N ₂	-146	35.0	-194.4	-203 to -214 Mean -280 ⁷	60	14	0.885	Colourless
Carbonic Oxide, CO	-139.5	35.5	-190.0	-207.0	100	14	...	Colourless
Argon, A	-121.0	50.6	-187.0	-180.6	...	19.9	about 1.5	Colourless
Air	-140.0	39.0	-191.0	-207.0	...	...	0.933	Bluish
Oxygen, O ₂	-118.8	50.8	-182.7	...	...	16	1.124	Bluish
Nitric Oxide, NO	-93.5	71.2	-153.6	-167.0	138	15	...	Colourless
Marsh Gas, CH ₄	-81.8	54.9	-164.0	-185.8	80	8	0.415	Colourless
Helium, He	...	...	Below -264 ⁷ { (Theor.) }	...	...	2.02 ^a	...	...
Fluorine	...	...	-187	...	...	...	...	...

¹ Andrews, *Deschanel Nat. Phil.*, II., 352.² Villard & Jarry, *Comptes Rendus*, 1895, 120, 1413.³ Regnault, *Muspratt's Chem.*, IV., 1626.⁴ Thilorier, *Muspratt's Chem.*, IV., 1626.⁵ Fownes, *Elem. Chem.*, 12th ed., p. 534.⁶ Olzewski, *Phil. Mag.*, 1885 (5), 40; 202.⁷ Olzewski, *Ann. Phys. Chem.*, 1896 (2), 59, 184.^a Cleve, *Comptes Rendus*, 1895, 120, 1212.⁹ Dewar.

TABLE SHOWING PROPERTIES OF SATURATED STEAM.—*Yaryan.*

Absolute Pressure from Vacuum.		Above Atmosphere.		Tempera- ture. Deg. Fahr.	Total Heat in British Units.	Heat of Vaporiza- tion or Latent Heat.
lbs. per Square In.	Inches of Mercury.	lbs. per Square In.	Inches of Mercury.			
1	2.0355	—13.7	—27.886	101.99	1113.1	1043.0
2	4.0710	—12.7	—25.851	126.27	1120.5	1026.1
3	6.1065	—11.7	—23.815	141.62	1125.1	1015.3
4	8.142	—10.7	—21.780	153.09	1128.6	1007.2
5	10.178	—9.7	—19.744	162.34	1131.5	1000.8
6	12.213	—8.7	—17.709	170.14	1133.8	995.2
7	14.249	—7.7	—15.673	176.90	1135.9	990.5
8	16.284	—6.7	—13.638	182.92	1137.7	986.2
9	18.320	—5.7	—11.602	188.33	1139.4	982.5
10	20.355	—4.7	—9.567	193.25	1140.9	979.0
11	22.319	—3.7	—7.531	197.78	1142.3	975.8
12	24.426	—2.7	—5.496	201.98	1143.6	972.9
13	26.462	—1.7	—3.460	205.89	1144.7	970.1
14	28.497	—0.7	—1.425	209.57	1145.8	967.5
14.7	29.922	0.0	0.000	212.00	1146.6	965.8
15	30.533	0.3	0.611	213.03	1146.9	965.1
16	32.568	1.3	2.646	216.32	1147.9	962.8
17	34.604	2.3	4.682	219.44	1148.9	960.6
18	36.639	3.3	6.717	222.40	1149.8	958.5
19	38.675	4.3	8.753	225.24	1150.7	956.6
20	40.710	5.3	10.788	227.95	1151.5	954.6
21	42.746	6.3	12.824	230.55	1152.3	952.8
22	44.781	7.3	14.859	233.06	1153.0	951.0
23	46.787	8.3	15.895	235.47	1153.7	949.2
24	48.852	9.3	18.930	237.79	1154.4	947.6
25	50.888	10.3	20.966	240.04	1155.1	946.0
26	52.923	11.3	23.007	242.21	1155.8	944.6
27	54.972	12.3	25.043	244.32	1156.5	943.1
28	57.008	13.3	27.079	246.36	1157.1	941.7
29	59.044	14.3	29.115	248.34	1157.7	940.3
30	61.080	15.3	31.143	250.27	1158.3	938.9
31	63.116	16.3	33.187	252.15	1158.8	937.5
32	65.152	17.3	35.223	253.98	1159.4	936.3
33	67.188	18.3	37.239	255.76	1159.9	935.0
34	69.224	19.3	39.295	257.50	1160.4	933.7
35	71.260	20.3	41.321	259.19	1161.0	932.6
36	73.296	21.3	43.367	260.85	1161.5	931.5
37	75.331	22.3	45.319	262.47	1162.0	930.3
38	77.367	23.3	47.397	264.06	1162.5	929.2
39	79.403	24.3	50.463	265.61	1163.0	928.2

TABLE SHOWING PROPERTIES OF SATURATED STEAM. — *Yaryan.**Continued.*

Absolute Pressure from Vacuum.		Above Atmosphere.		Tempera- ture.	Total Heat in British Units.	Heat of Vaporiza- tion or Latent Heat.
lbs. per Square In.	Inches of Mercury.	lbs. per Square In.	Inches of Mercury.	Deg. Fahr.		
40	81.439	25.3	51.499	267.13	1163.4	927.0
41	83.475	26.3	53.534	268.62	1163.9	926.0
42	85.511	27.3	55.583	270.08	1164.3	925.0
43	87.547	28.3	57.619	271.51	1164.8	924.0
44	89.583	29.3	59.655	272.91	1165.2	923.0
45	91.619	30.3	61.691	274.29	1165.6	922.0
46	93.655	31.3	63.727	275.65	1166.0	921.0
47	95.691	32.3	65.763	276.99	1166.4	920.1
48	97.727	33.3	67.799	278.30	1166.8	919.2
49	99.763	34.3	69.835	279.58	1167.2	918.3
50	101.799	35.3	71.871	280.85	1167.6	917.4
55	111.98	40.3	82.050	286.89	1169.4	913.1
60	122.16	45.3	92.230	292.51	1171.2	909.3
65	132.34	50.3	102.410	297.77	1172.7	905.5
70	142.52	55.3	112.59	302.71	1174.3	902.1
75	152.70	60.3	122.77	307.38	1175.7	898.8
80	162.88	65.3	132.95	311.80	1177.0	895.6
85	173.06	70.3	143.13	316.02	1178.3	892.5
90	185.24	75.3	153.31	320.04	1179.6	889.6
95	193.42	80.3	163.49	323.89	1180.7	886.7
100	203.06	85.3	173.67	327.58	1181.9	884.0
105	213.78	90.3	185.85	331.13	1182.9	881.3
110	223.96	95.3	194.03	334.56	1184.0	878.8
115	234.14	100.3	203.67	337.86	1185.0	876.3
120	244.32	105.3	214.39	341.05	1186.0	874.0
125	254.50	110.3	224.57	344.13	1186.9	871.7
130	264.68	115.3	234.75	347.12	1187.8	869.4
135	274.86	120.3	244.93	350.03	1188.7	867.3
140	285.04	125.3	255.11	352.85	1189.5	865.1
145	295.22	130.3	265.29	355.59	1190.4	863.2
150	305.40	135.3	275.47	358.26	1191.2	861.2
160	325.76	145.3	295.83	363.40	1192.8	857.4
170	345.82	155.3	316.19	368.29	1194.3	853.8
180	366.48	165.3	336.55	372.97	1195.7	850.3
190	386.84	175.3	356.91	377.44	1197.1	847.0
200	407.20	185.3	377.27	381.73	1198.4	843.8

PROPERTIES OF SATURATED STEAM AT PRESSURE FROM ONE POUND TO 200 POUNDS ON THE
 SQUARE INCH.

("Compend. of Mechanical Refrigeration.")

In lbs. sq. in.	PRESSURE ABSOLUTE.	HEAT IN DEGREES FAHR.			Volume, that of an equal weight of Water at its greatest density being 1.	Weight of one cubic foot in Decimals of a pound.	Specific Gravity, the atmo- sphere at 32° being 1.
		Temperature.	Latent Heat.	Total Heat.			
1	2.0375	102.0°	1,043.05	1,145.05	20.890	0.0029	0.037
5	10.1875	162.37	1,001.9	1,163.46	4.627	0.0135	0.167
10	20.375	193.29	979.6	1,172.89	2.429	0.0257	0.318
15	30.5625	213.07	965.85	1,178.92	1.669	0.0373	0.463
20	40.75	228.0	955.5	1,183.5	1.280	0.0487	0.604
25	50.9375	240.2	947.0	1,187.2	1.042	0.0598	0.742
30	61.125	250.4	939.9	1,190.3	.881	0.0707	0.877
35	71.3125	259.3	933.7	1,193.0	.764	0.0815	1.012
40	81.5	267.3	928.1	1,195.4	.676	0.0921	1.142
45	91.6875	274.4	923.2	1,197.6	.608	0.1025	1.272
50	101.875	281.0	918.6	1,199.6	.552	0.1129	1.402
55	112.0625	287.1	914.4	1,201.5	.506	0.1232	1.529
60	122.25	292.7	910.5	1,203.2	.467	0.1335	1.654
65	132.4375	298.0	906.8	1,204.8	.434	0.1436	1.779
			Dif. per lb.				
			—				
			9.26	2.82			
			4.93	1.50			
			3.47	1.05			
			2.8	0.8			
			2.3	0.7			
			2.0	0.6			
			1.7	0.5			
			1.5	0.4			
			1.4	0.4			
			1.3	0.4			
			1.2	0.4			
			1.1	0.3			
			1.1	0.3			

PROPERTIES OF SATURATED STEAM AT PRESSURE FROM ONE POUND TO 200 POUNDS ON THE
 SQUARE INCH.—(Continued.)

("Compend. of Mechanical Refrigeration.")

In lbs. in sq. in.	PRESSURE ABSOLUTE.		HEAT IN DEGREES FAHR.			Volume, that of an equal weight of Water at its greatest density being 1.	Weight of one cubic foot in Decimals of a pound.	Specific Gravity, the atmo- sphere at 32° being 1.
	Inches of Mercury at 32°.	Temperature.	Latent Heat.	Total Heat.	Dif. per lb.			
70	142.625	302.9°	903.4	1,206.3	0.3	406	0.1535	1.904
75	152.8125	307.5	900.3	1,207.8	0.3	381	0.1636	2.029
80	163.0	312.0	897.1	1,209.1	0.2	359	0.1736	2.151
85	173.1675	316.1	894.3	1,210.4	0.3	340	0.1833	2.271
90	183.375	320.2	891.4	1,211.6	0.2	323	0.1930	2.391
95	193.5625	324.1	888.7	1,212.8	0.3	307	0.2030	2.511
100	203.75	327.8	886.1	1,213.9	0.2	293	0.2127	2.631
105	213.9375	331.3	883.7	1,215.0	0.2	281	0.2224	2.751
110	224.135	334.6	881.4	1,216.0	0.2	269	0.2319	2.871
115	234.3125	338.0	879.0	1,217.0	0.2	259	0.2410	2.990
120	244.5	341.1	876.9	1,218.0	0.2	249	0.2503	3.105
125	254.6875	344.2	874.7	1,218.9	0.2	239	0.2598	3.227
130	264.875	347.2	872.6	1,219.8	0.2	231	0.2693	3.347
135	275.0625	350.0	870.7	1,220.7	0.1	223	0.2788	3.467

PROPERTIES OF SATURATED STEAM AT PRESSURE FROM ONE POUND TO 200 POUNDS ON THE SQUARE INCH.—(Continued.)

("Compend. of Mechanical Refrigeration.")

PRESSURE ABSOLUTE.		HEAT IN DEGREES FAHR.		Volume, that of an equal weight of Water at its greatest density, being 1.	Weight of one cubic foot in Decimals of a pound.	Specific Gravity, the atmos- phere at 32° being 1.
In lbs. on the sq. in.	In inches of Mercury at 32°.	Temperature.	Latent Heat.			
			Total Heat.			
140	285.25	352.9°	868.6	216	0.2883	3.582
145	295.4375	355.6	866.8	209	0.2978	3.697
150	305.625	358.3	864.9	203	0.3073	3.809
155	315.8125	360.9	863.1	196	0.3168	3.927
160	326.0	363.4	861.4	191	0.3263	4.042
165	336.1875	365.9	859.7	186	0.3353	4.157
170	346.375	368.2	858.1	181	0.3443	4.270
175	356.5625	370.6	856.4	176	0.3533	4.383
180	366.75	372.9	854.8	172	0.3623	4.495
185	376.9375	375.3	853.1	168	0.3713	4.607
190	387.125	377.5	851.6	164	0.3800	4.720
195	396.3125	379.7	850.1	160	0.3888	4.832
200	407.5	381.7	848.6	157	0.3973	4.945

HEAT OF COMBUSTION OF VARIOUS FUELS.

Fuel.	Air Chemically Consumed per lb. of Fuel.		Total Heat of Combustion of 1 lb. of Fuel.	Equivalent Evaporative Power, from and at 212° F., Water per lb. of Fuel.
	lbs.	Cub Ft. at 62° F.	Units.	lbs.
Asphalt	11.85	156	17,040	17.64
Coal of average composition	10.7	140	14,700	15.22
Coke	10.81	142	13,548	14.02
Lignite	8.85	146	13,108	13.57
Peat, desiccated	7.52	99	12,279	12.71
Peat, 30 per cent. moisture..	5.24	69	8,260	9.53
Peat charcoal, desiccated ..	9.9	130	12,325	12.76
Petroleum	14.33	188	20,411	21.13
Petroleum oils	17.93	235	27,531	28.50
Straw	4.26	56	8,144	8.43
Wood charcoal, desiccated ..	9.51	125	13,006	13.46
Wood, desiccated	6.09	80	10,974	11.36
Wood, 25 per cent. moisture	4.57	60	7,951	8.20
Coal gas, per cubic foot at 62° F.	—	—	630	0.70

PERCENTAGES, HANDY RULE.

Regard percentages as a decimal fraction, and with it multiply the whole number wanted. For example, 16 per cent. of 80 is $80 \times 0.16 = 12.8$.

SPECIFIC HEAT OF WATER AT VARIOUS TEMPERATURES.

Temperature. Deg. Fahr.	Specific Heat.	Units of Heat required to raise 1 lb. of Water from 32° F. to given Temperature.	Temperature. Deg. Fahr.	Specific Heat.	Units of Heat required to raise 1 lb. of Water from 32° F. to given Temperature.
32°	1'0000	0'000	248°	1'0177	217'449
50	1'0005	18'004	266	1'0204	235'791
68	1'0012	36'018	284	1'0232	254'187
86	1'0020	54'047	302	1'0262	272'628
104	1'0030	72'090	320	1'0294	291'132
122	1'0042	90'157	338	1'0328	309'690
140	1'0056	108'247	356	1'0364	328'320
158	1'0072	126'378	374	1'0401	347'004
176	1'0089	144'508	392	1'0440	365'760
194	1'0109	162'686	410	1'0481	384'588
212	1'0130	180'900	428	1'0524	403'488
230	1'0153	199'152	446	1'0568	422'478

SPECIFIC HEAT OF METALS, ETC.

METALS.			STONES (<i>contd.</i>)		
Antimony ..	..	0'0507	Chalk	..	0'2148
Bismuth	..	0'0308	Quicklime	..	0'2169
Brass	..	0'0939	Magnesian limestone		0'2174
Copper	..	0'0951			
Cymbal metal ..	..	0'086			
Gold	..	0'0324			
Iridium	..	0'1887			
Iron, cast	..	0'1298			
„ wrought	..	0'1138			
Lead	..	0'0314			
Manganese	..	0'1441			
Mercury, solid ..	..	0'0319			
„ liquid	..	0'0333			
Nickel	..	0'1086			
Platinum, sheet ..	..	0'0324			
„ spongy	..	0'0329			
Silver	..	0'0570			
Steel	..	0'1165			
Tin	..	0'0569			
Zinc	..	0'0959			
STONES.			CARBONACEOUS.		
Brickwork & masonry		0'20	Coal	..	0'2411
Marble	..	0'2129	Charcoal	..	0'2415
			Cannel ccke	..	0'2031
			Coke of pit coal ..	..	0'2008
			Anthracite	..	0'2017
			Graphite, natural ..	..	0'2019
			„ of blast furnaces	..	0'197
			SUNDRY.		
			Glass	..	0'1977
			Ice	..	0'504
			Phosphorus	..	0'2503
			Soda	..	0'2311
			Sulphate of lead ..	..	0'0872
			„ of lime	..	0'1966
			Sulphur	..	0'2026

SPECIFIC HEAT OF LIQUIDS.

Alcohol	0'6588	Turpentine	0'4160
Benzine	0'3932	Vinegar	0'9200
Mercury	0'0333	Water at 32° F. ..	1'0000
Olive oil	0'3096	„ 212° F. ..	1'0130
Sulphuric acid ..		„ 32° to 212° F. ..	1'0050
Density, 1'87 ..	0'3346	Wood spirit	0'6009
„ 1'30 ..	0'6614	Proof spirit	0'973

SPECIFIC HEAT OF GASES.

For Equal Weights. (Water = 1.)	At Constant Pressure.	At Constant Volume.
Air	0'2377	0'1688
Carbonic acid (CO ₂)	0'2164	0'1714
„ oxide (CO)	0'2479	0'1768
Hydrogen	3'4046	2'4096
Light carburetted hydrogen ..	0'5929	0'4683
Nitrogen	0'2440	0'1740
Oxygen	0'2182	0'1559
Steam, saturated	—	0'3050
Steam gas	0'4750	0'3700
Sulphurous acid	0'1553	0'1246

BRITISH THERMAL UNIT, OR HEAT UNIT.

Amount of heat necessary to raise the temperature of 1 lb. of water 1° by the Fabr. scale when at 39'4° (temp. of max. density). Mech. eq. 778 ft.-lbs.

FRENCH CALORIE, ENGLISH EQUIVALENT.

Unit of heat used on the Continent with the metrical system. Amount of heat required to raise 1 kilo. of water through 1° Cent. B.T.U. $\times 0'252$ = calorie. Calories $\times 3'968$ = B.T.U.

LOSS OF PRESSURE BY FRICTION OF COMPRESSED AIR IN PIPES.

F. A. Halsey.

Diameter of Pipe.	Cubic feet of Free Air compressed to a Gauge Pressure of 60 lbs. per Square Inch and passing through the Pipe per Minute.									
	50	75	100	125	150	200	250	300	400	600
	Loss of Pressure in Pounds per Square Inch for each 1,000 Feet of Straight Pipe.									
ins.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.	lbs.
1	10.40									
1½	2.63	5.90								
1½	1.22	2.75	4.89	7.65	11.00					
2	.35	.79	1.41	2.20	3.17	5.64	8.78			
2½	.14	.32	.57	.90	1.29	2.30	3.58	5.18	9.20	
3		.11	.20	.31	.44	.78	1.23	1.77	3.14	7.05
3½				.15	.21	.38	.59	.85	1.51	3.40
4						.20	.31	.45	.80	1.81
5							.10	.15	.26	.59
6										.23

FRICTION OF AIR IN TUBES.—*Unwin, "Min. Proceedings Inst. C.E."*

$$k = \text{coefficient of friction} = \frac{a}{v} + b, a \text{ and } b \text{ being constants, and}$$

$$v = \text{velocity of air feet per second.}$$

Diameter of tube, ft.	1.64	1.07	.83	.338	.266	.164
Value of a . . .	.00129	.00972	.01525	.03604	.0379	.04518
" b . . .	.00483	.0064	.00704	.00941	.00959	.01167
" k if $v = 100$	.00484	.0065	.00719	.00719	.00997	.01212

COEFFICIENTS FOR EFFLUX OF AIR FROM ORIFICES.
(*Molesworth*).

Vena contracta	0.98
Conical converging	0.9
Cylindrical rounded at ends	0.9
Cylindrical throughout	0.8
Thin plates	0.6

CENTRIFUGAL FANS.—*Molesworth*.

D = Diameter of fan.

V = Velocity of tips of fan in feet per second.

P = Pressure in lbs. per square inch.

$$V = \sqrt{P \times 97300}.$$

$$P = \frac{V^2}{97300}$$

POWER REQUIRED FOR FANS.—*Molesworth*.

P = Pressure of blast in lbs. per square inch.

A = Area of the sum of the tuyeres in square inches.

V = Velocity of tips of fan in feet per second.

HP = Indicated horse-power required.

$$HP = 0.000016 V^2 A P.$$

PROPORTIONS OF FANS.—*Molesworth*.

$$\text{Length of vanes} = \frac{D}{4}. \quad \text{Width of vanes} = \frac{D}{4}.$$

$$\text{Diameter of inlet} = \frac{D}{2}. \quad \text{Eccentricity of fan} = \frac{D}{10}.$$

$$\text{Length of spindle journal} = 4 \text{ diameters of spindle.}$$

HYDRAULIC RAM PROPORTIONS OF THE SUPPLY PIPES AND DELIVERY PIPES TO THE NUMBER OF GALLONS.—(*Hutton.*)

Number of gallons to be raised in 24 hours . . .	500	1,000	2,500	4,000	6,000
Diameter of fall or supply pipe, in inches	1½	2	2½	3	4
Diameter of rising main or delivery pipe, in inches .	¾	1	1½	2	2

EFFICIENCY OF HYDRAULIC RAMS.—(*Hutton.*)

Number of times the height to which the water to be raised is contained in the fall .	4	5	6	7	8	9	10	11	12	13	14	15	16	18	19	20	25
Efficiency per cent. . .	75	72	68	62	57	53	48	43	38	35	32	28	23	17	15	12	0

POWER REQUIRED TO DRIVE CENTRIFUGAL PUMPS.

Diameter of suction and delivery pipes in inches.	Quantity of water delivered per minute, in gallons.	Horse-power required for every foot in height the water is raised.
1	16	0'01
2	50	0'02
3	100	0'05
4	200	0'08
5	300	0'16
6	500	0'25
7	700	0'35
8	800	0'40
9	1,000	0'50
10	1,500	0'75
11	1,800	1'0
12	2,000	1'01
13	2,300	1'08
14	2,500	1'20
15	3,000	1'31
16	3,500	1'60
17	3,800	1'75
18	4,200	2'0

**TABLE OF POWER REQUIRED TO RAISE WATER FROM DEEP
WELLS.—(Appleby.)**

Gallons of water raised per hour .	200	350	500	650	800	1,000
Height of lift for one man working on crank, in feet	90	52	36	28	22	18
Height of lift for one donkey working on gin, in feet	180	102	72	56	45	36
Height of lift for one horse working on gin, in feet	630	357	252	196	154	126
Height of lift for one horse-power steam-engine, in feet	990	561	396	308	242	198

**TABLE GIVING QUANTITY OF WATER DISCHARGED PER
MINUTE BY BARREL PUMPS.—(Hutton.)**

Diam. of pump.	Length of stroke.	Single barrel.		Double barrel.		Treble barrel.	
		30 strokes per min.	40 strokes per min.	30 strokes per min.	40 strokes per min.	30 strokes per min.	40 strokes per min.
Inches.	Inches.	Galls.	Galls.	Galls.	Galls.	Galls.	Galls.
1½	9	1½	2½	3½	4½	4½	6½
2	9	3	4	6	8	9	12
2½	9	4½	6½	9½	12	14	19
3	9	6½	9	13½	18	20	27
3½	9	9½	12½	18½	25	28	37
4	9	12½	16	24½	32	36	48
4½	9	15½	20½	32	42	46	62
5	9	19	25½	38	50	57	76
5½	9	23½	32	46½	62	69	92
6	9	27½	37	55	73	82	110
2	10	3½	4½	6	9	10	13
2½	10	5½	7	10	14	15	22
3	10	7½	10	15	20	22	30
3½	10	10½	13½	20	27	32	42
4	10	13½	18	27	36	40	54
4½	10	17	23	34	45	52	68
5	10	22	28	42	56	63	84
5½	10	25½	34	51	68	77	102
6	10	30½	40	62	82	92	122
2	12	4	5	8	10	12	16
2½	12	6½	8	12	17	19	25
3	12	9	12	18	24	27	36
3½	12	12½	16	24	33	37	50
4	12	16½	22	32	43	49	65
4½	12	20½	27	42	55	62	82
5	12	25½	33	50	68	76	100
5½	12	30½	42	62	82	92	123
6	12	36½	49	73	97	110	146
6½	12	43	57	86	114	129	172
7	12	50	66	100	134	149	199
7½	12	57	76	114	152	171	229
8	12	65	87	130	174	195	262
9	12	82	110	165	220	246	330
10	12	102	134	202	268	303	404
12	12	146	195	294	390	440	588

DIAMETERS, AREAS, AND DISPLACEMENTS.

Worthington Pumping Engine Company.

Diameter.	Area.	Displacement in Imperial Gallons per foot of Travel.	Diameter.	Area.	Displacement in Imperial Gallons per foot of Travel.	Diameter.	Area.	Displacement in Imperial Gallons per foot of Travel.
1	0122	0005	7 1/4	41.28	1783	18 1/4	261.5	11297
1 1/4	0490	0021	7 1/2	44.17	1908	18 1/2	268.8	11612
1 1/2	1104	0047	7 3/4	47.17	2037	18 3/4	276.1	11927
1 3/4	1963	0084	8	50.26	2171	19	283.5	12247
2	3068	0132	8 1/4	53.45	2309	19 1/4	291.0	12571
2 1/4	4417	0190	8 1/2	56.74	2451	19 1/2	298.6	12900
2 1/2	6013	0259	8 3/4	60.13	2597	19 3/4	306.3	13232
2 3/4	7854	0339	9	63.61	2747	20	314.1	13569
3	9940	0429	9 1/4	67.20	2903	20 1/4	330.0	14256
3 1/4	1227	0530	9 1/2	70.88	3062	20 1/2	346.3	14960
3 1/2	1484	0641	9 3/4	74.66	3225	21	363.0	15681
3 3/4	1767	0763	10	78.54	3393	21 1/4	380.1	16420
4	2073	0895	10 1/4	82.51	3564	21 1/2	397.6	17176
4 1/4	2405	1038	10 1/2	86.59	3740	22	415.4	17945
4 1/2	2761	1192	10 3/4	90.76	3920	22 1/2	433.7	18735
4 3/4	3141	1356	11	95.03	4105	23	452.3	19539
5	3546	1531	11 1/4	99.40	4294	23 1/4	471.4	20364
5 1/4	3976	1717	11 1/2	103.8	4484	23 1/2	490.8	21202
5 1/2	4430	1913	11 3/4	108.4	4682	24	510.7	22062
5 3/4	4908	2120	12	113.0	4881	24 1/4	530.9	22935
6	5411	2337	12 1/4	117.8	5088	24 1/2	551.5	23824
6 1/4	5939	2565	12 1/2	122.7	5300	25	572.5	24732
6 1/2	6491	2804	12 3/4	127.6	5512	25 1/2	593.9	25656
6 3/4	7068	3053	13	132.7	5732	26	615.7	26598
7	7669	3313	13 1/4	137.8	5952	26 1/2	637.9	27567
7 1/4	8295	3583	13 1/2	143.1	6182	27	660.5	28533
7 1/2	8946	3864	13 3/4	148.4	6410	27 1/2	683.4	29522
7 3/4	9621	4156	14	153.9	6649	28	706.8	30533
8	1032	4458	14 1/4	159.4	6886	28 1/2	754.8	32607
8 1/4	1104	4769	14 1/2	165.1	7132	29	804.2	34741
8 1/2	1179	5193	14 3/4	170.8	7388	29 1/2	855.3	36949
8 3/4	1256	5426	15	176.7	7633	30	907.9	39221
9	1418	6125	15 1/4	182.6	7888	30 1/2	962.1	41562
9 1/4	1590	6868	15 1/2	188.6	8147	31	1017.9	43973
9 1/2	1772	7655	15 3/4	194.8	8415	31 1/2	1075.2	46448
9 3/4	1963	8480	16	201.0	8683	32	1134.1	48993
10	2154	9348	16 1/4	207.3	8955	32 1/2	1194.6	51607
10 1/4	2375	1026	16 1/2	213.8	9236	33	1256.6	54259
10 1/2	2596	1121	16 3/4	220.3	9516	33 1/2	1320.3	57037
10 3/4	2827	1221	17	226.9	9802	34	1385.4	59849
11	3067	1325	17 1/4	233.7	10095	34 1/2	1452.2	62735
11 1/4	3318	1433	17 1/2	240.5	10389	35	1520.5	65686
11 1/2	3578	1545	17 3/4	247.4	10687	35 1/2	1590.4	68688
11 3/4	3848	1662	18	254.4	10990	36	1661.9	71794

In estimating the capacity of Worthington (and other duplex) Pumps (*i.e.*, the delivery in gallons per minute or per hour) at a given rate of piston speed, it should be noted that they have *two* double-acting water plungers: the capacity, therefore, is double that of any ordinary double-acting pump of same size, or four times as large as a single-acting pump.

PRESSURE OF WATER.

Worthington Pumping Engine Company.

The pressure of water in pounds per square inch for every foot in height to 270 ft. By this Table, from the pounds pressure per square inch the feet head is readily obtained, and *vice versa*.

Feet Head.	Pressure per sq. in.	Feet Head.	Pressure per sq. in.	Feet Head.	Pressure per sq. in.	Feet Head.	Pressure per sq. in.	Feet Head.	Pressure per sq. in.	Feet Head.	Pressure per sq. in.
1	0.43	46	19.92	91	39.42	136	58.91	181	78.40	226	97.90
2	0.86	47	20.35	92	39.85	137	59.34	182	78.84	227	98.33
3	1.30	48	20.79	93	40.28	138	59.77	183	79.27	228	98.76
4	1.73	49	21.22	94	40.72	139	60.21	184	79.70	229	99.20
5	2.16	50	21.65	95	41.15	140	60.64	185	80.14	230	99.63
6	2.59	51	22.09	96	41.58	141	61.07	186	80.57	231	100.06
7	3.03	52	22.52	97	42.01	142	61.51	187	81.00	232	100.49
8	3.46	53	22.95	98	42.45	143	61.94	188	81.43	233	100.93
9	3.89	54	23.39	99	42.88	144	62.37	189	81.87	234	101.36
10	4.33	55	23.82	100	43.31	145	62.81	190	82.30	235	101.79
11	4.76	56	24.26	101	43.75	146	63.24	191	82.73	236	102.23
12	5.20	57	24.69	102	44.18	147	63.67	192	83.17	237	102.66
13	5.63	58	25.12	103	44.61	148	64.10	193	83.60	238	103.09
14	6.06	59	25.55	104	45.05	149	64.54	194	84.03	239	103.53
15	6.49	60	25.99	105	45.48	150	64.97	195	84.47	240	103.96
16	6.93	61	26.42	106	45.91	151	65.40	196	84.90	241	104.39
17	7.36	62	26.85	107	46.34	152	65.84	197	85.33	242	104.83
18	7.79	63	27.29	108	46.78	153	66.27	198	85.76	243	105.26
19	8.22	64	27.72	109	47.21	154	66.70	199	86.20	244	105.69
20	8.66	65	28.15	110	47.64	155	67.14	200	86.63	245	106.13
21	9.09	66	28.58	111	48.08	156	67.57	201	87.07	246	106.56
22	9.53	67	29.02	112	48.51	157	68.00	202	87.50	247	106.99
23	9.96	68	29.45	113	48.94	158	68.43	203	87.93	248	107.43
24	10.39	69	29.88	114	49.38	159	68.87	204	88.36	249	107.86
25	10.82	70	30.32	115	49.81	160	69.31	205	88.80	250	108.29
26	11.26	71	30.75	116	50.24	161	69.74	206	89.23	251	108.73
27	11.69	72	31.18	117	50.68	162	70.17	207	89.66	252	109.16
28	12.12	73	31.62	118	51.11	163	70.61	208	90.10	253	109.59
29	12.55	74	32.05	119	51.54	164	71.04	209	90.53	254	110.03
30	12.99	75	32.48	120	51.98	165	71.47	210	90.96	255	110.46
31	13.42	76	32.92	121	52.41	166	71.91	211	91.39	256	110.89
32	13.86	77	33.35	122	52.84	167	72.34	212	91.83	257	111.32
33	14.29	78	33.78	123	53.28	168	72.77	213	92.26	258	111.76
34	14.72	79	34.21	124	53.71	169	73.20	214	92.69	259	112.19
35	15.16	80	34.65	125	54.15	170	73.64	215	93.13	260	112.62
36	15.59	81	35.08	126	54.58	171	74.07	216	93.56	261	113.06
37	16.02	82	35.52	127	55.01	172	74.50	217	93.99	262	113.49
38	16.45	83	35.95	128	55.44	173	74.94	218	94.43	263	113.92
39	16.89	84	36.39	129	55.88	174	75.37	219	94.86	264	114.36
40	17.32	85	36.82	130	56.31	175	75.80	220	95.30	265	114.79
41	17.75	86	37.25	131	56.74	176	76.23	221	95.73	266	115.22
42	18.19	87	37.68	132	57.18	177	76.67	222	96.16	267	115.66
43	18.62	88	38.12	133	57.61	178	77.10	223	96.59	268	116.09
44	19.05	89	38.55	134	58.04	179	77.53	224	97.03	269	116.52
45	19.49	90	39.98	135	58.48	180	77.97	225	97.46	270	116.96

DIMENSIONS, ETC., OF STANDARD WROUGHT-IRON PIPES.

Nominal size in inches.	Inside diam. in inches.	Inside diam. extra strong in inches.	Inside diam. extra double strong in inches.	External diam. in inches.	Internal diam. in inches.	External circumference in inches.	Length in feet per square foot outside surface.	Weight per foot in lbs.	Number of threads per inch.
$\frac{1}{8}$	0.27	0.20	—	0.40	0.0572	1.272	9.44	0.24	27
$\frac{1}{4}$	0.36	0.29	—	0.54	0.1041	1.696	7.075	0.42	18
$\frac{3}{8}$	0.49	0.42	—	0.67	0.1916	2.121	5.657	0.56	18
$\frac{1}{2}$	0.62	0.54	0.24	0.84	0.3048	2.652	4.502	0.85	14
$\frac{3}{4}$	0.82	0.73	0.42	1.05	0.5333	3.299	3.637	1.12	14
1	1.04	0.95	0.58	1.31	0.8627	4.134	2.903	1.67	11 $\frac{1}{2}$
1 $\frac{1}{4}$	1.38	1.27	0.88	1.66	1.496	5.215	2.301	2.25	11 $\frac{1}{2}$
1 $\frac{1}{2}$	1.61	1.49	1.08	1.90	2.038	5.969	2.01	2.69	11 $\frac{1}{2}$
2	2.06	1.93	1.49	2.37	3.355	7.461	1.611	3.66	11 $\frac{1}{2}$
2 $\frac{1}{2}$	2.46	2.31	1.75	2.87	4.783	9.032	1.328	5.77	8
3	3.06	2.89	2.28	3.50	7.388	10.996	1.091	7.54	8
3 $\frac{1}{2}$	3.54	3.35	2.71	4.00	9.887	12.566	0.955	9.05	8
4	4.02	3.81	3.13	4.50	12.730	14.137	0.849	10.72	8
5	5.04	—	—	5.56	19.990	17.475	0.629	14.56	8
6	6.00	—	—	6.62	28.889	20.813	0.577	18.77	8
7	7.02	—	—	7.62	38.737	23.954	0.505	23.41	8
8	7.98	—	—	8.62	50.039	27.096	0.444	28.35	8
9	9.00	—	—	9.68	63.633	30.433	0.394	34.07	8
10	10.01	—	—	10.75	78.838	33.772	0.355	40.64	8

STRENGTH OF ICE.

Ice of a thickness of $1\frac{1}{2}$ inch will support a man; 4 inches in thickness will support cavalry; 5 inches in thickness will support an 84-pound cannon; 10 inches in thickness will support a multitude; 18 inches in thickness will support a railroad train.

FRICTION IN PIPES.

Friction loss in pounds pressure for each 100 feet in length of cast-iron pipe discharging the stated quantities per minute.—(*G. A. Ellis, C.E.*)

Imperial Gallons.	Sizes of pipes, inside diameters.															U.S. Gallons.
	3"	1"	1½"	1½"	2"	2½"	3"	4"	6"	8"	10"	12"	14"	16"	18"	
4	3'3	0'84	0'31	0'12												5
8	13'0	3'16	1'05	0'47	0'12											10
12	28'7	6'98	2'38	0'97	0'27											15
16	50'4	12'30	4'07	1'66	0'42											20
20	78'0	19'00	6'40	2'62	0'67	0'21	0'10									25
25		27'50	9'15	3'75	0'91	0'30	0'12									30
29		37'00	12'4	5'05	1'26	0'42	0'14									35
33		48'00	16'1	6'52	1'60	0'51	0'17									40
37			20'2	8'15	2'01	0'62	0'27									45
41				10'00	2'44	0'81	0'35	0'09								50
45				12'40	3'32	1'80	0'74	0'21	0'05							55
50				14'9	4'46	3'20	1'31	0'33	0'07							60
55				17'40	5'32	4'89	1'99	0'51	0'10	0'02						65
60				21'2	6'19	7'00	2'85	0'69	0'10	0'03						70
65				28'1	8'15	9'46	3'85	0'95	0'14	0'05						75
70				37'5	12'47	12'47	5'02	1'22	0'17	0'05	0'01					80
75				47'7	18'56	10'56	7'76	1'89	0'26	0'07	0'03					85
80					28'06	11'20	2'66	2'66	0'37	0'09	0'04	0'005				90
83					33'41	15'20	3'05	3'05	0'50	0'11	0'05	0'007				95
88					42'96	19'50	4'73	4'73	0'65	0'15	0'06	0'01				100
93						25'00	6'01	6'01	0'81	0'20	0'08	0'02				105
98						30'80	7'43	7'43	0'96	0'25	0'09	0'04	0'017	0'009	0'005	110
103							14'32	14'32	2'21	0'33	0'18	0'08	0'036	0'019	0'011	115
108									3'88	0'53	0'32	0'13	0'062	0'036	0'028	120
113										0'94	0'49	0'20	0'091	0'046	0'028	125
118										1'46	0'70	0'29	0'135	0'071	0'040	130
123										2'09	0'95	0'38	0'181	0'095	0'054	135
128											1'23	0'63	0'234	0'123	0'071	140
133												0'77	0'297	0'153	0'086	145
138												0'63	0'302	0'188	0'107	150
143												0'77	0'302	0'188	0'107	155
148												1'11	0'315	0'267	0'150	160
153													0'697	0'365	0'204	165
158													0'910	0'472	0'263	170
163													0'910	0'472	0'263	175
168													0'910	0'472	0'263	180
173													0'910	0'472	0'263	185
178													0'910	0'472	0'263	190
183													0'910	0'472	0'263	195
188													0'910	0'472	0'263	200
193													0'910	0'472	0'263	205
198													0'910	0'472	0'263	210
203													0'910	0'472	0'263	215
208													0'910	0'472	0'263	220
213													0'910	0'472	0'263	225
218													0'910	0'472	0'263	230
223													0'910	0'472	0'263	235
228													0'910	0'472	0'263	240
233													0'910	0'472	0'263	245
238													0'910	0'472	0'263	250
243													0'910	0'472	0'263	255
248													0'910	0'472	0'263	260
253													0'910	0'472	0'263	265
258													0'910	0'472	0'263	270
263													0'910	0'472	0'263	275
268													0'910	0'472	0'263	280
273													0'910	0'472	0'263	285
278													0'910	0'472	0'263	290
283													0'910	0'472	0'263	295
288													0'910	0'472	0'263	300
293													0'910	0'472	0'263	305
298													0'910	0'472	0'263	310
303													0'910	0'472	0'263	315
308													0'910	0'472	0'263	320
313													0'910	0'472	0'263	325
318													0'910	0'472	0'263	330
323													0'910	0'472	0'263	335
328													0'910	0'472	0'263	340
333													0'910	0'472	0'263	345
338													0'910	0'472	0'263	350
343													0'910	0'472	0'263	355
348													0'910	0'472	0'263	360
353													0'910	0'472	0'263	365
358													0'910	0'472	0'263	370
363													0'910	0'472	0'263	375
368													0'910	0'472	0'263	380
373													0'910	0'472	0'263	385
378													0'910	0'472	0'263	390
383													0'910	0'472	0'263	395
388													0'910	0'472	0'263	400
393													0'910	0'472	0'263	405
398													0'910	0'472	0'263	410
403													0'910	0'472	0'263	415
408													0'910	0'472	0'263	420
413													0'910	0'472	0'263	425
418													0'910	0'472	0'263	430
423													0'910	0'472	0'263	435
428													0'910	0'472	0'263	440
433													0'910	0'472	0'263	445
438													0'910	0'472	0'263	450
443													0'910	0'472	0'263	455
448													0'910	0'472	0'263	460
453													0'910	0'472	0'263	465
458													0'910	0'472	0'263	470
463													0'910	0'472	0'263	475
468													0'910	0'472	0'263	480
473													0'910	0'472	0'263	485
478													0'910	0'472	0'263	490
483													0'910	0'472	0'263	495
488													0'910	0'472	0'263	500
493													0'910	0'472	0'263	505
498													0'910	0'472	0'263	510

**COMPARISON BETWEEN THE SCALES OF CENTIGRADE AND
FAHRENHEIT THERMOMETERS.**

Centigrade.	Fahrenheit.	Centigrade.	Fahrenheit.
-73	-100.0	-24	-11.2
-72	-97.6	-23	-9.3
-71	-95.8	-22	-7.6
-70	-94.0	-21	-5.8
-69	-92.2	-20	-4.0
-68	-90.4	-19	-2.2
-67	-88.6	-18	-0.4
-66	-86.8	-17	+ 1.4
-65	-85.0	-16	+ 3.2
-64	-83.2	-15	+ 5.0
-63	-81.4	-14	+ 6.8
-62	-79.6	-13	+ 8.6
-61	-77.8	-12	+ 10.4
-60	-76.0	-11	+ 12.2
-59	-74.2	-10	+ 14.0
-58	-72.4	- 9	+ 15.8
-57	-70.7	- 8	+ 17.6
-56	-68.8	- 7	+ 19.4
-55	-67.0	- 6	+ 21.2
-54	-65.3	- 5	+ 23.0
-53	-63.4	- 4	+ 24.8
-52	-61.6	- 3	+ 26.6
-51	-59.8	- 2	+ 28.4
-50	-58.0	- 1	+ 30.2
-49	-56.2	- 0	+ 32.0
-48	-54.4	+ 1	+ 33.8
-47	-52.6	+ 2	+ 35.6
-46	-50.8	+ 3	+ 37.4
-45	-49.0	+ 4	+ 39.2
-44	-47.2	+ 5	+ 41.0
-43	-45.4	+ 6	+ 42.8
-42	-43.6	+ 7	+ 44.6
-41	-41.8	+ 8	+ 46.4
-40	-40.0	+ 9	+ 48.2
-39	-38.2	+ 10	+ 50.0
-38	-36.4	+ 11	+ 51.8
-37	-34.6	+ 12	+ 53.6
-36	-32.8	+ 13	+ 55.4
-35	-31.0	+ 14	+ 57.2
-34	-29.2	+ 15	+ 59.0
-33	-27.4	+ 16	+ 60.8
-32	-25.6	+ 17	+ 62.6
-31	-23.8	+ 18	+ 64.4
-30	-22.0	+ 19	+ 66.2
-29	-20.2	+ 20	+ 68.0
-28	-18.4	+ 21	+ 69.8
-27	-16.6	+ 22	+ 71.6
-26	-14.8	+ 23	+ 73.4
-25	-13.0	+ 24	+ 75.2

TO CONVERT DEGREES CENTIGRADE OR REAUMUR INTO DEGREES FAHRENHEIT, ETC.

Let F = degrees Fahrenheit ; C = degrees Centigrade ;
and R = degrees Reaumur.

$$F = \frac{9C}{5} + 32 \qquad F = \frac{9R}{4} + 32 \qquad C = \frac{5(F - 32)}{9}$$

$$R = \frac{4(F - 32)}{9}$$

USEFUL INFORMATION.

A gallon of water contains 231 cubic in., and weighs $8\frac{1}{3}$ lbs. (U.S. standard).

A cubic foot of water contains $6\frac{1}{4}$ gallons, and weighs $62\frac{1}{2}$ lbs.

The friction of liquids and vapours through pipes increases as the square of the velocity.

Sensible heat of a liquid is the amount indicated by the thermometer when immersed in it.

Specific heat is the amount of heat absorbed to produce sensible heat.

Latent heat is the amount of heat required for the conversion into vapour after a liquid has reached its boiling-point.

The latent heat of vapour is given off whilst condensing to a liquid ; the sensible heat is retained.

One U.S. gallon = 0·133 cubic ft. ; 0·83 imperial gallon ; 3·8 litres.

An imperial gallon contains 277·274 cubic in. ; 0·16 cubic ft. ; 10·00 lbs. ; 1·2 U.S. gallons ; 4·537 litres.

A cubic inch of water = 0·03607 lb. ; 0·003607 imperial gallon ; 0·004329 U.S. gallon.

A cubic foot of water = 6·25 imperial gallons ; 7·48 U.S. gallons ; 28·375 litres ; 0·0283 cubic metre ; 62·35 lbs. ; 0·557 cwt. ; 0·028 ton.

A lb. of water = 27·72 cubic in. ; 0·10 imperial gallon ; 0·83 U.S. gallon ; 0·4537 kilo.

One cwt. of water = 11·2 imperial gallons ; 13·44 U.S. gallons ; 1·8 cubic ft.

A ton of water = 35·84 cubic ft.; 224 imperial gallons; 298·8 U.S. gallons; 1,000 litres (about); 1 cubic metre (about).

A litre of water = 0·22 imperial gallon; 0·264 U.S. gallon; 61 cubic in.; 0·0353 cubic ft.

A cubic metre of water = 220 imperial gallons; 264 U.S. gallons; 1·308 cubic yard; 61·028 cubic in.; 35·31 cubic ft.; 1,000 kilos; 1 ton (nearly); 1,000 litres.

A kilo of water = 2·204 lbs.

A vedros of water = 2·7 imperial gallons.

An eimer of water = 2·7 imperial gallons.

A pood of water = 3·6 imperial gallons.

A Russian fathom = 7 ft.

One atmosphere = 1·054 kilos per square in.

One ton of petroleum = 275 imperial gallons (nearly); 360 U.S. gallons (nearly).

A column of water 1 ft. in height = 0·434 lb. pressure per square in.

A column of water 1 metre in height = 1·43 lb. pressure per square in.

One lb. pressure per square in. = 2·31 ft. of water in height.

One U.S. gallon of crude petroleum = 6·5 lbs. (about).

According to Prof. Siebel, about ten B.T.U. of heat will pass through a square foot of ice 1 inch thick in one hour for every degree Fahrenheit difference between the temperatures on either side of the ice sheet.

A cubic foot of ice weighs approximately 57·5 lbs.

A cubic foot of water frozen at 32° makes 1·0855 cubic ft. of ice.

One French horse-power = 75 kilogrammetres (542·533 foot-pounds) per second.

One force de cheval = 0·986337 horse-power.

One horse-power = 1·01385 force de cheval.

Indicated French horse-power = 3·49 D²PRS.

D = dia. of cy. in metres, S = length of stroke in metres, R = number of revs. per minute, and P = average pressure on piston in kilogs. per square centimetre.

FRACTIONS OF AN INCH AND DECIMAL EQUIVALENTS.

Fractions.	Inch.	Fractions.	Inch.	Fractions.	Inch.
1-32	0'03125	3-8	0'375	23-32	0'71875
1-16	0'0625	13-32	0'40625	3-4	0'75
3-32	0'09375	7-16	0'4375	25-32	0'78125
1-8	0'125	15-32	0'46875	13-16	0'8125
5-32	0'15625	1-2	0'5	27-32	0'84375
3-16	0'1875	17-32	0'53125	7-8	0'875
7-32	0'21875	9-16	0'5625	29-32	0'90625
1-4	0'25	19-32	0'59375	15-16	0'9375
9-32	0'28125	5-8	0'625	31-32	0'96875
5-16	0'3125	21-32	0'65625		
11-32	0'34375	11-16	0'6875		

COMPARISON OF BRITISH MEASURES WITH U.S.

United States Standard.

British Standard.

1 gill	=	0'833565	imperial gill.
4 gills	=	1 pint	= 0'833565 „ pint.
2 pints	=	1 quart	= 0'833565 „ quart.
4 quarts	=	1 gallon	= 0'833565 „ gallon.

An imperial gallon = 4'5435 litres = 1'19968 U.S. standard gallons.

An imperial gallon contains (Act of Parliament, 1878) 10 lbs. of water at a temperature of 62° Fahr. Its accepted volume is 277'274 cubic in.

SPECIFIC GRAVITIES OF GASES.

Gas at 32° and below one atmosphere.	Specific gravity.	Cubic feet in 1 lb.
Air	1'000	12'38
Ammonia ..	0'589	21'01
Carbonic acid ..	1'529	8'10
Chlorine ..	2'440	5'07
Nitrogen ..	0'978	12'72
Oxygen	1'105	11'20

INFORMATION REQUIRED BY MANUFACTURERS TO ENABLE
THEM TO ESTIMATE FOR THE COST OF A REFRIGERATING
PLANT.

1. The length, breadth, and height of the cellars, rooms, or stores to be refrigerated. If the ceiling or roof is vaulted, the height to the centre and spring of the arch will be required. Full particulars of the means of insulation adopted, or, if none exist, of the materials from which the chambers are built.

2. Whether it is desired to refrigerate on the direct expansion, on the brine circulation, or on the cold-air system.

3. The temperature desired to be maintained in each chamber or store.

4. The nature of the substance which it is desired to refrigerate.

5. In the case of a packing-house, or an abattoir, the largest number of carcasses to be cooled daily, and their average weight.

6. In the case of a freezing chamber for beef, mutton, or other produce, the number of carcasses, etc., to be frozen in each 24 hours, and their average weight.

7. When a liquid is to be cooled, the number of gallons, or barrels, to be dealt with per hour, and from what temperature down.

8. The nature, quantity, and temperature of the water supply available for use.

9. Rough dimensioned plan of the establishment, showing the most convenient spot to locate the refrigerating machine.

INFORMATION REQUIRED BY MANUFACTURERS TO ENABLE
THEM TO ESTIMATE FOR THE COST OF AN ICE-MAKING
PLANT.

1. Number of tons of ice that it is desired to produce per 24 hours.

2. If clear, crystal, transparent ice is required, or whether opaque ice will do for the purpose.

3. The nature, quantity, and temperature of the supply of water procurable for use.

4. Whether there is an available source of steam supply on the premises ; and if spare steam-power, then how many horse-powers could be utilised.

5. When the installation is to be erected in existing buildings, a rough dimensioned plan of same.

6. Where an estimate of cost of making ice is required, price and quality of fuel ; wages of engine-drivers, stokers, and common labourers, for 12 hours day work, and for 12 hours night work ; if water has to be bought, cost of same.

VARIOUS HORSE-POWERS IN USE.

	Kilogrammetres per second.	Foot-pounds per minute.	Ratio to British H.P.
Austria	76'119	33,034	1'001
Baden	75'000	32,552	0'986
France	75'000	32,552	0'986
Great Britain ..	76'041	33,000	1'000
Hanover	75'361	32,705	0'990
Prussia	75'325	32,689	0'990
Saxony	75'045	32,568	0'986
Wurtemberg ..	75'240	32,637	0'988

EXPANSION IN STEAM PIPES.

The expansion and contraction of steam pipes is about 1 inch in 50 feet by reason of temperature variations. This expansion and contraction may be provided for in the case of long lengths of pipe between fixed abutments, by spring bends or lengths, or by expansion sockets. In the latter case, guard bolts should be fitted to prevent the pipes from being drawn out of the sockets.

Works by A. J. Wallis-Tayler, A.M.Inst.C.E.

REFRIGERATION, COLD STORAGE, AND ICE-MAKING. A Practical Treatise on the Art and Science of Refrigeration. Medium 8vo, 611 pages, 361 illustrations, cloth, 15s. *net*.

REFRIGERATING AND ICE-MAKING MACHINERY. A Descriptive Treatise for the use of Persons employing Refrigerating and Ice-making Installations, and others. Third Edition. Revised and Enlarged. Crown 8vo, 320 pages, 105 illustrations, 7s. 6d., cloth.

POCKET-BOOK OF REFRIGERATION AND ICE-MAKING. Small crown 8vo, cloth, 184 pages, 31 illustrations, 3s. 6d. *net*.

TEA MACHINERY AND TEA FACTORIES. A Descriptive Treatise on the Mechanical Appliances required in the Cultivation of the Tea Plant and the Preparation of Tea for the Market. Medium 8vo, 468 pages, with 218 illustrations, cloth, 25s. *net*.

AËRIAL OR WIRE-ROPE TRAMWAYS: their Construction and Management. Crown 8vo, 224 pages, with 81 illustrations, 7s. 6d., cloth.

MODERN CYCLES. A Practical Handbook on their Construction and Repair. Crown 8vo, 356 pages, with 304 illustrations, 10s. 6d., cloth.

MOTOR-CARS, OR POWER-CARRIAGES FOR COMMON ROADS. Crown 8vo, about 200 pages, 70 illustrations, 4s. 6d., cloth.

London: CROSBY LOCKWOOD & SON, Stationers' Hall Court, E.C.

SUGAR MACHINERY. A Descriptive Treatise devoted to the Machinery and Apparatus used in the Manufacture of Cane and Beet Sugars. Crown 8vo, 314 pages, 52 illustrations. Price 5s., cloth.

BEARINGS AND LUBRICATIONS. A Handbook for every user of Machinery. Crown 8vo, 220 pages, 78 illustrations. Price 3s. 6d., cloth.

London: WM. RIDER & SON, Ltd., 14, Bartholomew Close, E.C.

INDEX.



ABSORPTION machines, 2-11
 Air co-efficients for efflux of, from orifices, 163
 Air condensers, open, 33
 Air, compressed, loss of pressure by friction of, in pipes, 162
 Air, determination of moisture in, 75, 76
 Allowance per ton capacity to be made when selecting machinery for refrigerating purposes, 33
 Ammonia and carbonic acid machines, comparative tests of, 22
 anhydrous, boiling point and latent heat of, 36, 37
 apparatus, leaks in, 145
 compression machines, management of, 141-144
 compression plant, efficiency of, under different conditions, 61
 gas, cubic feet of, per minute to produce one ton of refrigeration per day, 75
 gas, refrigerating effect of one cubic foot at different condensing and suction (back) pressures in B.T. units, 59
 gas, saturated, properties of, 44
 gas, temperatures to which raised by compression, 41-44
 gas, volume of, one pound at various pressures and temperatures, 45-47
 gas, volume of, at high temperatures, 48

Ammonia, saturated, Wood's table of, 49-58
 solubility of, in water at different temperatures, 38-40, 143
 solubility of, in water at different temperatures and pressures, 39
 solutions, yield of anhydrous ammonia from, 41
 useful efficiency of, 50
 Amount of refrigerating pipes necessary for chilling storing and freezing chambers, 69-72
 refrigerating required in cold storage, 69-72
 Analyser, The, 43, 44
 Anhydrous ammonia, boiling point and latent heat of, 36, 37
 ammonia, yield of, from ammonia solutions, 41
 Apparatus, ammonia, leaks in, 145
 refrigerating, 2-11
 Application of the entropy or theta-phi diagram to refrigerating machines, 11-20
 Approximate allowance per ton capacity when selecting machine for refrigerating purposes, 33
 Aqueous vapour in air, table of, 78
 vapour, tension of, 152
 Areas, diameters and displacements, 167
 Argentine Republic, mean temperatures and extremes for the year, 88, 89
 Atmospheric condensers, 33

- BARREL** pumps, quantity of water discharged by, per minute, 165
- Boiling point, latent heat, etc., of anhydrous ammonia, 36, 37
- point of liquids available for use in refrigerating machines, 35
- Box or tank, freezing, 104, 105
- Breweries, estimate of refrigeration in, 70, 72
- Brine circulation, loss of efficiency with, 23
- Brine for use in refrigerating and ice-making plants, 105, 106
- British measures, comparison of, with U.S. standards, 173
- British thermal unit, 161
- Butter freezing rates, 98
- CALCIUM** chloride, solutions of, 106, 107
- Calorie, 161
- Can ice, freezing times for different temperatures and thicknesses of, 111
- Cans, ice, time required for water to freeze in, 111
- Capacities of ice-making plants, 101
- refrigerating, 73
- Capacity, etc., of refrigerating machine, variations in, 74
- of compressor in cubic inches, 27-30
- of refrigerating machines, 25, 26
- Carbonic acid and ammonia machines, comparative tests of, 23
- acid gas, saturated, properties of, 62
- acid machines, leaks in, 145-147
- Cascade system of producing very low temperatures, 23
- Ceilings for cold stores and ice-houses, 133, 134
- Centrifugal fans, 163
- Centrifugal pumps, power required to drive, 164
- Chemical or liquefaction process, 2, 3
- Chloride of calcium, solutions of, 106, 107
- of calcium, properties of solution of, 107, 108
- of sodium, properties of solution of, 108
- Cities of the world, mean temperatures of principal, 85-87
- Co-efficients for efflux of air from orifices, 163
- Cold-air machines, 5, 6
- air machines, formula for calculating amount of air delivered by, 67
- air machines, results of test experiments with, 22
- storage, 68-99
- storage, amount of refrigerating pipes necessary for chilling storage and freezing chambers, 69
- storage and freezing rates, terms of payment of, 99
- storage charges, England, 90, 91
- storage charges, France, 99
- storage charges, United States, 91-95
- storage of various articles, temperatures adapted for, 80-84
- stores, divisional partitions for, 130, 131
- stores, floors for, 131-133
- stores, lighting, 149, 150
- stores, walls for, 127-130
- Combustion of various fuels, heat of, 159
- Common salt, *see* Chloride of sodium
- Comparative efficiency of various refrigerating machines, 20
- tests as to efficiency of ammonia and carbonic acid machines, 23
- Comparison between scales of Centigrade and Fahrenheit thermometers, 170
- of British measures with U.S. standards, 173
- of various hydrometer scales, 109, 110
- Composition and specific heat of victuals, 79

- Compressed air, loss of pressure by friction of, in pipes, 162
- Compression machines, 9-11
 machines, management of ammonia, 141-144
 plant, efficiency of, under different conditions, 61
 temperatures to which ammonia gas is raised by, 41-43
- Compressor, capacity in cubic inches, 27-30
 mean pressure of, 31
 diagram, interpretation of, 137-141
 capacities, relative, 23
- Condensers, 33
- Conditions of deposit and regulations, cold storage, 91
- Constant of gases, physical, 153
- Convert degrees, Centigrade or Reaumur, into Fahrenheit, to, 171
- Cooler, fore, 38
- Cooling wort, experiments in, 151
 power, effective, 21-23
- Cork, *see* Insulation
- Correct relative humidity in egg-rooms, 99
- Cubic feet of ammonia gas per minute to produce one ton of refrigeration per day, 75
 feet of gas that must be pumped per minute, at different condenser and suction pressures, to produce one ton of refrigeration in 24 hours, 32
- Cubic feet of space per running foot of 2-inch pipe, 70
 feet covered by one foot of 1-inch iron pipe, 71
- Curves, efficiency, of perfect refrigerating machine, 64
- D**AILY report, suggested form of engineer's, 148
- Decimal equivalents of fractions of an inch, 173
- Deep wells, power required to raise water from, 165
- Degrees, Centigrade or Reaumur, to convert into Fahrenheit, 171
- Deposit and regulations, cold storage conditions, 91
- Diagram, compressor, interpretation of, 137-141
- Diameters, areas and displacements, 166
- Dimensions of ice-making tanks, 102
 of standard wrought-iron pipes, 168
- Displacements, *see* Diameters, areas, etc.
- Divisional partitions for cold stores, 130, 131
- Door insulation, 134
- Double pipe condenser, 34
- E**FFECTIVE cooling power obtainable from expenditure of one pound of steam in theoretically perfect machines, 22
- Efficiency, comparative, of various refrigerating machines, 22
 of ammonia, useful, 60
 of ammonia, compression plant, under different conditions, 61
- Efficiency curves of perfect refrigerating machine, 64
- Efficiency of ether machines, 66, 67
 of hydraulic ram, 164
- Efflux of air from orifices, coefficients of, 163
- Egg freezing rates, 98
 rooms, correct relative humidity in, 79
- Engineer's daily report, suggested form of, 148
- Entropy or theta-phi diagram, application of, to refrigerating machines, 11-20
- Ether machines, efficiency of, 66, 67
 properties of saturated vapour of, 65
- Evaporation of liquids, 34
- Expansion in steam pipes, 175
- Experiments in wort cooling, 151
- Extreme limits of cubic feet of space per running foot of 2-in. pipe, 70

FANS, centrifugal, 163
 power required for, 163
 proportions of, 163
Fish, freezing rates for, 97, 98
Flooring for cold stores, 131-133
 for ice houses, 133
Fore cooler, 38
Form of engineer's daily report,
 suggested, 148
Formula for ascertaining units of
 refrigeration required to carry off
 heat radiated through walls, etc.,
 125
Formula for calculating amount of
 air delivered per hour by cold-
 air machines, 67
Fractions of an inch and decimal
 equivalents, 173
Freezing mixtures, 4, 5
Freezing rates for butter, 98
 rates for eggs, 98
 rates for fish and meats, 97,
 98
 rates for poultry, game, fish,
 meats, etc., 96-99
 rates, summer, 97
 tank or box, 104, 105
Friction in pipes, 169
 of compressed air in pipes, loss
 of pressure by, 162
 of air in tubes, 162

GAME, rate for freezing in un-
 broken packages, 96, 97
Gases, physical constant of, 153
 specific gravities of, 35, 173
 specific heat of, 161
General tables and memoranda,
 151-175
Gravities, specific, and percentages
 of ammonia, 35

HEA T, mechanical theory of, 1-3
 of combustion of various fuels,
 159
 specific, of gases, 161
 specific, of liquids, 161
 specific, of metals, 160
 specific, of water at various
 temperatures, 160

Horse-powers, various, 172, 175
Humidity of air, relative, 77
Hydraulic ram, efficiency of, 164
 ram, proportions of the supply
 pipes and delivery pipes to
 the number of gallons, 164
Hydrometer scales, comparison of
 various, 109, 110
Hydrometers, 78

ICE-houses, ceilings for, 133, 134
 houses, flooring for, 133
 making, 100-111
 making and storing ice, 100-114
 making plants, brine for use in,
 105, 106
 making plant, information re-
 quired to estimate for, 174,
 175
 making plants, sizes and capa-
 cities of, 101
 making tanks, dimensions of, 102
 storing, 111-114
 strength of, 168
Ich, decimal equivalents of frac-
 tions of, 173
Information required to estimate for
 cost of ice-making plant, 174, 175
Information required to estimate for
 cost of refrigerating plant, 174
 useful, 171, 172
Insulation, 115-135
 door, 134
 tank, 135
 window, 134
Interpretation of compressor dia-
 gram, 137-141

LATENT heat, boiling point, etc.,
 of anhydrous ammonia, 36, 37
Leaks in ammonia apparatus, 145
 in carbonic acid machines, 145-
 147
Lighting cold stores, 149, 150
Lineal feet of 1-inch pipe required
 per cubic foot of cold storage
 space, 70

Liquefaction process, chemical or, 2, 3
 Liquid receiver, 60
 Liquids, evaporation of, 34
 specific heat of, 161
 Liquor ammonia, strength of, 40
 Loss of efficiency with brine circulation, 23, 74
 Loss of pressure by friction of compressed air in pipes, 162
 Low temperatures, production of, 24-26
 Lubrication of refrigerating machinery, 147

MACHINERY, refrigerating, lubrication of, 147
 Machines, absorption, 7-9
 carbonic acid, 145-147
 cold-air, 5, 6
 compression, 8-11
 leaks in ammonia, 145
 vacuum, 6, 7
 Management of ammonia compression machines, 141-144
 of refrigerating machinery, 136-148
 Manufacturers, information required by, to enable them to estimate for the cost of an ice plant, 174, 175
 Manufacturers to estimate for the cost of refrigerating plant, 174
 Mean pressure of compressor, 31
 temperatures of principal cities of the world, 85-87
 temperatures and extremes of the year, Argentine Republic, 88, 89
 Meats, freezing, rates for, 97, 98
 Mechanical theory of heat, 1-3
 Memoranda, general tables and, 151-175
 Metals, specific heat of, 160
 Mineral water, rule for ascertaining quality of, 103
 Mixtures, table of freezing, 4, 5
 Moisture in air, determination of, 75, 76

NON-conductive values of various substances, results of tests as to, 116-125
 Number of cubic feet covered by one foot of 1-inch pipe, 71
 covered by one ton, refrigerating capacity for 24 hours, 71
 of cubic feet of gas that must be pumped per minute, at different condenser and suction pressures, to produce one ton of refrigeration in 24 hours, 32

OPEN-AIR condensers, 33
 Orifices, co-efficients for efflux of air from, 163

PARTITIONS for cold stores, divisional, 130, 131
 Payment of cold storage and freezing rates, terms of, 99
 Percentages, handy rule, 159
 of ammonia, *see* Specific gravities and percentages
 Physical constant of gases, 153
 Pictet's liquid, 67
 Pipes, friction of water in, 169
 loss of pressure by friction of compressed air in, 162
 Poultry, game, etc., rates for freezing in unbroken packages, 96, 97
 storing unfrozen, 97
 Power required for fans, 163
 required to drive centrifugal pumps, 164
 required to raise water from deep wells, 165
 Pressure and boiling point of liquids available for use in refrigerating apparatus, 35
 loss of, by friction of compressed air in pipes, 162
 of compressor, mean, 31
 of water, 167
 ratio of, sulphurous acid, ammonia, and carbonic acid, 23

Principal cities of the world, mean temperatures of, 85-87
 liquids employed in refrigeration, qualities of, 11
 Production of very low temperatures, 24, 25
 Properties of saturated ammonia gas, 44
 of saturated carbonic acid gas, 62
 of saturated steam, 154-158
 Proportions of fans, 163
 Psychrometers, 76
 Pumps, barrel, quantity of water discharged per minute by, 165
 Pure water, 103

QUALITIES of principal liquids employed in refrigeration, 11
 Quantity of water discharged per minute from barrel pumps, 165

RADIATION through walls, etc., 125, 126
 Ram, *see* Hydraulic ram
 Rates for freezing poultry, game, etc., 96-99
 Ratio of pressure of sulphurous acid, ammonia, and carbonic acid, 21
 Reagents, testing by, 104
 Receiver, liquid, 60
 Refrigerating apparatus, 2-11
 and ice-making plants, brine for use in, 105, 106
 capacities, 72
 capacity in B.T.U. required, per cubic foot of storage room, in 24 hours, 72
 effect of one cubic foot of ammonia gas at different condenser and suction (back) pressures in B.T. units, 89
 machinery, lubrication of, 147
 machinery, testing and management of, 136, 137
 machines, capacity of, 25, 26
 machines, comparative efficiency of, 22

Refrigerating machines, variations in capacity of, 74
 plant, information required to estimate for, 174
 Refrigeration in general, 2-11
 Regenerative process or self-intensive refrigeration, 23-25
 Relative humidity of air per cent., 77
 humidity in egg-rooms, correct, 79
 Rent of rooms, 98
 Report, suggested form of engineer's daily, 148
 Results of test experiments with cold-air machines, 22
 of tests to determine the non-conductive values of different materials, 116-127
 Rooms, rent of cold storage, 98
 Rough estimate of refrigeration in breweries, 73

SALT, common, *see* Chloride of sodium
 Saturated ammonia gas, properties of, 44
 ammonia, Wood's table of, 49-58
 carbonic acid gas, properties of, 62
 steam, properties of 154-158
 sulphur dioxide gas, 63
 vapour of ether, properties of, 65
 Scales of Centigrade and Fahrenheit thermometers, comparison of, 170
 Self-intensive refrigeration, 23-25
 Sizes and capacities of ice-making plants, 101
 Slag-wool, *see* Insulation
 Sodium, properties of solution of chloride of, 108
 Solubility of ammonia in water at different temperatures, 38-40
 of ammonia in water at different temperatures and pressures, 39

Solutions of chloride of calcium, 96,
97
 of chloride of calcium, prop-
 erties of, 107, 108
 of chloride of sodium, properties
 of, 108
Specific gravities and percentages of
 ammonia, 35
Specific gravities of gases, 35, 173
Specific heat and composition of
 victuals, 79
 heat of gases, 161
 heat of liquids, 161
 heat of metals, etc., 160
 heat of water at various tem-
 peratures, 160
Standard wrought-iron pipes, dimen-
 sions of, 168
Steam pipes, expansion in, 175
Steam saturated, properties of, 154,
 158
Storage charges, cold, England, 90,
 91
 charges, cold, United States,
 92-95
 cold, 68-99
Stores cold, ceilings for, 133, 134
 cold, divisional partitions for,
 130, 131
 cold, flooring for, 131-133
 cold, walls for, 127-130
Storing ice, 111-114
 unfrozen poultry, etc., 97
Strength of ice, 168
Strength of liquor ammonia, 40
Submerged condensers, 33
Suggested form of engineer's daily
 report, 148
Sulphur dioxide, useful efficiency of,
 64
Summer freezing rates, 97

TABLES and memoranda, gene-
 ral, 151-175

Tank insulation, 135
Tank or box, freezing, 104, 105
Temperatures adopted for the cold
 storage of various articles, 80-84
 mean, of principal cities in the
 world, 85-87

Temperatures, mean and extremes
 of year, Argentine Republic,
 88, 89
 to which ammonia gas is raised
 by compression, 41-43
Tension of aqueous vapour, 152
Terms of payment of cold storage
 and freezing rates, 99
Testing, 136, 137
Testing and management of refrige-
 rating machinery, 136-148
Testing by reagents, 104
Tests of ammonia and carbonic acid
 machines, comparative, 23
Tests to determine the non-conduc-
 tive values of various substances,
 116-127
Theory of heat, mechanical, 1, 3
Thermometers, comparison between
 scales of Centigrade and Fahren-
 heit, 170
Theta-phi diagram, application of,
 to refrigerating machines, 11-20
Time required for water to freeze in
 ice cans, 111
Transmission of heat through insula-
 ting structures, 115, 126
Tubes, friction of air in, 162

UNFROZEN poultry, etc.
 storing, 97

United States Standards, compari-
 son of British measures with, 173
Units of heat, 161
Units of refrigeration to carry off
 radiation through wall, 125
Useful efficiency of ammonia, 60
 efficiency of sulphur dioxide, 64
 information, 171, 172

VACUUM machines, 7, 8
 Vapour, aqueous, in air, 78
Vapour, aqueous, tension of, 152
 of ether, properties of saturated,
 65
Variation in capacity of refrigerating
 machine, 74

- Various articles, temperatures adapted for cold storage of, 80-84
fuels, heat of combustion of, 159
hydrometer scales, comparison of, 109
Very low temperatures, production of, 23-25
Victuals, specific heat and composition of, 79
Volume of ammonia gas at high temperatures, 48
of one pound of ammonia gas at various pressures and temperatures, 45-48
- W**ALLS for cold stores, 127-130
radiation through, 125, 126
Water, friction of, in pipes, 169
Water, mineral, rule for ascertaining quality of, 103, 104
- Water power required to raise from deep wells, 165
pressure of, 167
pure, 103
quantity discharged per minute by barrel pumps, 165
solubility of ammonia in, 38-40, 143
specific heat of at various temperatures, 160
time required for, to freeze in ice cans, 111
Window insulation, 135
Wood's table of saturated ammonia gas, 49-58
Wort cooling, experiments in, 151
Wrought-iron pipe, dimensions, etc., of, 168
- Y**IELD of anhydrous ammonia from ammonia solutions, 41

